

OSTROV DIKSON, Russian Federation

WMO: 206740

Lat: 73.514N

Lon: 80.406E

Elev: 46

StdP: 100.77

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-38.4	-36.6	-41.0	0.1	-38.2	-39.1	0.1	-36.5	19.7	-24.0	17.5	-22.7	4.2	190	1.136

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	15.7	12.8	13.3	11.3	11.1	9.7	13.1	15.5	11.3	13.1	9.8	11.1	4.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	8.6	14.3	10.2	7.8	12.4	8.7	7.0	10.9	37.1	15.6	32.7	13.4	29.0	11.2	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.9	13.3	DB	-39.3	18.5	2.8	2.8	-41.3	20.5	-43.0	22.2	-44.6	23.7	-46.6	25.8	(4)
(5)			WB	-39.4	14.7	2.8	2.1	-41.4	16.3	-43.0	17.5	-44.6	18.7	-46.6	20.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.9	-23.6	-24.2	-20.6	-15.3	-7.1	1.2	5.9	6.1	2.4	-6.0	-16.7	-21.5	(6)
(7)		DBStd	12.68	7.62	7.88	7.59	6.23	4.30	3.12	3.94	3.12	3.28	5.95	6.43	7.76	(7)
(8)		HDD10.0	7276	1042	957	948	758	532	266	142	129	230	497	799	976	(8)
(9)		HDD18.3	10294	1301	1190	1207	1008	790	514	386	380	479	756	1049	1234	(9)
(10)		CDD10.0	24	0	0	0	0	0	2	14	7	1	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.4	6.9	6.7	6.4	6.3	6.3	6.1	5.7	5.8	6.1	6.7	6.3	7.2	(14)
(15)	Precipitation	PrecAvg	359	37	27	22	18	20	27	35	42	43	33	24	32	(15)
(16)		PrecMax	561	222	98	70	47	48	62	71	81	83	74	54	82	(16)
(17)		PrecMin	181	2	0	2	1	3	6	4	9	9	2	1	4	(17)
(18)		PrecStd	86	36	18	15	12	12	13	18	17	16	16	14	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.3	-2.8	-1.7	1.0	2.9	15.3	20.4	17.3	12.7	4.2	-0.8	-2.4	(19)
(20)			MCWB	-3.7	-3.2	-2.1	0.5	1.5	11.2	15.1	13.6	11.3	3.6	-1.1	-2.7	(20)
(21)		2%	DB	-5.9	-5.3	-4.0	-1.1	0.6	10.8	17.2	14.4	9.7	2.8	-2.7	-3.9	(21)
(22)			MCWB	-6.3	-5.6	-4.4	-1.7	0.1	8.5	13.6	12.4	8.8	2.1	-3.1	-4.1	(22)
(23)		5%	DB	-8.8	-8.4	-6.3	-3.1	-0.1	7.5	14.5	12.5	8.0	1.6	-4.8	-6.4	(23)
(24)			MCWB	-9.1	-8.7	-6.6	-3.7	-0.5	6.2	12.0	11.0	7.4	1.1	-5.1	-6.6	(24)
(25)		10%	DB	-12.4	-12.6	-9.0	-5.6	-1.2	5.1	11.9	10.7	6.5	0.6	-7.0	-9.8	(25)
(26)			MCWB	-12.7	-12.9	-9.3	-6.1	-1.7	4.2	10.0	9.6	5.8	0.1	-7.3	-10.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.7	-3.0	-2.0	0.5	1.5	11.4	15.6	14.1	11.3	3.9	-1.1	-2.5	(27)
(28)			MCDWB	-3.3	-2.7	-1.8	0.9	2.4	14.7	18.9	16.1	12.5	4.0	-1.0	-2.3	(28)
(29)		2%	WB	-6.2	-5.5	-4.3	-1.6	0.2	8.7	13.9	12.7	9.1	2.2	-3.0	-4.1	(29)
(30)			MCDWB	-5.9	-5.3	-4.0	-1.2	0.6	10.5	16.8	14.3	9.7	2.6	-2.7	-3.9	(30)
(31)		5%	WB	-9.1	-8.7	-6.6	-3.7	-0.5	6.3	12.0	11.1	7.4	1.2	-5.1	-6.6	(31)
(32)			MCDWB	-8.8	-8.3	-6.3	-3.2	-0.2	7.5	14.5	12.2	7.9	1.5	-4.8	-6.4	(32)
(33)		10%	WB	-12.7	-12.9	-9.3	-6.1	-1.7	4.2	10.2	9.7	5.9	0.2	-7.4	-10.0	(33)
(34)			MCDWB	-12.4	-12.6	-9.0	-5.6	-1.3	5.0	11.8	10.7	6.4	0.6	-7.0	-9.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.2	6.3	6.0	4.0	3.0	4.2	3.3	2.5	3.7	5.6	5.8	(35)
(36)			MCDBR	9.1	9.2	7.2	6.4	4.0	6.7	7.9	6.0	4.2	2.5	6.9	7.8	(36)
(37)			MCWBR	9.0	9.2	7.2	6.4	3.9	5.2	5.4	4.5	3.5	2.8	6.9	7.7	(37)
(38)		5% WB	MCDBR	9.1	9.1	7.1	6.5	4.0	6.6	7.6	5.5	4.0	2.5	6.9	7.8	(38)
(39)			MCWBR	9.0	9.1	7.1	6.5	3.9	5.3	5.5	4.5	3.6	2.8	6.9	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.193	0.279	0.304	0.326	0.335	0.362	0.345	0.304	0.356	N/A	N/A	(40)	
(41)		taud	N/A	1.872	1.998	2.053	2.111	2.340	2.397	2.434	2.408	2.737	N/A	N/A	(41)	
(42)		Ebn at Noon	0	326	626	780	822	837	793	753	651	318	0	0	(42)	
(43)		Edh at Noon	0	26	74	106	117	98	90	75	53	22	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.13	1.40	3.77	5.68	5.30	4.32	2.62	1.12	0.25	0.00	0.00	(44)	
(45)		RadStd	0.00	0.01	0.10	0.26	0.40	0.41	0.54	0.43	0.12	0.03	0.00	0.00	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+1.59	+1.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (1 neighbor)	+1.59	+1.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page