

TAMBEY, Russian Federation

WMO: 208640

Lat: 71.483N

Lon: 71.817E

Elev: 26

StdP: 14.68

Time Zone: 5.00 (E05)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.5	(c) -37.4	(d) -44.9	(e) 0.4	(f) -39.9	(g) -41.8	(h) 0.5	(i) -37.1	(j) 34.5	(k) -1.6	(l) 30.4	(m) 1.0	(n) 7.2	(o) 160	(p) 1.113

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.0	(c) 59.3	(d) 53.8	(e) 54.5	(f) 51.1	(g) 50.6	(h) 48.1	(i) 54.7	(j) 57.9	(k) 51.5	(l) 54.3	(m) 48.5	(n) 50.4	(o) 12.6	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
52.9	59.6	56.2	49.7	52.8	52.9	46.8	47.4	49.3	23.0	57.8	21.1	54.6	19.5	50.5	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 32.4	(b) 28.6	(c) 25.8	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 32.4	(b) 28.6	(c) 25.8	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	-13.8	-13.0	-5.5	-0.4	19.5	33.8	43.1	43.1	37.7	19.6	1.8	-9.0		
	DBStd	24.34	14.60	15.85	15.18	14.27	8.91	6.00	5.66	4.80	5.08	11.04	15.06	14.52		
	HDD50	13453	1979	1765	1720	1513	946	488	231	223	369	942	1446	1831		
	HDD65	18901	2444	2185	2185	1963	1411	937	680	679	818	1407	1896	2296		
	CDD50	27	0	0	0	0	0	0	17	9	1	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	9	0	0	0	0	0	0	9	0	0	0	0	0		
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0		
	WSAvg	12.9	12.6	13.1	13.3	13.6	13.4	11.4	11.5	12.8	12.4	14.1	13.8	13.3		
	PrecAvg	25.4	2.2	2.0	1.9	1.9	1.8	2.0	1.9	2.1	2.1	2.8	2.3	2.4		
	PrecMax	34.8	5.9	4.3	5.2	3.9	3.1	3.8	4.1	4.3	4.1	4.3	4.2	4.2		
(15) Precipitation	PrecMin	17.8	0.5	0.6	0.5	0.4	1.0	0.4	0.5	0.7	0.6	1.2	0.3	0.9		
	PrecStd	5.0	1.1	0.8	0.9	0.8	0.4	0.9	1.0	0.7	0.8	0.8	0.8	0.9		
	DB	25.3	27.3	30.5	34.0	37.6	58.4	74.5	62.9	53.0	41.5	32.9	27.3			
	MCWB	25.2	27.1	29.5	33.1	35.9	51.9	64.7	55.4	51.7	40.5	31.8	26.2			
	2% DB	19.5	21.7	27.5	31.8	34.0	50.2	63.0	57.7	48.6	38.4	30.7	23.4			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	19.0	21.5	26.6	31.0	32.8	46.8	57.2	53.2	46.6	37.3	30.0	22.5			
	5% DB	13.6	16.8	24.2	29.5	33.0	44.9	55.9	53.7	47.0	35.7	28.4	18.3			
	MCWB	13.2	16.4	23.6	28.7	32.0	42.2	52.2	51.0	45.4	35.0	27.7	17.6			
	10% DB	7.4	11.7	19.6	25.0	31.9	41.0	51.6	50.3	45.1	33.4	25.7	12.7			
	MCWB	7.0	11.3	19.0	24.5	31.2	39.1	49.0	48.1	43.7	32.6	25.0	12.1			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	25.0	27.2	30.0	33.3	35.8	53.1	65.5	58.1	51.2	40.4	32.3	25.8			
	MCDB	25.4	27.4	30.4	33.8	37.4	56.5	73.8	62.2	52.2	41.0	32.7	26.6			
	2% WB	19.4	21.5	26.8	31.1	33.2	46.9	57.5	53.5	47.1	37.6	30.2	22.4			
	MCDB	19.6	21.7	27.6	31.6	33.6	50.1	63.1	55.9	48.1	38.3	30.7	23.1			
	5% WB	13.1	16.6	23.7	28.7	32.3	42.3	52.8	51.1	45.6	35.1	27.9	17.5			
(31) Mean Daily Temperature Range	MCDB	13.3	17.0	24.3	29.4	33.0	44.4	55.7	53.8	46.7	35.7	28.4	18.2			
	10% WB	7.0	11.4	19.0	24.1	31.1	39.0	49.0	48.6	43.9	32.9	25.1	12.1			
	MCDB	7.3	11.7	19.7	24.7	31.9	40.7	51.4	50.2	45.0	33.4	25.8	12.6			
	5% DB	13.1	14.0	15.2	15.9	9.8	6.7	10.5	8.0	6.0	9.2	11.7	13.4			
	MCDBR	19.5	21.3	17.9	12.1	6.6	15.1	21.4	14.8	8.7	7.6	11.9	20.3			
(36) Clear-Sky Solar Irradiance	MCWBR	19.4	21.2	17.9	12.6	6.5	11.5	16.1	10.6	7.1	7.9	11.9	20.0			
	5% WB	19.6	20.8	17.7	12.5	6.6	14.7	21.3	13.5	7.9	7.6	11.9	20.4			
	MCWBR	19.4	20.8	17.7	12.7	6.6	11.6	16.6	10.5	7.1	7.9	12.0	19.7			
	taub	N/A	0.226	0.288	0.311	0.332	0.341	0.368	0.351	0.308	0.222	N/A	N/A			
	taud	N/A	1.934	2.036	2.074	2.105	2.316	2.360	2.408	2.414	2.063	N/A	N/A			
(42) All-Sky Solar Radiation	Ebn at Noon	0	127	210	252	263	267	253	242	217	129	0	0			
	Edh at Noon	0	11	25	35	39	33	30	26	18	9	0	0			
	RadAvg	0	62	508	1242	1802	1700	1544	946	425	115	0	0			
	RadStd	0	10	44	103	110	169	191	106	39	17	0	0			

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page