

TAMBEY, Russian Federation

WMO: 208640

Lat: 71.483N

Lon: 71.817E

Elev: 8

StdP: 101.23

Time Zone: 5.00 (E05)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.3	(c) -38.5	(d) -42.7	(e) 0.1	(f) -39.9	(g) -41.0	(h) 0.1	(i) -38.4	(j) 15.4	(k) -18.7	(l) 13.6	(m) -17.2	(n) 3.2	(o) 160	(p) 1.113

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.4	(c) 15.1	(d) 12.1	(e) 12.5	(f) 10.6	(g) 10.3	(h) 8.9	(i) 12.6	(j) 14.4	(k) 10.8	(l) 12.4	(m) 9.1	(n) 10.2	(o) 5.6	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	8.5	13.4	9.8	7.5	11.6	8.2	6.8	9.6	35.7	14.3	31.3	12.5	27.4	10.3	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.5	(b) 12.8	(c) 11.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.4	-25.5	-25.0	-20.8	-18.0	-7.0	1.0	6.2	6.2	3.2	-6.9	-16.8	-22.8
	DBStd	13.52	8.11	8.80	8.44	7.93	4.95	3.33	3.15	2.67	2.82	6.14	8.37	8.06
	HDD10.0	7474	1099	981	956	841	526	271	128	124	205	523	803	1017
	HDD18.3	10501	1358	1214	1214	1091	784	521	378	377	454	782	1053	1276
	CDD10.0	15	0	0	0	0	0	0	9	5	1	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	5	0	0	0	0	0	0	5	0	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	5.8	5.6	5.9	5.9	6.1	6.0	5.1	5.1	5.7	5.5	6.3	6.2	5.9
Precipitation	PrecAvg	645	57	51	48	48	45	50	47	54	54	71	58	61
	PrecMax	885	150	109	133	98	79	97	104	109	104	110	107	106
	PrecMin	452	13	14	12	11	25	9	12	19	15	30	7	24
	PrecStd	126	29	21	24	20	11	23	26	19	20	20	20	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.7	-2.6	-0.8	1.1	3.1	14.7	23.6	17.2	11.7	5.3	0.5	-2.6
		MCWB	-3.8	-2.7	-1.4	0.6	2.2	11.1	18.2	13.0	11.0	4.7	-0.1	-3.2
	2%	DB	-6.9	-5.7	-2.5	-0.1	1.1	10.1	17.2	14.3	9.2	3.5	-0.7	-4.8
		MCWB	-7.2	-5.8	-3.0	-0.5	0.4	8.2	14.0	11.8	8.1	2.9	-1.1	-5.3
	5%	DB	-10.2	-8.4	-4.3	-1.4	0.6	7.2	13.3	12.0	8.3	2.1	-2.0	-7.6
		MCWB	-10.4	-8.6	-4.7	-1.8	0.0	5.7	11.2	10.5	7.5	1.7	-2.4	-8.0
	10%	DB	-13.7	-11.3	-6.9	-3.9	0.0	5.0	10.9	10.2	7.3	0.8	-3.5	-10.7
		MCWB	-13.9	-11.5	-7.2	-4.2	-0.5	4.0	9.4	9.0	6.5	0.3	-3.9	-11.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.9	-2.7	-1.1	0.7	2.1	11.7	18.6	14.5	10.7	4.7	0.1	-3.4
		MCDB	-3.7	-2.5	-0.9	1.0	3.0	13.6	23.2	16.8	11.2	5.0	0.4	-3.0
	2%	WB	-7.0	-5.8	-2.9	-0.5	0.7	8.3	14.2	12.0	8.4	3.1	-1.0	-5.4
		MCDB	-6.9	-5.7	-2.5	-0.2	0.9	10.0	17.3	13.3	8.9	3.5	-0.7	-4.9
	5%	WB	-10.5	-8.6	-4.6	-1.9	0.2	5.7	11.5	10.6	7.5	1.7	-2.3	-8.0
		MCDB	-10.4	-8.3	-4.3	-1.4	0.5	6.9	13.2	12.1	8.1	2.1	-2.0	-7.7
	10%	WB	-13.9	-11.4	-7.2	-4.4	-0.5	3.9	9.5	9.2	6.6	0.5	-3.8	-11.1
		MCDB	-13.7	-11.3	-6.8	-4.1	0.0	4.9	10.8	10.1	7.2	0.8	-3.5	-10.8
Mean Daily Temperature Range		MDBR	7.3	7.8	8.5	8.8	5.4	3.7	5.9	4.4	3.3	5.1	6.5	7.4
	5% DB	MCDBR	10.8	11.8	9.9	6.7	3.6	8.4	11.9	8.2	4.8	4.2	6.6	11.3
		MCWBR	10.8	11.8	9.9	7.0	3.6	6.4	9.0	5.9	3.9	4.4	6.6	11.1
	5% WB	MCDBR	10.9	11.6	9.8	6.9	3.7	8.2	11.8	7.5	4.4	4.2	6.6	11.3
		MCWBR	10.8	11.6	9.8	7.0	3.7	6.5	9.2	5.8	3.9	4.4	6.7	10.9
Clear-Sky Solar Irradiance	taub	N/A	0.226	0.288	0.311	0.332	0.341	0.368	0.351	0.308	0.222	N/A	N/A	
	taud	N/A	1.934	2.036	2.074	2.105	2.316	2.360	2.408	2.414	2.063	N/A	N/A	
	Ebn at Noon	0	399	663	794	828	841	798	764	684	407	0	0	
	Edh at Noon	0	36	79	109	122	103	96	81	57	29	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.20	1.60	3.92	5.68	5.36	4.87	2.98	1.34	0.36	0.00	0.00	
	RadStd	0.00	0.03	0.14	0.33	0.35	0.53	0.60	0.33	0.12	0.05	0.00	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page