

IM E K FEDOROVA, Russian Federation

WMO: 209460

Lat: 70.447N

Lon: 59.091E

Elev: 40

StdP: 14.67

Time Zone: 3.00 (E03)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.0	-19.5	-30.1	1.0	-23.7	-25.5	1.3	-19.6	43.9	12.5	39.8	15.8	11.3	130	1.101

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	60.5	55.8	55.7	52.7	52.2	49.9	56.5	60.5	52.9	55.7	50.0	51.9	16.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.4	63.1	58.0	50.9	55.3	54.3	48.5	50.5	51.7	24.2	60.7	22.0	55.7	20.3	52.1	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.7	33.8	30.6	-22.9	65.5	8.7	6.8	-29.2	70.3	-34.2	74.3	-39.1	78.1	-45.4	83.1		
(5)			-23.4	59.1	8.2	4.4	-29.3	62.2	-34.1	64.8	-38.7	67.2	-44.7	70.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.2	4.0	6.0	7.6	17.0	25.2	35.8	44.0	44.2	40.6	30.7	20.1	14.6	(6)
(7)		DBStd	17.02	13.48	13.95	14.05	9.67	6.63	5.70	6.90	4.31	3.88	6.02	9.40	10.96	(7)
(8)		HDD50	9447	1427	1233	1315	989	768	431	216	189	283	599	898	1099	(8)
(9)		HDD65	14879	1892	1653	1780	1439	1233	877	650	646	733	1064	1348	1564	(9)
(10)		CDD50	45	0	0	0	0	0	4	31	9	1	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	15.9	16.0	17.1	16.3	15.6	14.7	13.5	13.0	14.4	15.2	17.5	18.8	18.5	(14)
(15)	Precipitation	PrecAvg	7.6	0.3	0.4	0.3	0.3	0.4	0.6	0.8	1.0	1.1	1.2	0.8	0.6	(15)
(16)		PrecMax	13.1	1.0	1.2	1.1	1.0	1.5	1.7	1.9	3.0	2.8	2.3	1.8	1.7	(16)
(17)		PrecMin	2.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.4	0.2	0.2	(17)
(18)		PrecStd	2.8	0.3	0.4	0.3	0.2	0.3	0.5	0.7	0.7	0.7	0.5	0.4	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	31.9	32.4	36.7	43.3	63.1	69.6	60.6	52.7	42.2	35.1	33.4	(19)
(20)		MCWB	31.2	30.8	31.3	34.0	40.8	55.3	59.5	55.7	49.8	40.6	33.6	33.0		(20)
(21)		2%	DB	29.9	29.5	30.9	33.3	37.2	52.5	63.2	56.1	50.0	40.5	33.7	31.5	(21)
(22)		MCWB	29.4	28.9	30.1	32.1	35.6	48.6	57.9	53.2	48.1	38.9	32.7	30.9		(22)
(23)		5%	DB	27.3	27.2	29.5	32.3	34.7	46.4	58.8	53.0	47.7	39.5	32.3	30.2	(23)
(24)		MCWB	26.9	26.6	28.9	31.5	33.5	43.6	55.6	50.7	46.2	38.0	31.3	29.7		(24)
(25)		10%	DB	23.6	25.0	27.5	30.7	33.2	43.0	54.6	50.2	46.0	38.4	31.2	28.5	(25)
(26)		MCWB	22.8	24.4	26.8	30.1	32.4	41.1	51.9	48.5	44.5	36.9	30.2	27.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.9	31.2	31.9	34.2	40.8	55.8	61.6	56.3	50.6	41.4	34.1	33.0	(27)
(28)		MADB	32.0	31.9	32.3	35.4	43.1	62.9	65.8	58.7	52.0	41.7	34.6	33.1		(28)
(29)		2%	WB	29.4	29.0	30.3	32.5	35.8	48.9	58.6	53.6	48.3	39.5	32.9	31.2	(29)
(30)		MADB	29.8	29.5	30.7	33.2	37.1	52.3	62.0	55.8	49.3	40.1	33.4	31.4		(30)
(31)		5%	WB	26.9	26.7	29.0	31.7	33.6	44.1	55.3	50.9	46.4	38.4	31.5	29.7	(31)
(32)		MADB	27.3	27.2	29.5	32.3	34.2	46.2	59.0	52.8	47.4	39.3	32.1	30.0		(32)
(33)		10%	WB	22.8	24.4	26.8	30.2	32.5	41.2	52.0	48.7	44.8	37.0	30.3	27.8	(33)
(34)		MADB	23.5	24.9	27.5	30.8	33.1	42.9	54.6	50.1	45.8	38.2	31.1	28.4		(34)
(35)	Mean Daily Temperature Range	MDBR	9.9	11.4	10.7	11.0	7.3	6.0	6.8	5.2	4.2	4.9	7.4	9.9		(35)
(36)		5% DB	MADB	11.6	14.6	9.8	9.7	7.7	14.0	15.2	10.5	7.1	4.8	6.7	9.1	(36)
(37)		MCWBR	11.9	14.7	9.9	9.4	7.0	10.5	10.1	8.4	5.9	4.8	6.8	9.2		(37)
(38)		5% WB	MADB	11.3	14.7	9.2	9.2	7.0	14.1	14.2	10.0	6.2	4.8	6.7	8.9	(38)
(39)		MCWBR	11.5	14.8	9.4	8.8	6.6	11.0	9.9	8.4	5.7	4.8	6.9	9.0		(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.242	0.291	0.320	0.336	0.336	0.371	0.352	0.316	0.261	N/A	N/A	(40)	
(41)		taud	N/A	1.941	2.019	2.044	2.096	2.279	2.372	2.450	2.456	2.155	N/A	N/A	(41)	
(42)		Ebn at Noon	0	134	215	251	264	270	254	246	220	132	0	0	(42)	
(43)		Edh at Noon	0	13	27	36	40	34	30	25	18	10	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0	87	550	1215	1736	1800	1562	968	473	118	0	0	(44)	
(45)		RadStd	0	17	63	101	164	179	194	93	34	16	0	0	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+3.10	+5.00	+6.05	+2.95	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page