

SEYAHA, Russian Federation

WMO: 209670

Lat: 70.1697N

Lon: 72.5136E

Elev: 58

StdP: 14.66

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.3	-36.8	-47.2	0.3	-41.3	-42.4	0.5	-36.8	36.7	7.7	33.8	1.5	7.8	340	1.041

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	68.6	60.8	63.7	57.5	60.1	55.6	61.2	67.8	58.5	62.8	55.8	59.6	11.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.0	72.1	64.6	55.9	66.7	62.3	53.3	60.6	58.3	27.3	68.3	25.5	62.7	23.7	59.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
33.9	29.8	26.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	-11.9	-9.3	0.4	8.7	22.2	40.1	51.6	48.3	40.5	25.2	4.9	-2.6	
	DBStd	24.74	15.54	16.46	16.72	11.14	8.31	7.11	8.07	5.44	6.08	8.87	12.03	15.10	
	HDD50	11753	1918	1661	1538	1240	862	309	78	101	292	769	1353	1632	
	HDD65	17043	2383	2081	2003	1690	1327	748	422	520	735	1234	1803	2097	
	CDD50	192	0	0	0	0	0	11	127	47	7	0	0	0	
	CDD65	7	0	0	0	0	0	0	7	0	0	0	0	0	
	CDH74	38	0	0	0	0	0	0	36	2	0	0	0	0	
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0	
Wind	WSAvg	13.2	12.8	12.5	13.6	13.7	15.4	13.6	12.4	13.2	12.4	12.1	13.1	13.5	
Precipitation	PrecAvg	23.7	2.2	2.0	1.7	1.7	1.6	1.7	1.6	2.0	2.2	2.6	2.2	2.3	
	PrecMax	30.6	5.3	5.3	4.5	3.1	2.8	3.1	3.3	3.9	3.9	3.8	5.4	4.0	
	PrecMin	17.5	0.4	0.4	0.4	0.3	0.9	0.3	0.4	0.6	0.7	1.4	0.4	1.0	
	PrecStd	3.6	1.0	1.0	0.8	0.7	0.5	0.7	0.8	0.7	0.8	0.6	0.8	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	28.4	31.8	34.2	42.0	64.7	78.7	66.8	58.8	41.5	32.3	29.5	
		MCWB	28.0	28.1	31.2	33.2	39.3	56.8	63.5	59.3	53.4	39.3	31.8	29.3	
	2%	DB	23.5	24.0	29.5	32.4	36.9	60.1	73.1	62.9	54.6	38.8	29.6	26.4	
		MCWB	23.2	23.5	28.9	31.8	35.2	53.7	63.1	57.0	52.0	37.1	29.3	26.1	
	5%	DB	16.8	21.1	27.1	30.4	34.6	54.9	67.8	59.9	52.4	37.1	26.1	23.3	
		MCWB	16.1	20.6	26.6	30.0	33.5	49.5	60.1	55.7	50.4	36.0	25.5	22.9	
	10%	DB	9.9	15.7	24.5	26.2	32.9	50.9	63.4	57.0	49.3	35.0	22.7	20.4	
		MCWB	9.3	15.2	24.0	25.5	32.2	47.2	57.6	54.0	47.2	34.0	22.2	19.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.8	28.3	31.4	33.7	39.5	57.9	64.8	60.4	54.8	40.3	32.0	29.3
			MCDB	28.6	28.6	31.5	34.4	41.9	63.2	74.6	64.0	58.7	41.2	32.1	29.5
2%		WB	23.2	23.7	28.7	31.9	35.5	53.8	62.9	58.1	52.5	37.6	29.3	26.1	
		MCDB	23.4	24.0	29.2	32.2	36.7	59.4	71.6	61.6	54.3	38.6	29.5	26.3	
5%		WB	16.1	20.6	26.6	29.9	33.7	50.1	60.8	55.9	50.5	36.0	25.8	22.9	
		MCDB	16.6	21.1	27.0	30.4	34.4	54.0	67.4	59.5	52.2	37.1	26.2	23.2	
10%		WB	9.4	15.1	24.0	25.5	32.3	47.3	58.4	53.9	47.2	34.0	22.2	20.0	
		MCDB	9.9	15.6	24.5	26.1	32.8	51.1	62.9	56.7	48.9	34.7	22.7	20.5	
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.8	13.4	14.4	9.2	9.0	10.9	8.4	6.2	7.1	11.5	12.9	
		MCDBR	17.5	15.2	15.1	13.6	7.7	15.8	18.5	12.7	8.7	6.8	14.6	14.1	
		MCWBR	17.1	15.4	15.0	13.8	6.8	11.4	10.5	8.7	6.5	6.1	14.4	13.9	
	5% WB	MCDBR	16.9	15.2	15.5	14.3	7.7	15.3	17.5	11.7	7.5	6.8	15.0	13.3	
		MCWBR	17.0	15.4	15.4	14.5	7.0	11.9	10.6	8.7	6.3	6.3	14.8	13.4	
Clear-Sky Solar Irradiance	taub	N/A	0.238	0.293	0.316	0.334	0.347	0.372	0.356	0.312	0.238	N/A	N/A		
	taud	N/A	1.959	2.032	2.066	2.116	2.318	2.361	2.403	2.431	2.123	N/A	N/A		
	Ebn at Noon	0	142	216	254	265	267	254	244	222	146	0	0		
	Edh at Noon	0	14	27	36	39	33	31	26	19	11	0	0		
All-Sky Solar Radiation	RadAvg	0	84	561	1246	1868	1826	1575	980	456	136	0	0		
	RadStd	0	13	48	111	88	134	200	127	47	19	0	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page