

SEYAHA, Russian Federation

WMO: 209670

Lat: 70.1697N

Lon: 72.5136E

Elev: 18

StdP: 101.11

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.7	(c) -38.2	(d) -44.0	(e) 0.0	(f) -40.7	(g) -41.3	(h) 0.1	(i) -38.2	(j) 16.4	(k) -13.5	(l) 15.1	(m) -16.9	(n) 3.5	(o) 340	(p) 1.041

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.1	(c) 20.4	(d) 16.0	(e) 17.6	(f) 14.2	(g) 15.6	(h) 13.1	(i) 16.2	(j) 19.9	(k) 14.7	(l) 17.1	(m) 13.2	(n) 15.4	(o) 4.9	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	10.3	18.1	13.3	9.5	16.8	11.8	8.7	14.6	45.6	20.2	41.4	17.1	37.3	15.5	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 15.2	(b) 13.3	(c) 11.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.6	-24.4	-23.0	-17.6	-13.0	-5.4	4.5	10.9	9.0	4.7	-3.8	-15.1	-19.2
	DBStd	13.74	8.63	9.14	9.29	6.19	4.62	3.95	4.48	3.02	3.38	4.93	6.68	8.39
	HDD10.0	6529	1066	923	854	689	479	172	43	56	162	427	752	907
	HDD18.3	9468	1324	1156	1113	939	737	416	234	289	408	686	1002	1165
	CDD10.0	107	0	0	0	0	0	6	71	26	4	0	0	0
	CDD18.3	4	0	0	0	0	0	0	4	0	0	0	0	0
	CDH23.3	21	0	0	0	0	0	0	20	1	0	0	0	0
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH27.7	2	0	0	0	0	0	0	2	0	0	0	0	0
(14) Wind	WSAvg	5.9	5.7	5.6	6.1	6.1	6.9	6.1	5.5	5.9	5.6	5.4	5.9	6.0
(15) Precipitation	PrecAvg	603	56	51	42	43	40	43	40	51	55	67	56	58
	PrecMax	778	134	135	114	80	70	80	84	98	100	96	137	101
	PrecMin	445	11	9	9	7	24	7	11	14	18	35	9	26
	PrecStd	91	26	25	21	18	12	18	21	18	20	16	21	20
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.0	-2.0	-0.1	1.2	5.5	18.2	26.0	19.3	14.9	5.3	0.2	-1.4
		MCWB	-2.2	-2.2	-0.4	0.7	4.0	13.8	17.5	15.2	11.9	4.0	-0.1	-1.5
	2%	DB	-4.7	-4.4	-1.4	0.2	2.7	15.6	22.8	17.1	12.5	3.8	-1.3	-3.1
		MCWB	-4.9	-4.7	-1.7	-0.1	1.8	12.0	17.3	13.9	11.1	2.8	-1.5	-3.3
	5%	DB	-8.4	-6.1	-2.7	-0.9	1.4	12.7	19.9	15.5	11.3	2.8	-3.3	-4.9
		MCWB	-8.8	-6.3	-3.0	-1.1	0.8	9.7	15.6	13.2	10.2	2.2	-3.6	-5.1
	10%	DB	-12.3	-9.1	-4.1	-3.2	0.5	10.5	17.5	13.9	9.6	1.7	-5.2	-6.4
		MCWB	-12.6	-9.3	-4.4	-3.6	0.1	8.4	14.2	12.2	8.4	1.1	-5.4	-6.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.3	-2.1	-0.3	1.0	4.2	14.4	18.2	15.8	12.7	4.6	0.0	-1.5
		MCDB	-1.9	-1.9	-0.3	1.3	5.5	17.3	23.7	17.8	14.9	5.1	0.1	-1.4
	2%	WB	-4.9	-4.6	-1.8	0.0	2.0	12.1	17.2	14.5	11.4	3.1	-1.5	-3.3
		MCDB	-4.8	-4.5	-1.6	0.1	2.6	15.2	22.0	16.5	12.4	3.6	-1.4	-3.2
	5%	WB	-8.9	-6.3	-3.0	-1.2	0.9	10.1	16.0	13.3	10.3	2.2	-3.5	-5.0
		MCDB	-8.6	-6.1	-2.8	-0.9	1.4	12.2	19.6	15.3	11.2	2.8	-3.2	-4.9
	10%	WB	-12.6	-9.4	-4.4	-3.6	0.2	8.5	14.7	12.2	8.5	1.1	-5.4	-6.6
		MCDB	-12.3	-9.1	-4.2	-3.3	0.5	10.6	17.2	13.7	9.4	1.5	-5.2	-6.4
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	7.1	7.4	8.0	5.1	5.0	6.1	4.7	3.5	4.0	6.4	7.2
		MCDBR	9.7	8.4	8.4	7.5	4.3	8.8	10.3	7.1	4.8	3.8	8.1	7.9
		MCWBR	9.5	8.5	8.3	7.6	3.8	6.3	5.9	4.8	3.6	3.4	8.0	7.7
	5% WB	MCDBR	9.4	8.5	8.6	7.9	4.3	8.5	9.7	6.5	4.2	3.8	8.3	7.4
		MCWBR	9.5	8.5	8.6	8.0	3.9	6.6	5.9	4.8	3.5	3.5	8.2	7.4
(40) Clear-Sky Solar Irradiance	taub		N/A	0.238	0.293	0.316	0.334	0.347	0.372	0.356	0.312	0.238	N/A	N/A
	taud		N/A	1.959	2.032	2.066	2.116	2.318	2.361	2.403	2.431	2.123	N/A	N/A
	Ebn at Noon		0	448	681	800	835	841	802	768	701	460	0	0
	Edh at Noon		0	43	84	113	123	105	98	83	60	34	0	0
(44) All-Sky Solar Radiation	RadAvg		0.00	0.27	1.77	3.93	5.89	5.76	4.96	3.09	1.44	0.43	0.00	0.00
	RadStd		0.00	0.04	0.15	0.35	0.28	0.42	0.63	0.40	0.15	0.06	0.00	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page