

OSTROV ZHOKHOVA, Russian Federation

WMO: 213580

Lat: 76.150N

Lon: 152.833E

Elev: 46

StdP: 14.67

Time Zone: 10.00 (E10)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.2	-33.7	-40.5	0.5	-35.7	-37.9	0.6	-33.4	35.3	-8.3	31.6	-9.4	4.8	170	1.205

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	41.6	39.9	39.8	38.4	37.9	36.6	40.4	41.4	38.5	39.6	36.8	37.8	14.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
39.5	35.7	40.9	37.3	32.7	39.3	35.3	30.3	37.3	15.4	41.4	14.6	39.9	13.8	38.0	51.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.8	27.2	24.1	-38.7	44.6	3.4	5.6	-41.1	48.7	-43.1	52.0	-45.1	55.1	-47.6	59.2
			-39.0	41.6	3.4	4.7	-41.5	45.0	-43.4	47.7	-45.3	50.3	-47.8	53.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	-19.3	-18.9	-16.8	-4.4	16.1	29.5	34.0	32.6	25.8	8.1	-8.4	-15.5	(6)
(7)		DBStd	21.96	7.60	8.05	8.01	9.88	7.53	3.82	2.76	3.94	6.44	10.34	9.52	8.83	(7)
(8)		HDD50	16289	2147	1930	2071	1633	1052	614	495	541	726	1298	1752	2030	(8)
(9)		HDD65	21764	2612	2350	2536	2083	1517	1064	960	1006	1176	1763	2202	2495	(9)
(10)		CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.7	11.0	10.3	10.8	11.3	11.3	12.3	12.8	13.0	13.8	12.1	10.7	11.3	(14)
(15)	Precipitation	PrecAvg	8.0	0.3	0.3	0.2	0.3	0.4	0.7	1.2	1.5	1.3	0.9	0.5	0.3	(15)
(16)		PrecMax	10.9	0.8	1.1	0.7	0.8	0.9	1.5	2.4	2.9	2.9	1.7	1.0	0.8	(16)
(17)		PrecMin	5.2	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.6	0.6	0.4	0.2	0.0	(17)
(18)		PrecStd	1.5	0.2	0.2	0.2	0.2	0.2	0.3	0.5	0.6	0.5	0.3	0.2	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	4.4	9.6	23.5	32.6	40.1	46.6	45.2	38.3	30.6	20.9	14.7	(19)
(20)		MCWB	5.0	3.9	9.4	23.2	31.1	37.5	42.1	43.9	36.0	30.0	20.4	13.7	(20)	
(21)		2%	DB	0.8	-1.2	2.8	17.2	31.1	36.7	42.3	41.6	35.3	27.5	13.9	5.6	(21)
(22)		MCWB	0.3	-1.6	2.4	16.6	30.0	34.7	40.0	40.4	33.9	26.4	13.0	5.2	(22)	
(23)		5%	DB	-2.8	-4.9	-2.1	13.4	29.3	34.9	39.9	40.1	34.2	25.8	9.3	0.8	(23)
(24)		MCWB	-3.1	-5.3	-2.5	12.7	28.2	33.4	38.2	39.0	32.9	24.7	8.4	0.3	(24)	
(25)		10%	DB	-7.2	-7.9	-5.8	9.6	26.8	33.8	37.9	38.4	33.3	23.0	5.3	-2.8	(25)
(26)		MCWB	-7.5	-8.2	-6.1	9.1	25.8	32.3	36.5	37.5	32.2	22.0	4.6	-3.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	4.4	9.4	22.7	31.6	37.7	43.6	44.0	36.5	30.0	20.2	14.5	(27)
(28)		MDCB	5.3	4.7	9.7	23.0	32.1	39.5	46.3	44.6	38.3	30.7	20.7	15.8	(28)	
(29)		2%	WB	0.4	-1.5	2.7	16.7	30.2	35.3	40.4	40.9	34.3	26.5	13.3	5.3	(29)
(30)		MDCB	0.8	-1.2	3.0	17.1	30.9	36.3	41.9	41.5	35.0	27.2	13.8	5.6	(30)	
(31)		5%	WB	-3.2	-5.2	-2.6	12.9	28.3	33.7	38.4	39.2	33.3	24.7	8.8	0.5	(31)
(32)		MDCB	-2.9	-4.9	-2.3	13.6	29.3	34.5	39.8	39.9	34.0	25.7	9.5	0.8	(32)	
(33)		10%	WB	-7.5	-8.2	-6.0	9.0	25.9	32.7	36.7	37.5	32.3	22.2	4.5	-3.2	(33)
(34)		MDCB	-7.2	-7.9	-5.8	9.5	26.9	33.5	37.9	38.4	33.2	23.0	5.2	-2.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.7	8.1	8.8	10.3	6.7	4.0	3.9	4.0	5.6	9.0	8.9	8.6	(35)	
(36)		5% DB	MCDBR	12.7	11.6	13.5	11.7	7.3	4.8	7.3	6.7	3.9	8.6	13.8	13.5	(36)
(37)		MCWBR	12.6	11.4	13.4	11.3	7.1	4.4	6.0	6.2	4.0	8.6	13.6	13.1	(37)	
(38)		5% WB	MCDBR	12.9	11.5	13.8	11.6	6.6	4.6	6.9	5.9	4.0	8.7	13.9	13.5	(38)
(39)		MCWBR	12.9	11.5	13.7	11.3	6.6	4.4	6.0	5.7	4.2	8.8	13.8	13.3	(39)	
(40)		Clear-Sky Solar Irradiance	taub	N/A	0.164	0.255	0.302	0.326	0.314	0.338	0.342	0.286	N/A	N/A	N/A	(40)
(41)	taud		N/A	1.867	1.967	1.959	2.012	2.174	2.276	2.365	2.357	N/A	N/A	N/A	(41)	
(42)	Ebn at Noon		0	59	187	235	252	266	252	230	193	N/A	0	0	(42)	
(43)	Edh at Noon		0	4	21	35	39	35	30	24	15	N/A	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0	23	397	1170	1781	2077	1617	885	322	53	0	0	(44)	
(45)		RadStd	0	3	24	80	97	158	178	136	51	8	0	0	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page