

OSTROV KOTEL'NYJ, Russian Federation

WMO: 214320

Lat: 76.000N

Lon: 137.867E

Elev: 26

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.1	-34.7	-40.8	0.5	-36.7	-38.7	0.6	-34.6	37.3	-17.0	33.7	-11.7	6.7	140	1.173

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	53.3	48.8	49.4	45.9	46.0	43.4	49.3	52.8	46.1	49.0	43.4	45.8	17.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.7	47.2	51.2	43.5	41.7	47.8	41.1	38.0	44.9	19.9	52.9	18.2	49.2	16.9	46.0	63.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.8	29.7	26.7	-40.1	59.5	2.4	6.5	-41.8	64.1	-43.2	67.9	-44.5	71.5	-46.3	76.2
			-40.2	53.1	2.4	6.5	-41.9	57.7	-43.3	61.5	-44.7	65.1	-46.4	69.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-19.0	-19.6	-15.9	-1.1	17.4	32.6	37.9	37.8	31.7	17.4	-3.0	-14.5		
	DBStd	23.61	8.94	9.26	9.96	9.89	7.99	5.54	5.17	5.43	5.23	9.09	9.88	9.20		
	HDD50	15102	2138	1949	2043	1532	1011	525	378	380	548	1009	1590	1999		
	HDD65	20570	2603	2369	2508	1982	1476	973	840	843	998	1474	2040	2464		
	CDD50	6	0	0	0	0	0	2	2	2	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.3	12.3	12.0	11.4	11.5	12.6	12.8	12.8	12.8	12.8	13.2	11.6	11.8		
	PrecAvg	5.4	0.2	0.2	0.2	0.2	0.3	0.7	1.1	0.9	0.8	0.5	0.2	0.2		
(15) Precipitation	PrecMax	8.9	0.8	0.6	0.8	0.5	0.9	1.7	2.6	3.1	2.4	1.8	0.7	0.5		
	PrecMin	2.8	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.1	0.1	0.0	0.0	0.0		
	PrecStd	1.3	0.2	0.2	0.2	0.2	0.2	0.4	0.6	0.6	0.4	0.4	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	8.7	19.1	26.7	35.9	59.0	59.4	59.3	45.0	34.0	25.4	15.0		
		MCWB	7.6	8.2	17.8	26.1	33.7	53.1	54.6	53.8	42.4	32.9	24.6	14.0		
	2%	DB	3.0	2.4	10.4	20.7	33.2	48.0	53.3	53.0	41.4	32.1	19.7	6.5		
		MCWB	2.4	2.0	10.1	19.8	31.9	44.2	48.6	48.8	39.9	31.2	19.0	5.9		
	5%	DB	-1.2	-1.8	2.5	17.2	31.0	42.8	49.4	49.5	39.6	30.4	15.0	1.8		
		MCWB	-1.7	-2.3	1.9	16.4	29.7	40.4	45.8	46.2	38.4	29.3	14.3	1.3		
	10%	DB	-5.0	-5.4	-1.8	13.5	28.4	38.8	46.0	46.2	37.8	28.7	11.0	-1.7		
		MCWB	-5.4	-5.8	-2.3	12.7	27.2	37.1	43.2	44.0	36.6	27.5	10.3	-2.2		
	0.4%	WB	7.6	8.2	17.8	26.0	34.1	53.5	54.9	54.1	43.3	33.2	25.0	14.1		
		MCDB	7.8	8.7	19.0	26.6	35.4	59.4	58.9	58.4	44.4	33.7	25.4	15.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	2.4	1.9	9.8	19.9	32.1	44.4	49.2	49.3	40.3	31.4	19.1	6.0		
		MCDB	2.9	2.2	10.2	20.5	33.1	47.8	52.7	52.6	41.3	32.0	19.7	6.5		
	5%	WB	-1.8	-2.2	1.9	16.4	29.8	40.4	45.8	46.4	38.6	29.5	14.3	1.4		
		MCDB	-1.3	-1.9	2.3	17.1	30.9	42.6	49.0	49.2	39.5	30.3	14.9	1.9		
	10%	WB	-5.3	-5.8	-2.3	12.7	27.2	37.3	43.1	44.0	36.8	27.6	10.4	-2.2		
		MCDB	-4.9	-5.4	-1.8	13.5	28.2	38.7	45.8	46.2	37.7	28.6	11.1	-1.7		
	5% DB	MDBR	10.1	9.9	9.8	10.9	7.9	5.5	7.0	6.8	4.5	7.5	9.7	9.9		
		MCDBR	13.9	13.3	14.0	12.7	8.0	12.2	14.7	13.4	6.4	5.5	12.2	14.6		
		MCWBR	13.7	13.2	13.8	12.4	7.6	9.7	11.4	10.2	5.8	5.3	12.1	14.4		
		MCWBR	13.9	13.1	13.8	12.7	8.1	11.3	14.6	12.9	6.1	5.0	12.3	14.5		
(35) Mean Daily Temperature Range	5% WB	MCWBR	13.7	12.9	13.7	12.5	7.8	9.3	11.7	10.3	5.7	5.0	12.1	14.3		
	taub		N/A	0.168	0.261	0.299	0.325	0.318	0.344	0.335	0.279	0.193	N/A	N/A		
		taud	N/A	1.880	1.988	2.022	2.089	2.310	2.364	2.379	2.326	1.953	N/A	N/A		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		0	62	187	239	255	266	252	233	196	42	0	0		
		Edh at Noon	0	4	20	33	36	31	28	23	15	3	0	0		
	RadAvg		0	22	378	1169	1764	1825	1403	835	346	59	0	0		
(44) All-Sky Solar Radiation	RadStd		0	2	22	67	108	198	138	89	29	4	0	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page