

KIGILYAH, Russian FederationWMO: **216360**Lat: **73.336N**Lon: **139.869E**Elev: **24**StdP: **101.03**Time Zone: **10.00 (E10)**Period: **90-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.2	-37.7	-40.8	0.1	-39.0	-39.3	0.1	-37.6	14.9	-26.6	13.7	-24.4	2.3	110	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	11.8	9.4	9.7	8.0	8.1	6.8	9.5	11.4	8.2	9.6	7.0	7.9	4.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
8.2	6.8	10.2	7.2	6.3	8.9	6.1	5.8	7.9	28.2	11.6	25.5	9.7	22.7	8.0	14.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	12.1	10.6	DB	-40.2	13.8	1.5	1.9	-41.3	15.1	-42.1	16.2	-42.9	17.3	-44.0	18.6	(4)
(5)			WB	-40.2	11.8	1.5	1.8	-41.3	13.1	-42.1	14.1	-42.9	15.1	-44.0	16.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.3	-29.4	-30.0	-25.7	-16.2	-6.6	1.4	3.2	4.8	1.6	-6.3	-18.6	-26.7
	DBStd	13.71	4.59	5.17	5.96	4.83	4.42	2.79	2.40	2.31	2.59	4.82	5.56	4.88
	HDD10.0	8134	1222	1120	1107	786	514	258	212	161	252	506	857	1139
	HDD18.3	11173	1481	1353	1366	1036	773	507	469	419	502	764	1107	1397
	CDD10.0	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.2	4.1	4.6	4.8	5.4	6.1	5.5	5.4	5.5	5.3	6.0	4.7	4.5
Precipitation	PrecAvg	108	4	4	3	4	6	14	22	22	18	10	3	3
	PrecMax	186	13	15	11	11	21	31	63	42	42	20	7	9
	PrecMin	52	0	0	0	0	0	1	1	4	5	3	0	0
	PrecStd	42	3	4	3	4	5	8	17	12	11	5	2	3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-14.9	-13.7	-5.3	-3.6	2.7	13.8	14.4	13.5	9.5	2.0	-3.7	-13.9
		MCWB	-14.9	-14.0	-5.8	-4.1	1.6	10.0	11.6	11.1	8.0	1.4	-4.2	-14.1
	2%	DB	-17.6	-16.7	-8.4	-5.5	1.6	10.6	12.0	10.7	7.6	1.0	-5.4	-15.9
		MCWB	-17.8	-16.9	-8.8	-6.0	0.7	8.0	9.6	9.1	6.3	0.3	-5.9	-16.1
	5%	DB	-19.8	-19.9	-12.4	-7.5	0.7	7.2	9.7	9.3	6.0	0.2	-8.0	-18.0
		MCWB	-20.0	-20.0	-12.5	-7.9	0.0	5.2	7.9	8.0	5.0	-0.5	-8.3	-18.3
	10%	DB	-22.1	-22.3	-17.6	-9.0	0.0	5.2	7.2	8.2	5.0	-0.8	-10.6	-19.8
		MCWB	-22.2	-22.5	-17.9	-9.4	-0.6	3.7	5.7	7.2	4.1	-1.5	-10.8	-20.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-15.0	-13.9	-5.8	-4.1	1.7	10.2	11.9	11.6	8.1	1.5	-4.2	-14.1
		MCDB	-15.0	-13.7	-5.5	-3.8	2.5	13.3	13.7	13.3	9.3	1.6	-3.9	-14.0
	2%	WB	-17.7	-16.7	-8.8	-6.0	0.7	7.9	9.8	9.1	6.2	0.4	-5.9	-16.0
		MCDB	-17.5	-16.6	-8.4	-5.5	1.3	10.4	11.9	10.4	7.2	0.8	-5.3	-15.9
	5%	WB	-20.0	-20.0	-12.6	-7.9	0.1	5.4	8.1	8.2	5.2	-0.4	-8.3	-18.3
		MCDB	-19.8	-19.9	-12.4	-7.5	0.6	7.0	9.9	9.2	5.9	0.1	-8.0	-18.1
	10%	WB	-22.2	-22.4	-17.8	-9.3	-0.6	3.6	5.8	7.3	4.2	-1.4	-10.8	-20.0
		MCDB	-22.1	-22.3	-17.6	-9.0	-0.1	5.1	7.0	8.0	4.8	-0.8	-10.6	-19.8
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.0	5.6	6.6	4.4	3.5	4.0	3.3	2.3	3.1	5.0	4.8
		MCDBR	7.5	7.8	9.2	8.6	4.2	6.8	8.3	4.8	3.3	2.1	6.7	6.9
		MCWBR	7.4	7.7	9.2	8.4	3.9	4.9	6.5	3.6	2.7	2.3	6.6	7.0
	5% WB	MCDBR	7.1	7.8	9.2	8.8	4.3	6.8	8.3	4.4	3.1	2.0	6.7	6.8
		MCWBR	7.1	7.7	9.2	8.6	4.0	5.2	6.8	3.6	2.8	2.3	6.6	6.9
Clear-Sky Solar Irradiance	taub	N/A	0.173	0.270	0.303	0.335	0.327	0.363	0.353	0.298	0.357	N/A	N/A	
	taud	N/A	1.888	1.982	1.993	1.983	2.188	2.269	2.407	2.429	2.727	N/A	N/A	
	Ebn at Noon	0	388	642	779	807	840	787	744	665	322	0	0	
	Edh at Noon	0	26	76	113	134	114	102	78	52	22	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.15	1.52	4.06	6.09	6.44	5.17	2.82	1.25	0.28	0.00	0.00	
	RadStd	0.00	0.02	0.06	0.15	0.24	0.39	0.36	0.35	0.12	0.04	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page