

SASKYLAKH, Russian Federation

WMO: 218020

Lat: 71.967N

Lon: 114.083E

Elev: 17

StdP: 101.12

Time Zone: 9.00 (E09)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-50.3	-47.7	-52.6	0.0	-50.0	-50.1	0.0	-47.5	14.7	-16.6	13.1	-21.2	0.7	160	0.962

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	24.5	16.6	21.4	14.8	18.7	13.2	17.2	23.1	15.3	20.7	13.7	18.1	4.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.5	10.3	20.1	12.7	9.2	18.1	11.0	8.2	16.2	48.6	23.3	43.1	20.5	38.7	18.1	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.2	8.0	-51.6	28.0	2.6	3.4	-53.5	30.4	-55.0	32.4	-56.5	34.2	-58.5	36.7		
(5)			-52.1	18.8	3.3	1.9	-54.5	20.2	-56.5	21.3	-58.4	22.4	-60.8	23.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.7	-32.8	-34.9	-26.6	-16.3	-5.3	7.7	11.5	9.2	2.3	-11.2	-25.1	-32.0	(6)
(7)		DBStd	18.23	9.38	8.26	9.41	7.55	5.88	5.95	4.53	3.89	3.75	7.40	7.69	8.12	(7)
(8)		HDD10.0	8437	1327	1258	1135	788	476	115	33	62	232	657	1052	1302	(8)
(9)		HDD18.3	11323	1586	1491	1393	1038	733	324	217	282	481	915	1302	1561	(9)
(10)		CDD10.0	166	0	0	0	0	1	44	81	39	1	0	0	0	(10)
(11)		CDD18.3	11	0	0	0	0	0	4	7	1	0	0	0	0	(11)
(12)		CDH23.3	116	0	0	0	0	0	42	66	8	0	0	0	0	(12)
(13)		CDH26.7	18	0	0	0	0	0	7	11	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.5	3.4	3.0	3.1	3.7	4.0	4.3	3.9	3.7	3.8	3.3	3.1	3.1	(14)
(15)	Precipitation	PrecAvg	218	9	9	10	11	14	28	34	32	22	17	12	10	(15)
(16)		PrecMax	322	24	48	31	27	49	78	96	99	54	33	32	29	(16)
(17)		PrecMin	103	1	1	1	2	0	3	6	4	3	0	4	1	(17)
(18)		PrecStd	55	6	8	6	7	9	19	24	21	13	7	7	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.0	-10.7	-0.8	5.5	12.6	27.8	28.3	24.4	15.7	3.5	-2.6	-8.9	(19)
(20)			MCWB	-8.4	-11.2	-2.0	2.5	7.7	16.3	19.3	16.2	11.4	2.4	-3.2	-9.5	(20)
(21)		2%	DB	-13.7	-15.8	-4.1	1.4	7.7	23.9	25.6	21.4	11.8	1.1	-7.5	-12.0	(21)
(22)			MCWB	-14.1	-16.2	-5.1	-0.5	4.5	15.6	17.9	14.5	8.5	0.2	-8.1	-12.5	(22)
(23)		5%	DB	-16.2	-19.6	-7.4	-1.7	5.2	20.1	22.1	18.6	9.2	-0.5	-11.3	-16.1	(23)
(24)			MCWB	-16.7	-20.0	-8.1	-2.9	2.7	13.4	15.8	13.2	6.8	-1.3	-12.0	-16.6	(24)
(25)		10%	DB	-18.5	-22.7	-11.7	-5.1	3.0	16.9	19.4	15.9	7.2	-2.0	-14.2	-19.5	(25)
(26)			MCWB	-18.8	-22.9	-12.4	-6.1	1.1	11.5	14.0	12.2	5.5	-2.7	-14.6	-19.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.3	-11.2	-1.8	2.5	8.1	17.7	20.9	17.5	11.3	2.7	-3.2	-9.3	(27)
(28)			MCDWB	-7.9	-10.7	-0.5	5.5	12.7	24.8	26.6	22.4	14.7	3.4	-2.5	-9.0	(28)
(29)		2%	WB	-14.1	-16.2	-5.2	-0.4	4.5	15.9	18.2	15.3	9.0	0.2	-8.0	-12.5	(29)
(30)			MCDWB	-13.8	-15.8	-4.3	1.0	7.4	22.7	24.1	20.0	11.3	0.9	-7.5	-12.1	(30)
(31)		5%	WB	-16.6	-19.8	-8.2	-3.0	2.7	14.0	16.3	13.8	7.1	-1.2	-11.9	-16.5	(31)
(32)			MCDWB	-16.2	-19.5	-7.4	-1.7	5.0	19.9	21.4	17.6	9.0	-0.6	-11.3	-16.1	(32)
(33)		10%	WB	-18.8	-22.9	-12.3	-6.1	1.3	11.7	14.4	12.2	5.7	-2.7	-14.6	-19.7	(33)
(34)			MCDWB	-18.5	-22.6	-11.7	-5.1	2.9	16.7	18.9	15.6	7.1	-2.1	-14.1	-19.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.9	6.7	8.5	9.7	6.3	7.6	7.9	7.6	5.3	5.8	7.0	6.9	(35)
(36)			MCDBR	9.4	10.4	9.3	11.4	8.5	12.5	12.5	12.7	9.4	5.6	8.6	10.0	(36)
(37)			MCWBR	9.2	10.2	8.7	9.9	6.0	6.7	6.5	6.7	6.4	5.2	8.5	9.8	(37)
(38)		5% WB	MCDBR	9.3	10.7	9.3	11.6	7.7	12.3	11.7	10.9	8.5	5.5	8.5	9.9	(38)
(39)			MCWBR	9.2	10.4	8.7	10.3	5.6	7.1	6.8	6.7	6.1	5.2	8.5	9.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.198	0.281	0.312	0.343	0.345	0.384	0.382	0.301	0.206	N/A	N/A	(40)	
(41)		taud	N/A	1.945	2.033	2.067	2.106	2.404	2.324	2.273	2.400	1.997	N/A	N/A	(41)	
(42)		Ebn at Noon	0	431	664	788	814	837	776	715	682	393	0	0	(42)	
(43)		Edh at Noon	0	32	77	109	121	94	99	91	56	28	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.21	1.66	4.13	5.74	5.33	4.83	3.12	1.39	0.37	0.00	0.00	(44)	
(45)		RadStd	0.00	0.02	0.08	0.18	0.37	0.41	0.36	0.41	0.17	0.05	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page