

TIKSI, Russian Federation

WMO: 218240

Lat: 71.583N

Lon: 128.917E

Elev: 23

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-45.8	-42.0	-49.2	0.3	-45.5	-45.6	0.4	-41.8	45.4	-8.8	41.8	-12.3	2.4	210	1.061

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	69.5	57.9	63.8	56.1	58.8	53.0	59.6	67.0	56.5	63.0	53.3	58.4	13.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.1	67.1	62.8	53.1	59.9	59.4	49.9	53.3	56.4	26.3	66.8	24.2	62.8	22.2	58.5	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.4	33.9	28.2	-47.9	79.2	4.4	4.8	-51.1	82.6	-53.7	85.4	-56.2	88.1	-59.4	91.6		
(5)			-47.8	64.2	4.2	2.7	-50.9	66.2	-53.3	67.8	-55.7	69.3	-58.8	71.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	-21.6	-23.0	-14.2	1.4	21.5	39.4	47.2	47.5	35.6	14.8	-7.2	-18.6		
	DBStd	28.40	10.68	12.61	15.19	13.59	9.91	8.15	7.68	6.63	6.56	11.49	10.67	11.37		
	HDD50	14578	2220	2045	1989	1459	885	335	150	130	432	1091	1717	2125		
	HDD65	19924	2685	2465	2454	1909	1350	768	554	544	882	1556	2167	2590		
	CDD50	133	0	0	0	0	0	17	63	52	1	0	0	0		
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0		
	CDH74	51	0	0	0	0	0	10	37	4	0	0	0	0		
	CDH80	8	0	0	0	0	0	2	6	0	0	0	0	0		
	WSAvg	10.5	13.0	10.3	8.5	7.9	9.4	9.6	9.6	10.2	10.8	11.3	11.9	13.4		
	PrecAvg	8.9	0.7	0.6	0.5	0.4	0.4	1.1	1.7	1.7	1.1	0.5	0.4	0.9		
	PrecMax	16.9	3.1	2.6	3.7	1.6	1.2	2.6	3.7	4.5	2.9	1.0	3.2	2.5		
(15) Precipitation	PrecMin	5.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.3	0.2	0.1	0.0	0.1		
	PrecStd	3.6	0.9	0.7	0.8	0.5	0.3	0.6	0.8	0.9	0.6	0.3	0.7	0.7		
	DB	5.4	11.4	27.7	39.6	50.2	74.1	78.7	73.3	56.2	35.9	22.7	10.0			
	MCWB	4.2	10.3	26.4	35.2	42.3	58.0	62.3	60.3	49.8	33.4	21.5	9.2			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	0.1	3.7	21.8	33.3	42.9	64.2	71.2	67.3	51.4	32.9	15.8	4.9			
	2% MCWB	-0.4	3.0	20.8	30.4	37.9	54.4	60.4	57.4	47.1	31.0	14.8	4.2			
	5% DB	-3.4	-0.6	15.9	27.0	38.4	56.9	64.5	62.4	47.8	30.6	11.6	1.0			
	5% MCWB	-3.8	-1.1	14.6	24.9	35.1	49.7	57.1	55.6	44.0	29.1	10.9	0.4			
	10% DB	-6.5	-5.0	9.9	21.3	35.1	51.2	59.1	58.1	44.8	28.8	7.5	-2.4			
	10% MCWB	-6.9	-5.4	8.8	19.6	32.9	46.1	53.4	53.2	42.3	27.3	6.8	-2.8			
	0.4% WB	4.5	10.5	26.4	35.4	43.5	59.3	64.6	61.7	51.2	34.0	21.2	9.4			
	0.4% MCDB	5.2	11.4	27.6	39.1	49.2	69.3	74.9	68.9	54.5	35.2	22.5	10.1			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	-0.4	2.9	20.7	30.5	38.4	54.6	61.3	58.9	47.6	31.1	14.9	4.1			
	2% MCDB	0.1	3.5	21.8	33.1	42.4	64.6	69.3	65.0	50.9	32.5	15.7	4.7			
	5% WB	-3.7	-1.2	14.6	25.0	35.2	50.0	57.3	56.2	44.5	29.3	10.8	0.4			
	5% MCDB	-3.4	-0.7	15.8	27.0	37.8	56.2	64.3	61.8	47.0	30.7	11.4	0.9			
	10% WB	-7.0	-5.4	8.7	19.6	32.8	46.3	53.7	53.3	42.1	27.4	6.8	-3.0			
	10% MCDB	-6.7	-5.1	9.6	21.4	34.7	50.7	59.1	57.7	44.4	28.7	7.5	-2.7			
	MDBR	10.9	11.0	13.6	16.4	11.0	11.3	12.2	10.1	8.3	9.4	11.2	10.7			
	5% DB	12.6	13.1	14.7	20.6	15.4	24.3	22.8	19.5	13.3	7.8	12.2	12.7			
(36) Mean Daily Temperature Range	5% DB	12.3	12.7	14.1	18.6	12.0	15.3	13.9	11.8	9.7	7.3	12.1	12.5			
	5% WB	12.5	13.1	14.7	19.8	14.8	23.0	21.5	17.8	11.9	7.6	12.2	12.8			
	MCWBR	12.3	12.6	14.2	18.0	11.8	15.3	14.4	11.7	9.3	7.3	12.2	12.5			
	MCWBR	12.3	12.6	14.2	18.0	11.8	15.3	14.4	11.7	9.3	7.3	12.2	12.5			
(40) Clear-Sky Solar Irradiance	taub	N/A	0.199	0.281	0.310	0.341	0.344	0.403	0.381	0.299	0.212	N/A	N/A			
	taud	N/A	1.962	2.025	2.057	2.099	2.335	2.247	2.301	2.439	2.031	N/A	N/A			
	Ebn at Noon	0	144	213	252	259	266	240	229	221	131	0	0			
	Edh at Noon	0	11	25	35	39	32	34	29	17	9	0	0			
(44) All-Sky Solar Radiation	RadAvg	0	76	555	1337	1905	1967	1499	920	438	130	0	0			
	RadStd	0	9	23	47	79	117	123	105	48	20	0	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+1.89	N/A	N/A	N/A	N/A	N/A	-743	-709	N/A	N/A
Regional (4 neighbors)		+1.89	N/A	N/A	N/A	N/A	N/A	-743	-709	N/A	N/A

Nomenclature: See separate page