

TIKSI, Russian Federation

WMO: 218240

Lat: 71.583N

Lon: 128.917E

Elev: 7

StdP: 101.24

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-43.2	-41.1	-45.1	0.0	-43.1	-43.1	0.1	-41.0	20.3	-22.6	18.7	-24.6	1.1	210	1.061

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	20.8	14.4	17.6	13.4	14.9	11.7	15.4	19.4	13.6	17.2	11.8	14.7	5.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.4	9.6	17.1	11.7	8.6	15.2	9.9	7.6	13.6	43.3	19.3	38.4	17.1	33.9	14.7	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.2	12.6	DB	-44.4	26.2	2.5	2.6	-46.2	28.1	-47.6	29.7	-49.0	31.2	-50.8	33.1	(4)
(5)			WB	-44.3	17.9	2.3	1.5	-46.0	19.0	-47.4	19.9	-48.7	20.7	-50.4	21.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.0	-29.8	-30.6	-25.6	-17.0	-5.9	4.1	8.4	8.6	2.0	-9.5	-21.8	-28.1
	DBStd	15.78	5.94	7.01	8.44	7.55	5.51	4.53	4.27	3.68	3.64	6.39	5.93	6.32
	HDD10.0	8099	1233	1136	1105	811	492	186	83	72	240	606	954	1181
	HDD18.3	11069	1492	1369	1363	1061	750	427	308	302	490	864	1204	1439
	CDD10.0	74	0	0	0	0	0	9	35	29	1	0	0	0
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	28	0	0	0	0	0	6	21	2	0	0	0	0
	CDH26.7	4	0	0	0	0	0	1	3	0	0	0	0	0
Wind	WSAvg	4.7	5.8	4.6	3.8	3.5	4.2	4.3	4.3	4.6	4.8	5.0	5.3	6.0
Precipitation	PrecAvg	226	18	15	13	9	10	29	44	44	27	12	11	22
	PrecMax	430	79	67	94	41	30	65	93	115	74	25	82	64
	PrecMin	128	1	1	0	1	1	10	10	8	4	2	1	3
	PrecStd	91	23	17	20	12	8	14	20	23	16	7	18	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-14.8	-11.5	-2.4	4.2	10.1	23.4	25.9	23.0	13.4	2.2	-5.1	-12.2
		MCWB	-15.5	-12.0	-3.1	1.8	5.7	14.5	16.8	15.7	9.9	0.8	-5.8	-12.7
	2%	DB	-17.7	-15.7	-5.6	0.7	6.1	17.9	21.8	19.6	10.8	0.5	-9.0	-15.0
		MCWB	-18.0	-16.1	-6.2	-0.9	3.3	12.4	15.8	14.1	8.4	-0.6	-9.6	-15.4
	5%	DB	-19.6	-18.1	-9.0	-2.8	3.5	13.9	18.1	16.9	8.8	-0.8	-11.3	-17.2
		MCWB	-19.9	-18.4	-9.7	-3.9	1.7	9.8	13.9	13.1	6.7	-1.6	-11.7	-17.6
	10%	DB	-21.4	-20.6	-12.3	-5.9	1.7	10.7	15.1	14.5	7.1	-1.8	-13.6	-19.1
		MCWB	-21.6	-20.8	-12.9	-6.9	0.5	7.8	11.9	11.8	5.7	-2.6	-14.0	-19.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-15.3	-11.9	-3.1	1.9	6.4	15.2	18.1	16.5	10.7	1.1	-6.0	-12.6
		MCDB	-14.9	-11.5	-2.4	4.0	9.6	20.7	23.8	20.5	12.5	1.8	-5.3	-12.2
	2%	WB	-18.0	-16.1	-6.3	-0.9	3.5	12.6	16.3	14.9	8.7	-0.5	-9.5	-15.5
		MCDB	-17.7	-15.8	-5.7	0.6	5.8	18.1	20.7	18.3	10.5	0.3	-9.0	-15.2
	5%	WB	-19.8	-18.5	-9.7	-3.9	1.8	10.0	14.1	13.4	7.0	-1.5	-11.8	-17.5
		MCDB	-19.7	-18.2	-9.0	-2.8	3.2	13.4	18.0	16.5	8.3	-0.7	-11.4	-17.3
	10%	WB	-21.6	-20.8	-13.0	-6.9	0.5	7.9	12.1	11.8	5.6	-2.6	-14.0	-19.4
		MCDB	-21.5	-20.6	-12.4	-5.9	1.5	10.4	15.0	14.3	6.9	-1.8	-13.6	-19.3
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.1	7.6	9.1	6.1	6.3	6.8	5.6	4.6	5.2	6.2	6.0
		MCDBR	7.0	7.3	8.2	11.4	8.6	13.5	12.7	10.8	7.4	4.3	6.8	7.0
		MCWBR	6.9	7.0	7.8	10.3	6.7	8.5	7.7	6.6	5.4	4.1	6.7	6.9
	5% WB	MCDBR	7.0	7.3	8.2	11.0	8.2	12.8	11.9	9.9	6.6	4.2	6.8	7.1
		MCWBR	6.8	7.0	7.9	10.0	6.6	8.5	8.0	6.5	5.2	4.1	6.8	7.0
Clear-Sky Solar Irradiance	taub	N/A	0.199	0.281	0.310	0.341	0.344	0.403	0.381	0.299	0.212	N/A	N/A	
	taud	N/A	1.962	2.025	2.057	2.099	2.335	2.247	2.301	2.439	2.031	N/A	N/A	
	Ebn at Noon	0	454	670	793	817	838	756	722	697	414	0	0	
	Edh at Noon	0	34	79	111	123	101	108	90	55	29	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.24	1.75	4.21	6.00	6.20	4.72	2.90	1.38	0.41	0.00	0.00	
	RadStd	0.00	0.03	0.07	0.15	0.25	0.37	0.39	0.33	0.15	0.06	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.05	N/A	N/A	N/A	N/A	N/A	-413	-394	N/A	N/A
(47) Regional (4 neighbors)		+1.05	N/A	N/A	N/A	N/A	N/A	-413	-394	N/A	N/A

Nomenclature: See separate page