

DZALINDA, Russian Federation

WMO: 219080

Lat: 70.133N

Lon: 113.967E

Elev: 203

StdP: 14.59

Time Zone: 9.00 (E09)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-62.5	-58.6	-64.2	0.1	-62.0	-60.6	0.1	-58.4	16.5	6.7	15.6	-3.1	1.6	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	80.4	63.1	75.8	60.9	71.3	58.7	65.1	76.5	62.4	73.1	59.8	69.4	5.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.5	79.4	70.4	57.7	71.7	66.8	55.1	65.1	64.3	30.2	76.5	28.3	74.2	26.4	69.3	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	14.3	11.8	DB	-64.9	87.2	3.9	3.8	-67.7	89.9	-70.0	92.1	-72.2	94.3	-75.0	97.1	(4)
(5)			WB	-64.9	71.5	3.9	5.7	-67.7	75.7	-70.0	79.0	-72.2	82.2	-75.0	86.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-30.2	-32.0	-9.9	12.6	30.3	53.0	57.3	50.8	36.2	14.0	-16.5	-30.8		
	DBStd	35.45	17.71	16.64	17.47	12.73	11.99	10.71	7.67	7.02	7.69	12.35	16.01	15.44		
	HDD50	14599	2487	2295	1857	1121	620	91	19	75	418	1117	1994	2505		
	HDD65	19583	2952	2715	2322	1571	1076	382	261	444	864	1582	2444	2970		
	CDD50	540	0	0	0	0	9	182	246	99	4	0	0	0		
	CDD65	48	0	0	0	0	0	23	23	2	0	0	0	0		
	CDH74	550	0	0	0	0	2	244	253	51	0	0	0	0		
	CDH80	128	0	0	0	0	0	65	56	7	0	0	0	0		
	WSAvg	4.2	4.1	3.3	3.9	5.2	5.2	5.6	4.4	4.1	4.0	3.7	3.8	3.5		
	PrecAvg	10.4	0.3	0.3	0.4	0.5	0.9	1.5	1.9	2.0	1.1	0.9	0.6	0.4		
(15) Precipitation	PrecMax	15.6	0.8	0.6	0.8	1.2	2.1	2.5	6.0	4.0	2.8	1.7	1.3	0.8		
	PrecMin	7.4	0.0	0.0	0.1	0.0	0.1	0.4	0.7	0.4	0.3	0.3	0.2	0.0		
	PrecStd	2.0	0.2	0.2	0.2	0.3	0.5	0.6	1.1	1.0	0.6	0.4	0.3	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	18.1	34.4	50.8	70.6	86.1	85.9	79.5	66.9	40.5	28.5	16.2		
		MCWB	17.7	17.2	30.2	41.8	54.8	66.9	63.6	64.4	55.5	37.8	26.9	15.3		
	2%	DB	9.0	6.1	29.8	43.4	61.2	81.0	80.9	74.0	56.4	36.2	19.5	6.2		
		MCWB	8.3	5.5	26.6	37.2	49.4	62.2	63.8	60.4	47.6	34.4	18.5	5.5		
	5%	DB	3.8	-0.6	24.7	38.1	54.2	75.7	76.6	69.5	51.5	33.0	12.3	-1.2		
		MCWB	3.1	-1.1	22.6	33.3	44.7	60.3	61.8	58.9	45.3	31.7	11.3	-1.7		
	10%	DB	-2.8	-8.0	18.5	33.5	48.7	70.8	71.8	64.9	47.6	29.8	5.9	-8.3		
		MCWB	-3.4	-8.6	16.8	29.7	41.2	57.3	59.4	56.2	43.4	28.4	5.3	-8.7		
	0.4%	WB	17.5	17.7	30.7	42.0	55.8	68.3	69.0	67.4	56.8	38.5	27.6	15.3		
		MCDB	18.9	18.8	33.8	49.8	70.0	79.3	80.4	77.6	65.7	40.0	29.1	16.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	8.2	5.6	26.4	36.9	49.5	64.3	65.5	62.7	49.3	34.7	18.5	5.9		
		MCDB	8.8	6.1	29.6	42.2	59.7	78.3	76.8	70.5	54.4	35.6	19.4	6.6		
	5%	WB	3.1	-1.2	22.3	33.8	45.4	61.4	62.9	59.5	46.1	31.7	11.4	-1.6		
		MCDB	3.9	-0.7	24.8	37.8	53.8	73.7	74.0	67.2	50.3	33.1	12.3	-1.1		
	10%	WB	-3.3	-8.4	16.8	29.6	41.4	58.2	60.5	56.9	43.8	28.6	5.4	-8.6		
		MCDB	-2.7	-8.0	18.6	33.3	48.2	69.6	69.9	63.8	47.7	29.9	6.0	-8.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.7	16.4	25.0	24.5	17.0	17.1	16.8	18.2	13.8	12.0	14.0	14.0		
		MCDBR	22.6	19.6	20.1	26.6	22.2	23.9	24.3	28.2	23.9	11.2	16.6	19.5		
		MCWBR	22.0	19.3	17.8	21.9	14.7	12.3	12.1	17.8	16.3	9.7	16.2	19.1		
		MCDBR	23.1	19.8	19.6	25.3	21.4	23.0	22.2	24.2	20.0	10.7	16.8	19.6		
	5% WB	MCWBR	22.6	19.4	17.5	21.2	14.6	13.2	12.4	17.0	14.3	9.5	16.4	19.2		
(40) Clear-Sky Solar Irradiance	taub		N/A	0.215	0.284	0.313	0.341	0.352	0.411	0.394	0.306	0.224	N/A	N/A		
	taud		N/A	1.992	2.042	2.077	2.165	2.427	2.265	2.264	2.442	2.074	N/A	N/A		
	Ebn at Noon		0	159	221	255	263	266	241	228	226	151	0	0		
	Edh at Noon		0	13	26	36	37	30	34	30	19	11	0	0		
(44) All-Sky Solar Radiation	RadAvg		0	128	617	1331	1801	1759	1553	1040	515	162	0	0		
	RadStd		0	10	33	66	115	153	104	122	53	17	0	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page