

MYS MIKULKIN, Russian Federation

WMO: 222820

Lat: 67.800N

Lon: 46.667E

Elev: 20

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.3	-6.5	-15.6	2.4	-10.6	-10.4	3.2	-6.0	40.8	22.9	36.2	19.0	9.4	20	0.963

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	58.9	54.8	56.4	53.2	54.4	51.8	55.4	58.0	53.8	56.0	52.2	54.2	9.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.0	62.0	56.8	52.4	58.4	55.1	50.9	55.3	53.6	23.5	58.1	22.5	56.0	21.6	54.4	62.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.3	31.4	27.9	DB	-14.8	63.8	4.8	2.8	-18.2	65.8	-21.0	67.5	-23.7	69.1	-27.1	71.1	
			WB	-15.5	56.9	4.7	3.5	-18.9	59.4	-21.6	61.5	-24.2	63.4	-27.6	66.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	30.5	15.0	12.6	18.0	25.0	32.0	41.2	47.9	47.5	43.3	35.7	26.3	20.7		
	DBStd	14.10	9.17	11.79	9.21	7.00	6.19	5.25	4.97	4.11	4.33	5.41	7.03	8.76		
	HDD50	7170	1084	1047	993	750	558	270	101	99	203	444	711	910		
	HDD65	12578	1549	1467	1458	1200	1023	715	529	542	650	909	1161	1375		
	CDD50	67	0	0	0	0	0	5	37	22	3	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	13.9	15.6	14.6	14.6	13.5	12.9	11.9	11.0	11.2	12.5	15.8	16.9	16.6		
	PrecAvg	14.0	1.0	0.7	0.7	0.6	0.9	1.3	1.2	1.7	1.8	1.9	1.1	1.1		
	PrecMax	17.9	4.7	1.5	1.4	1.9	2.9	2.8	2.9	4.7	4.2	3.2	2.5	2.0		
(15) Precipitation	PrecMin	10.4	0.3	0.2	0.2	0.2	0.1	0.6	0.2	0.2	0.7	0.7	0.3	0.4		
	PrecStd	2.0	0.8	0.4	0.3	0.3	0.6	0.6	0.6	0.9	0.8	0.6	0.4	0.4		
	DB	33.6	33.8	33.0	37.2	51.0	59.5	63.3	60.8	54.9	47.4	38.2	35.6	31.2		
	MCWB	32.7	33.1	31.5	34.7	47.1	53.5	56.9	57.1	51.8	45.4	37.0	33.8	30.1		
	2% DB	30.8	31.6	31.7	34.7	46.0	54.3	59.9	57.6	52.9	45.5	36.5	33.1	32.1		
(23) Mean Coincident Wet Bulb Temperatures	MCWB	29.7	30.6	30.5	32.9	42.9	49.8	55.3	54.7	50.6	44.1	35.4	32.1	31.2		
	DB	29.2	29.9	30.5	33.5	43.3	51.1	57.5	55.6	51.3	44.2	35.6	32.0	31.2		
	MCWB	28.4	28.9	29.5	32.1	40.7	47.4	53.8	53.3	49.3	42.9	34.5	31.2	30.8		
	10% DB	27.4	27.7	29.4	32.6	40.4	48.5	55.3	53.8	49.9	43.0	34.5	30.8	30.1		
	MCWB	26.6	26.7	28.4	31.4	38.4	45.5	52.4	51.9	48.3	41.7	33.6	30.1	30.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	32.5	33.2	32.1	35.0	47.5	54.2	58.3	58.0	52.5	46.1	37.6	34.1	32.1		
	MCDB	33.3	33.6	32.4	36.6	50.6	58.5	61.8	60.1	54.0	47.0	38.0	35.2	32.8		
	2% WB	30.1	30.7	30.9	33.2	43.2	50.7	56.0	54.9	51.1	44.3	35.7	32.3	31.3		
	MCDB	30.7	31.4	31.4	34.0	45.4	53.7	58.9	56.8	52.6	45.1	36.2	32.8	31.3		
	5% WB	28.3	29.0	29.7	32.5	40.7	47.8	54.3	53.7	49.8	43.2	34.7	31.3	31.8		
(33) Mean Daily Temperature Range	MCDB	28.9	29.9	30.5	33.3	43.2	50.4	56.9	55.4	50.9	44.1	35.3	31.8	31.8		
	10% WB	26.6	26.8	28.6	31.7	38.5	45.7	52.7	52.2	48.4	41.9	33.7	30.1	30.8		
	MCDB	27.3	27.8	29.6	32.6	40.3	48.0	55.1	53.7	49.9	42.9	34.5	30.8	30.8		
	5% DB	8.9	9.3	9.3	7.9	6.8	7.7	7.5	7.5	6.8	6.0	6.3	7.4	5.5		
	MCDBR	8.5	8.4	6.6	5.7	10.4	12.3	11.2	10.1	7.8	6.2	5.3	5.3	5.3		
(36) Clear-Sky Solar Irradiance	MCWBR	8.8	8.4	6.4	5.4	8.3	8.6	8.0	7.9	6.4	5.8	5.2	5.3	5.3		
	5% WB	8.5	8.2	6.6	5.5	10.1	11.3	10.0	9.4	7.1	6.3	5.2	5.4	5.4		
	MCWBR	8.6	8.2	6.6	5.4	8.2	8.6	8.0	7.6	6.2	6.0	5.3	5.5	5.5		
	taub	0.216	0.259	0.300	0.329	0.338	0.339	0.372	0.350	0.324	0.291	0.361	N/A	N/A		
	taud	1.915	2.030	2.092	2.168	2.345	2.491	2.436	2.487	2.509	2.252	2.554	N/A	N/A		
(42) All-Sky Solar Radiation	Ebn at Noon	29	166	228	257	271	275	259	253	232	158	35	0	0		
	Edh at Noon	3	16	28	34	32	29	30	25	19	13	4	0	0		
	RadAvg	11	145	599	1121	1476	1649	1527	1012	530	150	23	0	0		
(45)	RadStd	1	24	75	127	119	186	177	103	59	23	2	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page