

MYS MIKULKIN, Russian Federation

WMO: 222820

Lat: **67.800N**Lon: **46.667E**Elev: **6**StdP: **101.25**Time Zone: **3.00 (E03)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-24.0	-21.4	-26.4	0.3	-23.7	-23.5	0.5	-21.1	18.3	-5.1	16.2	-7.2	4.2	20	0.963

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.2	14.9	12.7	13.6	11.8	12.4	11.0	13.0	14.4	12.1	13.3	11.2	12.3	4.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	8.9	13.8	11.3	8.3	12.8	10.5	7.9	12.0	36.7	14.5	34.4	13.3	32.3	12.4	16.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	14.0	12.5	-26.0	17.7	2.7	1.6	-27.9	18.8	-29.4	19.7	-30.9	20.6	-32.8	21.7		
(5)			-26.4	13.8	2.6	2.0	-28.3	15.2	-29.8	16.4	-31.2	17.5	-33.1	18.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.8	-9.4	-10.8	-7.8	-3.9	0.0	5.1	8.9	8.6	6.3	2.0	-3.2	-6.3
	DBStd	7.83	5.10	6.55	5.12	3.89	3.44	2.92	2.76	2.28	2.41	3.00	3.90	4.87
	HDD10.0	3983	602	582	552	417	310	150	56	55	113	247	395	506
	HDD18.3	6988	861	815	810	667	568	397	294	301	361	505	645	764
	CDD10.0	37	0	0	0	0	0	3	21	12	2	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.2	7.0	6.5	6.5	6.0	5.7	5.3	4.9	5.0	5.6	7.1	7.5	7.4
Precipitation	PrecAvg	356	26	19	18	16	23	33	30	43	45	48	29	29
	PrecMax	455	120	38	35	49	74	72	74	120	106	81	63	51
	PrecMin	263	8	5	4	5	3	14	4	6	17	17	7	9
	PrecStd	51	20	9	8	8	14	14	16	24	21	16	11	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.9	1.0	0.5	2.9	10.6	15.3	17.4	16.0	12.7	8.6	3.4	2.0
		MCWB	0.4	0.6	-0.3	1.5	8.4	12.0	13.8	13.9	11.0	7.5	2.8	1.0
	2%	DB	-0.7	-0.2	-0.2	1.5	7.8	12.4	15.5	14.2	11.6	7.5	2.5	0.6
		MCWB	-1.3	-0.8	-0.8	0.5	6.0	9.9	12.9	12.6	10.4	6.7	1.9	0.0
	5%	DB	-1.5	-1.1	-0.8	0.8	6.3	10.6	14.2	13.1	10.7	6.8	2.0	0.0
		MCWB	-2.0	-1.7	-1.4	0.1	4.8	8.6	12.1	11.8	9.6	6.1	1.4	-0.4
	10%	DB	-2.5	-2.4	-1.4	0.3	4.7	9.1	12.9	12.1	9.9	6.1	1.4	-0.6
		MCWB	-3.0	-2.9	-2.0	-0.3	3.5	7.5	11.3	11.1	9.1	5.4	0.9	-1.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.3	0.7	0.0	1.7	8.6	12.3	14.6	14.4	11.4	7.8	3.1	1.2
		MCDB	0.7	0.9	0.2	2.5	10.3	14.7	16.5	15.6	12.2	8.3	3.3	1.8
	2%	WB	-1.1	-0.7	-0.6	0.7	6.2	10.4	13.3	12.7	10.6	6.8	2.1	0.2
		MCDB	-0.7	-0.3	-0.3	1.1	7.4	12.0	15.0	13.8	11.4	7.3	2.3	0.4
	5%	WB	-2.1	-1.7	-1.3	0.3	4.9	8.8	12.4	12.1	9.9	6.2	1.5	-0.4
		MCDB	-1.7	-1.2	-0.9	0.7	6.2	10.2	13.8	13.0	10.5	6.7	1.9	-0.1
	10%	WB	-3.0	-2.9	-1.9	-0.1	3.6	7.6	11.5	11.2	9.1	5.5	0.9	-1.0
		MCDB	-2.6	-2.3	-1.4	0.3	4.6	8.9	12.8	12.0	9.9	6.0	1.4	-0.7
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.2	5.1	4.4	3.8	4.3	4.2	4.2	3.8	3.4	3.5	4.1
		MCDBR	4.7	4.7	3.7	3.1	5.8	6.8	6.2	5.6	4.4	3.4	3.0	3.0
		MCWBR	4.9	4.7	3.6	3.0	4.6	4.8	4.5	4.4	3.5	3.2	2.9	2.9
	5% WB	MCDBR	4.7	4.5	3.7	3.1	5.6	6.3	5.6	5.2	3.9	3.5	2.9	3.0
		MCWBR	4.8	4.5	3.7	3.0	4.5	4.8	4.5	4.2	3.4	3.4	2.9	3.1
Clear-Sky Solar Irradiance	taub	0.216	0.259	0.300	0.329	0.338	0.339	0.372	0.350	0.324	0.291	0.361	N/A	
	taud	1.915	2.030	2.092	2.168	2.345	2.491	2.436	2.487	2.509	2.252	2.554	N/A	
	Ebn at Noon	90	522	720	811	854	866	817	799	730	498	111	0	
	Edh at Noon	10	51	87	108	102	91	94	80	61	42	13	0	
All-Sky Solar Radiation	RadAvg	0.03	0.46	1.89	3.53	4.65	5.20	4.81	3.19	1.67	0.47	0.07	0.00	
	RadStd	0.00	0.08	0.24	0.40	0.38	0.59	0.56	0.33	0.19	0.07	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page