

MYS ABRAMOVSKIY, Russian Federation

WMO: 223650

Lat: 66.409N

Lon: 43.267E

Elev: 20

StdP: 101.08

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.9	-23.1	-28.5	0.3	-25.9	-25.4	0.4	-23.0	18.3	-6.0	16.0	-6.1	3.5	180	0.893

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	21.6	17.0	19.4	15.6	17.7	14.8	17.4	20.9	16.2	18.8	15.1	17.4	4.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	11.3	18.8	14.9	10.6	18.1	13.8	9.9	17.0	49.1	21.3	45.7	18.8	42.4	17.4	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.7	11.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-10.5	-9.6	-5.9	-1.8	3.0	8.5	11.8	12.0	8.1	2.0	-4.5	-7.7
	DBStd	9.21	6.67	6.29	4.79	3.67	4.52	3.87	4.06	3.07	3.02	3.60	5.01	6.29
	HDD10.0	3671	634	549	492	355	224	74	26	12	72	249	434	548
	HDD18.3	6511	893	783	751	605	476	296	207	198	307	507	684	806
	CDD10.0	208	0	0	0	0	7	29	82	74	16	0	0	0
	CDD18.3	7	0	0	0	0	0	1	4	2	0	0	0	0
	CDH23.3	33	0	0	0	0	0	4	19	9	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
(14) Wind	WSAvg	6.0	6.9	6.5	6.5	5.9	5.5	5.6	5.2	5.5	5.7	6.2	6.1	6.3
(15) Precipitation	PrecAvg	731	59	47	39	37	47	62	61	78	72	86	73	71
	PrecMax	975	88	103	78	65	95	119	125	151	137	155	118	109
	PrecMin	626	23	17	12	7	18	20	17	20	28	41	33	28
	PrecStd	73	14	19	17	15	17	22	28	27	25	26	20	20
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.9	1.6	2.9	8.9	19.1	22.8	26.0	24.5	18.5	11.2	4.2	1.7
		MCWB	0.2	0.7	1.0	5.5	11.5	17.6	18.2	18.2	15.4	9.9	3.5	0.7
	2%	DB	0.0	0.7	1.6	6.0	15.4	19.1	22.4	20.9	15.8	8.8	2.6	0.9
		MCWB	-0.3	0.0	0.5	3.4	11.3	15.1	17.3	16.7	13.2	8.0	1.9	0.2
	5%	DB	-1.0	0.0	0.9	4.1	12.6	17.1	19.8	18.8	13.8	7.5	1.8	0.2
		MCWB	-1.5	-0.4	0.0	2.1	9.7	13.3	16.0	15.5	11.8	6.6	1.1	-0.3
	10%	DB	-2.4	-1.1	0.2	2.8	9.7	14.7	18.0	17.1	12.3	6.5	1.2	-0.6
		MCWB	-3.0	-1.5	-0.6	1.3	7.1	11.9	15.2	14.9	10.8	5.6	0.5	-1.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.4	1.1	1.2	5.6	14.3	18.0	19.1	18.8	15.8	10.2	3.7	1.0
		MCDB	0.8	1.3	2.1	8.4	17.3	23.1	24.2	22.9	18.1	11.0	4.1	1.4
	2%	WB	-0.3	0.2	0.7	3.6	11.4	15.7	17.6	17.2	13.5	8.1	2.2	0.3
		MCDB	0.0	0.6	1.3	5.6	14.2	18.7	21.7	19.9	15.1	8.7	2.4	0.8
	5%	WB	-1.5	-0.5	0.2	2.4	9.6	13.6	16.4	16.0	12.1	6.8	1.3	-0.2
		MCDB	-1.0	-0.1	0.9	3.9	13.1	16.6	19.4	18.0	13.5	7.4	1.6	0.2
	10%	WB	-3.0	-1.6	-0.5	1.5	7.2	12.0	15.4	14.9	11.0	5.7	0.6	-1.1
		MCDB	-2.6	-1.1	0.2	2.6	9.5	14.6	17.7	17.0	12.2	6.4	1.1	-0.7
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	5.7	5.4	5.3	5.4	5.4	5.0	5.6	4.5	3.6	4.1	5.3
		MCDBR	4.5	3.3	3.8	6.4	10.6	9.5	9.5	9.7	7.6	5.0	3.1	4.4
	5% WB	MCWBR	4.6	3.1	3.3	4.7	7.3	6.2	5.3	6.0	5.2	4.4	2.9	4.2
		MCWBR	4.2	3.5	3.2	5.3	10.3	9.2	8.1	8.7	6.7	4.7	2.6	4.4
(40) Clear-Sky Solar Irradiance	taub	taub	0.218	0.270	0.304	0.335	0.344	0.344	0.380	0.354	0.329	0.299	0.355	0.369
		taud	1.925	2.050	2.097	2.141	2.401	2.494	2.418	2.472	2.509	2.297	2.557	2.575
	Ebn at Noon	Ebn at Noon	179	556	736	814	856	867	815	803	740	541	190	40
		Edh at Noon	17	57	91	113	98	92	97	83	63	45	17	8
(44) All-Sky Solar Radiation	RadAvg	0.07	0.55	2.00	3.76	4.65	5.24	4.90	3.33	1.79	0.60	0.11	0.01	
	RadStd	0.01	0.07	0.19	0.25	0.35	0.46	0.52	0.35	0.20	0.10	0.01	0.00	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page