

SEGEZHA, Russian Federation

WMO: 226210

Lat: 63.7591N

Lon: 34.2863E

Elev: 112

StdP: 99.99

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.8	(c) -25.5	(d) -31.3	(e) 0.2	(f) -28.8	(g) -27.8	(h) 0.3	(i) -25.4	(j) 9.7	(k) -5.9	(l) 8.9	(m) -4.9	(n) 1.0	(o) 230	(p) 0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.0	(c) 26.5	(d) 18.0	(e) 24.4	(f) 17.1	(g) 22.5	(h) 16.2	(i) 19.5	(j) 24.1	(k) 18.3	(l) 22.6	(m) 17.2	(n) 21.1	(o) 3.3	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 17.8	(b) 13.0	(c) 21.6	(d) 16.6	(e) 12.0	(f) 20.4	(g) 15.5	(h) 11.1	(i) 19.3	(j) 56.1	(k) 24.2	(l) 52.3	(m) 22.6	(n) 48.7	(o) 21.2	(p) 24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	7.4	6.4	-31.4	28.8	4.8	2.7	-34.8	30.7	-37.6	32.3	-40.3	33.8	-43.8	35.8
			-31.7	21.0	4.7	1.6	-35.0	22.1	-37.8	23.0	-40.4	23.9	-43.8	25.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.4	-10.4	-10.3	-5.4	1.0	7.4	13.0	16.5	14.3	9.1	2.9	-3.2	-7.3		
	DBStd	10.69	7.65	7.60	5.18	4.42	5.11	4.41	3.81	3.50	3.40	4.02	5.22	7.06		
	HDD10.0	3296	632	568	477	271	112	18	2	5	56	223	395	537		
	HDD18.3	5863	890	801	735	520	338	169	82	132	276	480	645	796		
	CDD10.0	514	0	0	0	1	33	108	202	139	29	1	0	0		
	CDD18.3	42	0	0	0	0	1	9	24	8	0	0	0	0		
	CDH23.3	288	0	0	0	0	13	66	161	49	0	0	0	0		
	CDH26.7	47	0	0	0	0	2	9	29	7	0	0	0	0		
(14) Wind	WSAvg	2.9	3.0	3.1	3.1	2.8	2.9	2.8	2.6	2.4	2.8	3.1	3.1	3.2		
(15) Precipitation	PrecAvg	635	42	32	32	30	52	70	84	70	63	61	52	45		
	PrecMax	867	66	71	59	62	93	118	231	154	149	123	82	86		
	PrecMin	485	17	6	14	4	19	39	18	11	11	14	12	7		
	PrecStd	100	14	16	11	14	18	22	49	36	29	29	15	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.7	3.2	7.2	16.9	25.2	28.0	29.7	27.4	20.8	13.2	7.7	4.4		
		MCWB	1.8	1.8	3.1	9.5	14.3	17.7	20.4	18.9	15.6	11.1	6.4	3.8		
	2%	DB	1.2	1.7	4.3	12.2	21.6	25.3	26.9	24.5	17.7	11.1	6.1	2.7		
		MCWB	0.5	0.8	1.3	7.1	12.9	17.1	18.8	17.4	13.6	9.6	5.3	2.0		
	5%	DB	0.4	0.8	2.6	9.5	18.5	22.7	25.0	22.3	15.8	9.6	4.5	1.7		
		MCWB	-0.1	0.0	0.5	5.0	11.0	15.5	17.9	16.5	12.6	8.4	3.9	1.1		
	10%	DB	-0.6	-0.3	1.3	7.2	16.1	20.6	23.0	20.4	14.3	8.3	2.9	0.9		
		MCWB	-1.0	-0.9	0.0	3.8	10.2	14.6	16.9	15.7	11.8	7.3	2.2	0.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.8	2.1	3.5	10.5	16.2	19.9	21.8	20.2	16.0	11.6	6.8	4.0		
		MCDB	2.6	2.8	6.5	14.9	22.2	24.9	27.6	25.4	19.1	12.5	7.4	4.2		
	2%	WB	0.6	1.0	1.8	7.8	13.9	18.4	20.2	18.4	14.2	10.0	5.3	2.1		
		MCDB	1.0	1.5	3.5	11.8	18.8	23.1	24.8	22.8	16.8	11.0	6.0	2.5		
	5%	WB	0.0	0.1	0.9	5.6	12.2	16.8	19.0	17.2	13.1	8.6	4.0	1.1		
		MCDB	0.4	0.7	2.0	8.5	17.2	21.0	23.3	21.2	15.1	9.4	4.6	1.6		
	10%	WB	-1.0	-0.9	0.2	4.1	10.6	15.1	17.8	16.1	12.2	7.4	2.4	0.4		
		MCDB	-0.6	-0.2	1.3	6.7	15.3	19.9	21.7	19.5	14.1	8.2	2.8	0.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	6.3	7.3	7.8	8.4	8.4	8.0	7.5	6.2	4.1	4.1	5.0		
		MCDBR	4.7	5.2	7.0	11.0	13.1	11.2	11.0	10.7	8.5	5.1	4.2	4.0		
	5% WB	MCWBR	4.6	4.9	5.2	6.5	6.2	5.2	4.7	5.0	5.1	3.9	3.9	4.0		
		MCWBR	4.4	5.0	5.6	10.1	11.0	9.5	9.4	8.9	7.5	4.6	4.1	4.0		
(40) Clear-Sky Solar Irradiance	taub		0.223	0.280	0.308	0.344	0.351	0.344	0.374	0.354	0.328	0.304	0.229	0.206		
	taud		1.970	2.092	2.155	2.296	2.443	2.496	2.428	2.461	2.515	2.385	2.046	1.954		
	Ebn at Noon		352	623	772	832	863	877	834	820	771	619	342	157		
	Edh at Noon		29	65	93	102	97	94	98	87	67	50	26	13		
(44) All-Sky Solar Radiation	RadAvg		0.17	0.76	2.25	3.71	4.71	5.36	4.96	3.64	2.05	0.77	0.18	0.07		
	RadStd		0.02	0.14	0.26	0.37	0.47	0.44	0.57	0.36	0.23	0.10	0.03	0.01		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page