

PUDOZH, Russian Federation

WMO: 228310

Lat: 61.8214N

Lon: 36.5779E

Elev: 157

StdP: 14.61

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.7	-17.7	-30.0	1.0	-24.6	-22.8	1.6	-17.6	16.1	27.1	13.6	26.0	0.8	90	0.595

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	82.7	67.5	78.9	65.6	75.3	63.8	69.7	78.8	67.5	76.2	65.4	73.0	4.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	98.0	74.3	64.3	90.9	71.9	62.2	84.1	69.5	33.8	78.7	32.1	76.3	30.4	73.0	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.8	10.1	DB	-28.6	87.1	7.0	4.5	-33.6	90.3	-37.8	92.9	-41.7	95.4	-46.8	98.6	(4)
(5)			WB	-29.1	72.7	6.9	2.6	-34.1	74.5	-38.1	76.1	-42.0	77.5	-47.0	79.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	37.4	13.0	14.1	23.6	36.2	48.4	57.3	63.3	58.2	49.0	38.1	26.7	19.3	(6)
(7)		DBStd	19.87	15.39	14.64	9.55	8.18	8.96	7.62	6.57	6.15	6.57	7.31	10.50	13.73	(7)
(8)		HDD50	5675	1147	1005	818	420	140	17	2	7	95	374	698	952	(8)
(9)		HDD65	10170	1612	1425	1283	863	519	254	109	225	480	835	1148	1417	(9)
(10)		CDD50	1079	0	0	0	7	90	236	415	261	66	4	0	0	(10)
(11)		CDD65	98	0	0	0	0	4	23	57	14	0	0	0	0	(11)
(12)		CDH74	1034	0	0	0	4	69	279	539	142	1	0	0	0	(12)
(13)		CDH80	237	0	0	0	0	11	67	135	24	0	0	0	0	(13)
(14)	Wind	WSAvg	4.0	3.7	3.8	4.2	4.0	5.0	4.3	3.6	3.4	3.6	4.1	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	27.2	1.7	1.3	1.6	1.6	1.9	2.2	2.7	3.1	2.9	3.2	2.6	2.3	(15)
(16)		PrecMax	34.9	3.6	2.9	3.2	3.6	3.7	5.2	8.7	9.4	5.0	7.0	5.0	3.8	(16)
(17)		PrecMin	19.3	0.3	0.3	0.4	0.5	0.2	0.7	0.6	0.9	1.1	0.1	0.4	0.7	(17)
(18)		PrecStd	3.5	0.7	0.7	0.7	0.8	0.8	1.1	1.6	1.7	1.1	1.4	1.2	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	37.5	48.0	70.2	81.3	86.6	88.4	83.2	72.1	58.9	46.3	42.8	(19)
(20)			MCWB	34.8	35.9	39.3	55.3	62.3	68.4	71.0	68.4	62.5	54.4	44.3	41.8	(20)
(21)		2%	DB	34.4	35.2	41.3	60.4	74.4	81.4	83.7	77.9	66.4	53.1	43.7	38.2	(21)
(22)			MCWB	33.4	34.0	35.5	48.4	58.0	66.4	68.7	65.5	58.5	50.5	42.4	37.3	(22)
(23)		5%	DB	33.2	33.8	38.0	54.0	69.5	76.7	79.9	73.8	62.8	50.6	41.8	35.9	(23)
(24)			MCWB	32.5	32.9	34.1	44.1	55.7	63.3	66.9	63.7	57.1	48.7	40.8	35.0	(24)
(25)		10%	DB	32.0	32.4	35.8	49.3	64.9	72.5	76.2	70.3	59.7	48.5	39.2	34.1	(25)
(26)			MCWB	31.6	31.5	33.3	41.5	53.1	60.5	65.3	61.7	55.3	46.8	38.4	33.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	36.4	39.9	55.0	65.2	71.7	73.7	71.2	63.7	55.0	44.8	41.6	(27)
(28)			MDCB	35.3	37.0	46.0	67.9	76.6	82.5	84.2	79.7	70.3	58.3	45.6	42.5	(28)
(29)		2%	WB	33.7	34.2	36.8	49.2	61.1	68.2	70.6	67.4	60.3	51.1	42.7	37.3	(29)
(30)			MDCB	34.1	34.8	39.6	58.3	70.5	79.0	80.3	74.8	64.6	52.5	43.5	37.9	(30)
(31)		5%	WB	32.7	33.0	35.0	45.5	57.3	65.3	68.4	64.9	57.7	49.1	40.9	35.1	(31)
(32)			MDCB	33.2	33.7	37.1	52.5	66.6	74.5	77.0	71.2	61.5	50.4	41.8	35.8	(32)
(33)		10%	WB	31.6	31.6	33.7	42.2	54.2	62.0	66.7	62.9	55.7	47.0	38.4	33.4	(33)
(34)			MDCB	32.2	32.4	35.3	48.2	63.6	70.4	74.5	68.9	59.1	48.3	39.2	34.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.9	14.1	16.1	17.9	19.6	19.1	18.1	17.6	14.7	9.6	8.3	9.3	(35)
(36)			MCDBR	7.6	8.6	17.7	26.6	27.7	26.1	24.4	24.0	20.8	12.6	8.1	6.6	(36)
(37)			MCWBR	7.6	8.1	12.8	15.9	13.7	12.4	11.9	13.0	13.2	9.9	7.6	6.4	(37)
(38)		5% WB	MCDBR	7.5	8.1	12.1	23.9	24.5	22.6	21.2	19.9	17.2	11.5	7.6	6.7	(38)
(39)			MCWBR	7.6	7.9	9.0	15.2	13.5	11.6	11.3	11.8	11.6	9.6	7.4	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.248	0.297	0.322	0.363	0.355	0.351	0.387	0.369	0.339	0.321	0.267	0.217	(40)	
(41)		taud	2.015	2.073	2.129	2.256	2.445	2.485	2.400	2.426	2.496	2.382	2.111	1.957	(41)	
(42)		Ebn at Noon	134	203	245	261	275	278	263	258	246	202	127	87	(42)	
(43)		Edh at Noon	12	23	32	35	31	31	33	29	23	18	11	7	(43)	
(44)	All-Sky Solar Radiation	RadAvg	73	256	693	1197	1586	1700	1623	1215	686	267	73	35	(44)	
(45)		RadStd	10	64	93	116	109	115	189	105	69	36	13	4	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+1.06	N/A	N/A	N/A	N/A	N/A	-398	-419	N/A	N/A

Nomenclature: See separate page