

NYANDOMA, Russian Federation

WMO: 228540

Lat: 61.6794N

Lon: 40.1953E

Elev: 764

StdP: 14.29

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.0	-13.9	-25.7	1.4	-20.0	-18.8	2.0	-13.8	17.1	22.3	15.6	23.3	3.8	20	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	79.9	64.9	76.8	63.2	73.6	61.3	67.0	76.3	65.4	73.8	63.4	70.9	6.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.7	90.9	71.3	62.0	85.5	69.3	60.2	80.0	67.6	32.0	76.4	30.6	74.1	29.2	70.4	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
15.2	13.7	12.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-22.3	85.2	7.3	3.0	-27.6	87.3	-31.8	89.0	-35.9	90.7	-41.2	92.8		
			-22.6	70.0	7.2	2.4	-27.8	71.7	-32.0	73.2	-36.0	74.5	-41.3	76.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.7	10.8	14.2	22.4	35.3	47.1	56.3	61.8	56.9	47.7	35.5	23.2	16.2
	DBStd	19.98	14.15	12.89	9.00	9.30	9.89	8.17	6.66	6.65	6.89	7.78	10.97	12.42
	HDD50	6174	1214	1001	856	450	179	28	4	14	122	453	804	1049
	HDD65	10759	1679	1421	1321	891	559	281	142	264	518	915	1254	1514
	CDD50	968	0	0	0	9	88	218	369	227	54	3	0	0
	CDD65	79	0	0	0	0	3	21	43	12	0	0	0	0
	CDH74	608	0	0	0	2	35	192	296	83	0	0	0	0
	CDH80	86	0	0	0	0	2	38	39	7	0	0	0	0
Wind	WSAvg	6.0	6.1	6.6	6.8	6.0	6.1	5.7	5.1	5.2	5.5	6.5	6.6	6.3
Precipitation	PrecAvg	29.7	2.1	1.8	1.8	1.6	2.5	2.8	2.8	3.1	2.6	2.9	3.0	2.6
	PrecMax	36.1	3.6	4.1	3.0	3.3	5.3	5.2	6.7	6.4	5.6	5.1	5.5	4.6
	PrecMin	23.8	0.7	0.5	0.3	0.3	0.8	0.6	0.8	1.8	0.9	0.8	0.9	1.1
	PrecStd	3.2	0.7	0.9	0.7	0.7	1.0	1.2	1.2	1.3	1.2	1.1	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	35.7	44.8	69.1	78.9	84.4	84.5	80.5	70.9	57.7	42.7	36.9
		MCWB	32.1	34.4	36.2	52.3	59.6	66.5	68.3	64.7	60.7	51.2	41.3	35.9
	2%	DB	32.3	33.4	39.5	60.9	73.0	79.2	80.2	76.1	65.5	51.9	40.3	33.9
		MCWB	31.5	32.3	33.6	48.6	56.8	64.1	65.7	63.4	58.1	49.4	39.4	32.9
	5%	DB	31.3	32.0	36.3	53.8	68.5	75.1	77.5	72.1	61.4	49.0	38.2	32.6
		MCWB	30.6	31.1	32.6	44.5	54.4	61.3	64.5	61.5	55.5	47.3	37.6	31.8
	10%	DB	29.3	30.5	34.1	48.7	64.0	71.0	74.3	68.6	58.0	46.2	35.8	31.4
		MCWB	28.6	29.6	31.6	40.9	52.5	58.9	62.8	60.3	53.8	44.7	35.1	30.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.9	34.7	37.1	53.9	62.6	68.7	70.4	67.2	62.0	52.7	41.8	36.3
		MCDB	33.1	35.5	41.4	67.4	74.7	80.1	81.1	76.3	68.1	55.8	42.4	36.8
	2%	WB	31.8	32.5	35.1	49.2	59.5	66.2	67.6	65.0	59.2	49.5	39.6	33.4
		MCDB	32.2	33.0	38.2	59.4	68.8	77.1	76.3	72.8	64.3	51.2	40.0	33.7
	5%	WB	30.6	31.2	33.4	45.2	56.2	63.5	66.2	63.1	56.8	47.5	37.7	32.1
		MCDB	31.2	31.9	35.4	52.5	64.3	71.9	74.7	69.9	60.5	49.1	38.2	32.5
	10%	WB	28.6	29.6	32.1	41.6	53.7	60.8	64.6	61.2	54.4	44.8	35.1	30.7
		MCDB	29.3	30.5	33.8	47.5	63.0	68.7	72.3	67.2	57.4	46.2	35.6	31.3
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.5	13.2	15.4	16.8	16.5	15.9	14.4	11.7	7.1	7.0	8.2
		MCDBR	8.3	8.2	13.9	22.5	23.7	22.4	20.6	19.7	17.2	10.4	6.5	6.8
		MCWBR	8.3	8.2	9.9	12.8	11.3	10.4	9.0	9.0	9.8	8.1	6.6	6.9
	5% WB	MCDBR	8.8	7.5	10.5	20.8	20.2	19.4	17.9	17.0	15.2	10.0	6.4	7.0
		MCWBR	8.8	7.6	7.9	12.5	11.5	10.0	8.9	8.9	9.5	8.1	6.5	7.2
Clear-Sky Solar Irradiance	taub	0.243	0.293	0.319	0.358	0.348	0.347	0.382	0.364	0.333	0.314	0.265	0.213	
	taud	2.012	2.074	2.106	2.216	2.448	2.472	2.384	2.412	2.488	2.387	2.116	1.946	
	Ebn at Noon	139	206	247	262	277	279	264	259	248	206	130	91	
	Edh at Noon	12	23	33	36	31	31	33	30	23	18	11	7	
All-Sky Solar Radiation	RadAvg	79	266	666	1135	1552	1658	1636	1174	664	262	74	36	
	RadStd	12	69	107	119	115	153	143	111	75	32	13	5	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+1.17	N/A	N/A	N/A	N/A	N/A	-356	-391	N/A	N/A

Nomenclature: See separate page