

NOVY PORT, Russian Federation

WMO: 232420

Lat: 67.6878N

Lon: 72.8842E

Elev: 12

StdP: 101.18

Time Zone: 5.00 (E05)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.3	-38.6	-43.1	0.1	-40.2	-41.2	0.1	-38.4	19.1	-10.4	16.5	-12.1	2.9	0	0.939

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	23.4	18.8	20.9	17.3	18.3	15.2	19.1	22.8	17.3	20.9	15.6	18.1	3.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.6	21.6	15.7	11.2	19.4	14.2	10.1	17.6	54.4	22.7	48.9	21.3	43.9	17.8	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.7	12.0	10.5	-41.7	25.3	3.0	3.4	-43.9	27.8	-45.6	29.8	-47.3	31.7	-49.5	34.1		
			-41.8	19.6	2.9	2.4	-43.9	21.3	-45.6	22.7	-47.3	24.1	-49.4	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.5	-23.5	-23.0	-16.1	-10.6	-3.6	6.7	13.4	10.0	5.3	-3.1	-14.7	-19.3
	DBStd	14.15	7.99	8.90	8.32	6.51	4.49	4.64	4.77	3.34	3.60	5.18	7.78	8.67
	HDD10.0	6202	1038	925	810	619	421	122	19	42	148	407	742	907
	HDD18.3	9064	1297	1158	1068	869	679	351	168	259	391	666	992	1166
	CDD10.0	197	0	0	0	0	0	23	125	42	7	0	0	0
	CDD18.3	16	0	0	0	0	0	1	16	0	0	0	0	0
	CDH23.3	52	0	0	0	0	0	3	49	0	0	0	0	0
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	5.2	5.7	5.1	5.3	5.5	5.7	4.8	4.7	4.8	4.7	5.1	5.2	5.3
Precipitation	PrecAvg	395	26	19	22	20	27	34	37	57	45	35	26	27
	PrecMax	619	84	45	72	52	81	94	101	154	107	73	56	61
	PrecMin	256	9	1	4	0	13	4	3	12	2	11	4	3
	PrecStd	99	15	11	14	12	13	21	29	34	22	13	12	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.3	-3.8	0.2	2.5	8.4	21.8	26.7	21.2	16.8	8.8	0.9	-1.0
		MCWB	-4.3	-4.6	-0.4	1.3	6.4	16.7	19.3	16.7	13.8	7.9	0.7	-1.2
	2%	DB	-7.1	-5.8	-1.2	1.4	4.3	18.6	24.7	18.3	13.7	5.6	-0.5	-3.6
		MCWB	-7.8	-6.3	-1.8	0.6	3.0	15.0	19.1	15.3	12.5	4.8	-0.7	-4.1
	5%	DB	-8.9	-7.6	-2.3	0.7	2.9	16.1	23.2	17.3	12.3	4.4	-3.0	-5.4
		MCWB	-9.3	-8.1	-2.9	0.1	1.8	12.6	18.9	14.8	11.1	3.7	-3.4	-5.8
	10%	DB	-12.2	-10.0	-4.2	-0.4	1.7	13.7	21.3	15.8	10.9	3.0	-4.6	-7.4
		MCWB	-12.6	-10.4	-4.8	-1.0	0.7	10.9	17.8	13.7	9.7	2.3	-5.0	-7.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.2	-4.4	-0.3	1.7	6.6	17.4	21.2	17.2	13.9	7.8	0.6	-1.2
		MCDB	-3.3	-3.9	0.1	2.5	7.8	21.1	24.4	19.5	16.2	8.6	0.7	-1.1
	2%	WB	-7.6	-6.2	-1.7	0.8	3.2	15.4	20.1	16.0	12.7	5.1	-0.7	-3.9
		MCDB	-7.1	-5.8	-1.4	1.3	4.1	18.5	23.4	17.8	13.7	5.4	-0.4	-3.5
	5%	WB	-9.4	-8.0	-3.0	0.2	1.7	13.1	19.0	15.1	11.2	3.8	-3.4	-5.8
		MCDB	-8.9	-7.6	-2.4	0.9	2.6	15.7	22.8	17.2	12.1	4.3	-3.1	-5.4
	10%	WB	-12.4	-10.4	-4.7	-1.0	0.9	10.8	17.6	13.8	9.8	2.4	-5.1	-7.8
		MCDB	-12.1	-10.0	-4.1	-0.4	1.5	13.6	21.3	15.6	10.7	3.0	-4.6	-7.4
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.1	8.0	7.9	4.8	5.3	6.2	6.1	4.2	3.9	6.3	7.2
		MCDBR	11.5	7.6	8.0	6.3	4.9	9.0	7.8	7.0	5.0	3.6	5.6	7.2
		MCWBR	10.5	7.6	8.0	6.0	4.0	6.2	4.3	4.8	3.7	3.3	5.7	7.3
	5% WB	MCDBR	10.6	7.6	8.1	6.2	4.8	8.6	7.4	6.5	4.7	3.5	5.8	7.4
		MCWBR	10.4	7.6	8.1	5.8	4.0	6.6	4.5	4.9	3.7	3.3	5.8	7.5
Clear-Sky Solar Irradiance	taub	0.209	0.255	0.304	0.326	0.343	0.363	0.389	0.371	0.320	0.271	0.203	N/A	
	taud	1.865	1.997	2.022	2.056	2.131	2.326	2.343	2.373	2.460	2.205	1.928	N/A	
	Ebn at Noon	94	527	707	810	841	837	797	769	729	522	93	0	
	Edh at Noon	11	53	94	120	125	107	103	90	63	43	9	0	
All-Sky Solar Radiation	RadAvg	0.03	0.47	2.11	3.97	5.99	5.80	5.08	3.29	1.72	0.59	0.09	0.00	
	RadStd	0.00	0.07	0.17	0.48	0.28	0.32	0.63	0.38	0.20	0.10	0.01	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page