

TAZOVSKY, Russian Federation

WMO: 232560

Lat: 67.467N

Lon: 78.733E

Elev: 28

StdP: 100.99

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.2	-41.6	-47.1	0.0	-44.1	-44.5	0.0	-41.6	16.9	-14.5	14.3	-15.8	2.4	120	0.906

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	25.4	18.1	22.8	16.9	20.5	15.9	19.0	23.5	17.6	21.8	16.3	19.9	4.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	12.4	21.1	15.9	11.3	19.5	14.6	10.4	18.5	54.3	23.5	50.0	21.6	46.0	19.8	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.4	9.9	DB	-45.1	28.4	4.0	2.3	-47.9	30.0	-50.2	31.4	-52.4	32.7	-55.3	34.3	(4)
(5)			WB	-45.1	20.5	3.9	1.5	-47.8	21.6	-50.1	22.5	-52.2	23.3	-55.1	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.5	-25.9	-24.7	-17.8	-12.2	-3.6	8.8	14.4	11.2	4.7	-5.2	-18.5	-22.4	(6)
(7)		DBStd	15.92	9.60	9.52	9.23	8.02	5.67	6.24	4.46	3.83	4.23	6.77	9.03	9.80	(7)
(8)		HDD10.0	6669	1113	971	862	664	423	98	9	29	168	471	854	1006	(8)
(9)		HDD18.3	9453	1371	1204	1121	914	681	291	140	224	409	729	1104	1264	(9)
(10)		CDD10.0	282	0	0	0	0	1	63	144	66	8	0	0	0	(10)
(11)		CDD18.3	25	0	0	0	0	0	6	17	2	0	0	0	0	(11)
(12)		CDH23.3	172	0	0	0	0	0	35	124	13	0	0	0	0	(12)
(13)		CDH26.7	32	0	0	0	0	0	4	26	1	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	5.0	4.8	5.1	5.3	5.1	4.5	4.4	4.2	4.4	4.7	4.7	5.1	(14)
(15)	Precipitation	PrecAvg	591	46	44	45	44	39	49	56	67	53	56	46	47	(15)
(16)		PrecMax	840	142	132	143	86	113	93	152	167	131	91	85	114	(16)
(17)		PrecMin	396	7	6	5	0	3	3	12	24	24	19	9	12	(17)
(18)		PrecStd	93	30	29	28	21	21	20	33	31	23	18	19	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.5	-3.3	0.7	4.2	14.6	27.4	29.5	25.0	18.9	8.7	1.0	-1.7	(19)
(20)			MCWB	-4.0	-3.6	-0.3	2.1	10.1	16.8	19.6	17.7	14.5	8.2	0.6	-1.9	(20)
(21)		2%	DB	-6.7	-5.9	-1.2	2.7	8.5	23.8	26.6	22.1	15.3	6.2	-0.5	-3.4	(21)
(22)			MCWB	-7.1	-6.2	-1.7	1.2	5.5	16.7	18.9	17.1	12.3	5.5	-0.8	-3.8	(22)
(23)		5%	DB	-9.5	-8.5	-2.9	1.5	5.5	21.1	24.1	19.6	12.9	4.2	-2.7	-5.5	(23)
(24)			MCWB	-9.9	-8.9	-3.4	0.5	3.5	15.5	18.0	15.5	10.6	3.6	-3.1	-5.9	(24)
(25)		10%	DB	-12.3	-11.2	-4.9	0.3	3.2	18.5	21.7	17.3	10.9	2.4	-5.2	-8.1	(25)
(26)			MCWB	-12.7	-11.6	-5.4	-0.5	1.7	14.0	16.7	14.4	9.3	1.8	-5.7	-8.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.9	-3.5	-0.1	2.4	10.7	19.2	21.1	19.2	15.5	8.2	0.7	-1.9	(27)
(28)			MCDWB	-3.5	-3.4	0.4	3.8	14.1	23.7	26.7	23.2	17.8	8.8	0.8	-1.7	(28)
(29)		2%	WB	-7.0	-6.2	-1.7	1.4	5.9	17.3	19.9	17.6	12.7	5.7	-0.8	-3.7	(29)
(30)			MCDWB	-6.6	-5.9	-1.2	2.5	8.3	22.1	24.4	20.9	14.7	6.0	-0.5	-3.4	(30)
(31)		5%	WB	-9.9	-8.8	-3.4	0.6	3.5	16.0	18.5	16.3	11.0	3.7	-3.0	-5.9	(31)
(32)			MCDWB	-9.5	-8.6	-3.0	1.5	5.3	20.5	23.1	18.9	12.7	4.1	-2.7	-5.6	(32)
(33)		10%	WB	-12.7	-11.6	-5.4	-0.5	1.9	14.4	17.2	14.8	9.4	1.9	-5.6	-8.4	(33)
(34)			MCDWB	-12.3	-11.2	-4.9	0.3	3.0	18.4	21.3	17.0	10.7	2.4	-5.2	-8.1	(34)
(35)	Mean Daily Temperature Range	MDBR	7.2	7.3	8.1	8.5	6.0	6.7	7.5	6.4	5.3	4.9	6.9	7.1	(35)	
(36)		5% DB	MCDBR	9.6	8.7	8.4	5.9	7.7	10.2	10.6	9.5	8.9	5.0	7.3	7.7	(36)
(37)			MCWBR	9.3	8.7	8.4	5.1	5.3	5.0	4.9	4.9	5.6	4.4	7.3	7.7	(37)
(38)		5% WB	MCDWB	9.6	8.9	8.6	6.3	7.5	9.2	9.8	8.8	8.1	4.5	7.3	7.4	(38)
(39)			MCWBR	9.6	8.9	8.5	5.7	5.3	5.2	5.3	5.1	5.7	4.3	7.3	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.210	0.257	0.308	0.326	0.345	0.369	0.404	0.382	0.325	0.269	0.201	N/A	(40)	
(41)		taud	1.868	2.005	2.017	2.069	2.168	2.386	2.290	2.318	2.431	2.179	1.899	N/A	(41)	
(42)		Ebn at Noon	107	534	704	812	841	834	782	756	723	527	103	0	(42)	
(43)		Edh at Noon	12	54	95	119	121	101	108	95	66	44	10	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.04	0.50	2.11	4.28	5.47	5.51	5.02	3.31	1.78	0.58	0.11	0.00	(44)	
(45)		RadStd	0.00	0.06	0.17	0.31	0.43	0.46	0.62	0.44	0.25	0.07	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+1.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page