

PECHORA, Russian Federation

WMO: 234180

Lat: 65.1261N

Lon: 57.1350E

Elev: 194

StdP: 14.59

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.4	-34.8	-45.8	0.4	-41.3	-39.3	0.6	-34.5	21.6	11.1	18.5	12.4	1.3	120	0.719

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	82.6	66.3	78.2	63.9	74.0	61.8	68.1	79.2	65.9	75.5	63.4	71.7	7.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	90.2	72.8	62.0	83.6	70.9	59.6	76.6	68.9	32.5	79.4	30.8	75.6	28.9	71.5	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.6	16.2	14.2	DB	-43.8	87.4	6.1	3.3	-48.1	89.8	-51.7	91.7	-55.1	93.6	-59.5	96.0
(5)				WB	-43.6	71.0	5.6	2.1	-47.6	72.5	-50.9	73.7	-54.0	74.9	-58.1	76.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	29.2	-0.4	1.1	15.1	27.5	40.2	53.1	60.5	53.7	44.7	31.9	14.5	6.2	(6)
(7)		DBStd	24.37	17.96	17.69	13.56	11.48	11.02	10.01	9.30	7.58	7.08	8.77	15.56	18.35	(7)
(8)		HDD50	8350	1563	1369	1081	676	348	82	15	44	189	561	1064	1358	(8)
(9)		HDD65	13172	2028	1789	1546	1125	771	376	204	360	610	1026	1514	1823	(9)
(10)		CDD50	748	0	0	0	1	44	174	339	160	29	1	0	0	(10)
(11)		CDD65	93	0	0	0	0	2	18	63	10	0	0	0	0	(11)
(12)		CDH74	895	0	0	0	0	24	194	605	72	0	0	0	0	(12)
(13)		CDH80	222	0	0	0	0	3	45	162	12	0	0	0	0	(13)
(14)	Wind	WSAvg	6.8	6.6	6.3	6.9	7.2	7.5	7.2	6.2	6.4	6.3	7.2	6.6	6.8	(14)
(15)	Precipitation	PrecAvg	22.4	1.5	1.2	1.2	1.3	1.3	1.8	2.2	3.0	2.6	2.3	2.0	1.8	(15)
(16)		PrecMax	29.8	2.9	2.1	2.8	2.6	2.7	4.4	4.7	7.1	5.4	3.7	3.7	3.1	(16)
(17)		PrecMin	17.4	0.7	0.1	0.3	0.4	0.3	0.6	0.9	0.6	1.3	1.2	1.2	0.2	(17)
(18)		PrecStd	3.2	0.6	0.5	0.6	0.6	0.4	0.9	1.1	1.6	1.0	0.7	0.6	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	34.4	44.0	58.7	77.0	85.6	88.6	81.0	69.3	54.3	39.8	34.9	(19)
(20)		MCWB	31.4	32.8	36.6	45.7	58.8	66.3	68.7	66.5	59.2	49.4	38.5	33.3	(20)	
(21)		2%	DB	28.9	31.6	37.3	49.8	70.8	79.8	84.6	75.0	62.8	49.9	36.3	33.1	(21)
(22)		MCWB	27.8	30.2	32.2	41.3	55.4	63.1	67.4	63.2	55.7	46.5	35.3	31.9	(22)	
(23)		5%	DB	25.6	28.6	34.7	45.6	64.7	74.6	80.7	71.0	58.3	46.1	34.1	31.1	(23)
(24)		MCWB	24.4	27.0	31.7	38.6	52.1	60.6	65.8	61.4	52.7	43.5	33.2	30.0	(24)	
(25)		10%	DB	21.6	24.6	32.7	42.0	58.8	69.7	76.8	66.5	54.9	43.3	32.4	28.4	(25)
(26)		MCWB	20.5	23.1	30.2	36.6	48.6	58.2	64.1	59.3	50.8	41.4	31.4	27.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.4	33.2	37.3	46.6	61.0	67.5	71.1	68.4	60.4	50.5	38.9	33.8	(27)
(28)		MADB	32.5	34.2	42.9	55.8	73.6	80.3	82.9	78.1	67.1	52.9	39.6	34.4	(28)	
(29)		2%	WB	28.0	30.1	33.7	42.2	57.1	65.1	69.2	65.5	56.5	46.6	35.3	32.1	(29)
(30)		MADB	28.9	31.6	35.9	48.8	69.1	76.6	81.0	72.6	61.6	49.6	36.1	32.9	(30)	
(31)		5%	WB	24.4	27.1	32.2	39.4	52.9	62.5	67.5	62.5	53.7	43.7	33.3	29.9	(31)
(32)		MADB	25.6	28.5	34.5	44.3	63.5	72.1	78.4	68.0	57.3	46.0	33.9	31.0	(32)	
(33)		10%	WB	20.4	23.2	30.1	37.2	49.0	59.6	65.6	59.8	51.2	41.4	31.5	27.1	(33)
(34)		MADB	21.4	24.7	32.7	41.3	58.5	68.5	74.6	65.6	54.3	43.3	32.4	28.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	12.4	13.7	17.4	16.3	15.9	15.7	16.9	13.8	11.1	7.5	10.0	11.5	(35)	
(36)		5% DB	MCDBR	12.5	10.0	13.0	18.1	24.1	23.1	22.8	21.4	16.9	10.1	7.8	9.8	(36)
(37)		MCWBR	12.3	9.6	10.1	11.7	12.5	10.7	9.4	10.8	10.2	7.8	7.8	9.3	(37)	
(38)		5% WB	MADB	12.4	10.0	11.6	15.2	22.6	20.8	20.2	18.3	16.0	9.3	7.6	9.4	(38)
(39)		MCWBR	12.3	9.7	9.8	10.4	12.8	10.9	9.3	11.0	10.8	7.5	7.8	9.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.229	0.282	0.318	0.350	0.354	0.363	0.402	0.377	0.338	0.299	0.223	0.232	(40)	
(41)		taud	1.883	2.013	2.041	2.071	2.306	2.438	2.333	2.379	2.452	2.259	1.932	1.901	(41)	
(42)		Ebn at Noon	75	180	231	255	269	270	252	248	234	180	75	15	(42)	
(43)		Edh at Noon	8	21	32	39	35	31	34	30	22	16	7	3	(43)	
(44)	All-Sky Solar Radiation	RadAvg	42	245	714	1219	1571	1602	1583	1030	553	193	56	11	(44)	
(45)		RadStd	3	30	80	131	121	141	218	122	72	27	11	1	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	+2.11	N/A	N/A	N/A	N/A	N/A	-702	N/A	N/A	

Nomenclature: See separate page