

PECHORA, Russian Federation

WMO: 234180

Lat: 65.1261N

Lon: 57.1350E

Elev: 59

StdP: 100.62

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.8	-37.1	-43.2	0.1	-40.7	-39.6	0.1	-37.0	9.7	-11.6	8.3	-10.9	0.6	120	0.719

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	28.1	19.1	25.7	17.7	23.3	16.6	20.0	26.2	18.9	24.2	17.5	22.1	3.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.9	22.7	16.7	11.9	21.6	15.3	10.9	20.5	57.6	26.3	53.8	24.2	49.4	21.9	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.3	6.3	DB	-42.1	30.8	3.4	1.9	-44.5	32.1	-46.5	33.2	-48.4	34.2	-50.8	35.6	(4)
(5)			WB	-42.0	21.7	3.1	1.2	-44.2	22.5	-46.1	23.2	-47.8	23.8	-50.0	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.6	-18.0	-17.2	-9.4	-2.5	4.6	11.7	15.8	12.1	7.0	0.0	-9.7	-14.3	(6)
(7)		DBStd	13.54	9.98	9.83	7.53	6.38	6.12	5.56	5.17	4.21	3.93	4.87	8.64	10.20	(7)
(8)		HDD10.0	4639	868	761	601	376	193	46	8	24	105	312	591	754	(8)
(9)		HDD18.3	7318	1127	994	859	625	428	209	113	200	339	570	841	1013	(9)
(10)		CDD10.0	416	0	0	0	1	24	97	188	89	16	1	0	0	(10)
(11)		CDD18.3	52	0	0	0	0	1	10	35	6	0	0	0	0	(11)
(12)		CDH23.3	497	0	0	0	0	13	108	336	40	0	0	0	0	(12)
(13)		CDH26.7	123	0	0	0	0	2	25	90	7	0	0	0	0	(13)
(14)	Wind	WSAvg	3.0	2.9	2.8	3.1	3.2	3.4	3.2	2.8	2.8	3.2	3.0	3.0	(14)	
(15)	Precipitation	PrecAvg	569	39	31	31	33	34	46	57	76	66	59	52	46	(15)
(16)		PrecMax	757	73	53	70	67	69	112	120	181	136	93	93	78	(16)
(17)		PrecMin	442	19	3	8	11	8	16	22	15	34	31	31	6	(17)
(18)		PrecStd	81	15	12	14	15	11	24	27	41	25	18	15	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.4	1.4	6.7	14.8	25.0	29.8	31.4	27.2	20.7	12.4	4.3	1.6	(19)
(20)			MCWB	-0.3	0.4	2.6	7.6	14.9	19.1	20.4	19.2	15.1	9.7	3.6	0.7	(20)
(21)		2%	DB	-1.7	-0.2	3.0	9.9	21.6	26.5	29.2	23.9	17.1	9.9	2.4	0.6	(21)
(22)			MCWB	-2.3	-1.0	0.1	5.2	13.0	17.3	19.7	17.3	13.2	8.1	1.8	-0.1	(22)
(23)		5%	DB	-3.6	-1.9	1.5	7.5	18.2	23.6	27.1	21.6	14.6	7.8	1.1	-0.5	(23)
(24)			MCWB	-4.2	-2.8	-0.2	3.6	11.2	15.9	18.8	16.3	11.5	6.4	0.7	-1.1	(24)
(25)		10%	DB	-5.8	-4.1	0.4	5.6	14.9	20.9	24.9	19.2	12.7	6.3	0.2	-2.0	(25)
(26)			MCWB	-6.4	-4.9	-1.0	2.6	9.2	14.6	17.8	15.2	10.4	5.2	-0.3	-2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.3	0.6	2.9	8.1	16.1	19.7	21.7	20.2	15.8	10.3	3.9	1.0	(27)
(28)			MCD B	0.3	1.2	6.0	13.2	23.1	26.8	28.3	25.6	19.5	11.6	4.2	1.3	(28)
(29)		2%	WB	-2.2	-1.0	0.9	5.7	13.9	18.4	20.7	18.6	13.6	8.1	1.9	0.0	(29)
(30)			MCD B	-1.7	-0.2	2.2	9.3	20.6	24.8	27.2	22.5	16.5	9.8	2.3	0.5	(30)
(31)		5%	WB	-4.2	-2.7	0.1	4.1	11.6	16.9	19.7	17.0	12.0	6.5	0.7	-1.2	(31)
(32)			MCD B	-3.6	-2.0	1.4	6.8	17.5	22.3	25.8	20.0	14.1	7.8	1.0	-0.5	(32)
(33)		10%	WB	-6.4	-4.9	-1.1	2.9	9.4	15.3	18.6	15.4	10.6	5.2	-0.3	-2.7	(33)
(34)			MCD B	-5.9	-4.1	0.4	5.1	14.7	20.3	23.7	18.7	12.4	6.3	0.2	-2.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.9	7.6	9.7	9.0	8.8	8.7	9.4	7.6	6.1	4.2	5.6	6.4	(35)
(36)			MCDBR	6.9	5.6	7.2	10.1	13.4	12.8	12.7	11.9	9.4	5.6	4.3	5.4	(36)
(37)			MCWBR	6.9	5.3	5.6	6.5	6.9	5.9	5.2	6.0	5.6	4.3	4.4	5.2	(37)
(38)		5% WB	MCDBR	6.9	5.6	6.4	8.5	12.6	11.6	11.2	10.2	8.9	5.2	4.2	5.2	(38)
(39)			MCWBR	6.8	5.4	5.5	5.8	7.1	6.0	5.1	6.1	6.0	4.2	4.3	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.229	0.282	0.318	0.350	0.354	0.363	0.402	0.377	0.338	0.299	0.223	0.232	(40)	
(41)		taud	1.883	2.013	2.041	2.071	2.306	2.438	2.333	2.379	2.452	2.259	1.932	1.901	(41)	
(42)		Ebn at Noon	235	569	729	803	849	851	796	783	738	569	237	46	(42)	
(43)		Edh at Noon	25	65	100	124	109	99	107	93	69	51	22	8	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.13	0.77	2.25	3.84	4.95	5.05	4.99	3.25	1.74	0.61	0.18	0.04	(44)	
(45)		RadStd	0.01	0.09	0.25	0.41	0.38	0.45	0.69	0.38	0.23	0.08	0.04	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+1.17	N/A	N/A	N/A	N/A	N/A	N/A	-390	N/A	N/A

Nomenclature: See separate page