

NADYM, Russian Federation

WMO: 234450

Lat: 65.4802N

Lon: 72.6892E

Elev: 62

StdP: 14.66

Time Zone: 5.00 (E05)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.5	-41.6	-54.2	0.2	-47.4	-48.6	0.3	-41.5	23.2	5.2	20.7	2.8	2.5	320	0.779

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	83.9	65.0	79.2	63.2	74.2	61.1	67.0	78.2	64.9	76.3	62.6	71.9	7.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.1	86.6	71.6	60.7	79.6	68.5	58.3	72.8	66.8	31.6	77.9	30.0	75.8	28.3	71.8	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.2	17.2	DB	-49.5	89.0	5.9	5.9	-53.8	93.3	-57.2	96.7	-60.5	100.0	-64.8	104.3	(4)
(5)			WB	-49.6	70.6	5.8	4.4	-53.8	73.8	-57.2	76.4	-60.5	78.9	-64.7	82.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.3	-10.7	-6.7	10.4	22.8	33.5	54.6	60.3	53.7	43.5	27.3	4.4	-3.0		
	DBStd	27.50	16.07	16.87	14.82	11.39	10.49	10.42	8.81	6.84	7.82	10.96	16.47	18.64		
	HDD50	10100	1883	1587	1228	817	527	70	9	37	225	704	1369	1644		
	HDD65	14935	2348	2007	1693	1267	976	340	205	358	645	1168	1819	2109		
	CDD50	736	0	0	0	0	16	207	330	151	31	1	0	0		
	CDD65	93	0	0	0	0	0	27	60	6	0	0	0	0		
	CDH74	1053	0	0	0	0	12	307	682	51	1	0	0	0		
	CDH80	312	0	0	0	0	1	73	236	2	0	0	0	0		
	WSAvg	7.8	6.5	6.9	8.0	8.7	9.6	8.4	8.2	7.5	7.5	7.6	7.4	6.8		
	PrecAvg	20.2	1.0	0.8	1.0	1.3	1.4	2.4	2.7	2.8	2.0	2.2	1.4	1.2		
(15) Precipitation	PrecMax	26.9	2.1	1.6	1.7	2.6	2.9	3.7	8.6	5.8	4.4	3.6	2.7	2.3		
	PrecMin	13.8	0.3	0.3	0.1	0.1	0.2	0.7	0.4	0.6	0.7	0.9	0.6	0.5		
	PrecStd	3.0	0.4	0.4	0.4	0.6	0.7	0.7	1.8	1.2	1.0	0.6	0.6	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	29.5	39.2	49.1	74.9	87.4	89.7	79.4	69.9	53.2	37.0	32.0		
		MCWB	27.8	28.3	33.9	40.5	57.1	64.5	67.8	65.2	60.7	48.5	35.6	30.9		
	2%	DB	20.7	25.2	35.5	44.5	64.6	81.5	86.1	74.7	63.0	46.3	34.3	28.4		
		MCWB	19.6	24.1	31.5	37.8	52.0	62.1	65.7	61.9	55.4	44.1	33.5	27.3		
	5%	DB	16.9	21.6	32.9	41.1	55.7	77.4	82.3	70.1	58.8	42.9	30.3	25.2		
		MCWB	16.5	20.5	30.6	36.2	47.8	60.9	65.4	59.6	53.1	41.1	29.6	24.7		
	10%	DB	12.1	16.9	30.5	38.1	48.5	72.1	76.8	65.9	55.5	40.1	26.6	21.1		
		MCWB	11.6	16.0	28.5	34.0	42.1	58.8	63.5	58.4	51.2	38.2	26.1	20.5		
	0.4%	WB	27.8	28.4	34.2	42.3	58.0	67.9	71.2	66.6	61.2	49.0	36.1	31.2		
		MCDB	27.8	29.3	37.5	47.3	72.0	77.9	83.3	73.7	68.5	52.3	36.9	31.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.1	24.1	32.3	38.7	53.1	64.8	68.4	63.7	57.1	44.3	33.5	27.4		
		MCDB	20.7	25.1	34.6	43.3	63.9	76.5	80.4	71.9	61.3	45.3	34.3	28.2		
	5%	WB	16.4	20.5	30.7	36.6	48.2	62.7	66.4	61.4	54.0	41.2	29.8	24.7		
		MCDB	16.9	21.5	32.8	40.3	56.0	73.9	78.1	68.1	57.7	42.8	30.3	25.4		
	10%	WB	11.3	15.9	28.6	34.6	42.6	60.1	64.5	59.1	51.2	38.3	26.0	20.5		
		MCDB	11.9	16.6	30.6	37.6	48.6	69.5	76.3	65.3	54.5	39.8	26.5	21.0		
	5% DB	MDBR	14.2	15.9	18.7	17.9	14.6	17.2	17.1	15.1	11.9	9.2	13.7	14.1		
		MCDBR	17.3	13.9	14.6	15.3	25.2	25.2	25.7	22.1	17.1	9.8	11.3	12.5		
		MCWBR	17.2	13.3	12.1	10.4	14.8	11.4	9.7	11.2	10.5	7.9	10.9	12.4		
		MCWBR	17.2	14.6	14.6	13.4	24.6	23.0	23.2	19.2	15.0	9.3	11.6	12.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	17.1	13.9	12.4	9.8	15.5	12.0	9.9	11.5	10.0	7.9	11.2	12.4		
	Clear-Sky Solar Irradiance	taub	0.210	0.268	0.319	0.336	0.358	0.377	0.402	0.381	0.331	0.289	0.205	0.215		
		taud	1.881	2.031	2.020	2.078	2.223	2.385	2.317	2.348	2.446	2.215	1.915	1.890		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	76	185	229	259	266	265	252	246	235	179	75	12		
		Edh at Noon	7	20	32	39	37	33	34	30	22	16	6	2		
(44) All-Sky Solar Radiation	RadStd	RadAvg	34	243	762	1439	1684	1635	1538	1049	602	217	61	8		
		RadStd	3	19	42	107	127	130	193	121	78	24	7	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page