

KRASNOSELKUPSKY, Russian Federation

WMO: 234650

Lat: **65.7065N**Lon: **82.4552E**Elev: **25**StdP: **101.03**Time Zone: **5.00 (E05)**Period: **86-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-46.4	-43.5	-48.9	0.0	-46.2	-46.0	0.0	-43.4	9.4	-15.6	8.5	-15.2	1.9	40	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	28.2	18.2	25.9	17.1	23.4	16.6	19.6	25.3	18.3	23.4	17.1	22.4	3.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.6	22.2	16.2	11.5	20.8	14.9	10.6	19.6	56.1	25.2	52.0	23.6	48.2	22.1	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.0	7.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			DB													
			WB	-47.7	20.6	2.6	1.3	-49.6	21.5	-51.1	22.3	-52.6	23.0	-54.5	23.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.6	-26.0	-22.7	-14.2	-8.4	0.0	12.7	16.8	12.3	6.3	-4.5	-18.9	-22.1
	DBStd	16.39	9.63	9.08	9.13	7.50	5.52	5.99	4.39	3.45	4.33	6.53	8.60	10.35
	HDD10.0	6143	1114	915	751	552	314	40	2	16	126	449	867	996
	HDD18.3	8799	1373	1148	1009	802	570	187	84	187	360	707	1117	1254
	CDD10.0	441	0	0	0	0	3	121	213	88	16	1	0	0
	CDD18.3	55	0	0	0	0	1	18	36	1	0	0	0	0
	CDH23.3	521	0	0	0	0	2	179	332	7	0	0	0	0
	CDH26.7	127	0	0	0	0	0	47	80	0	0	0	0	0
Wind	WSAvg	3.5	3.3	3.3	3.8	4.1	4.0	3.8	3.3	3.2	3.3	3.7	3.3	3.5
Precipitation	PrecAvg	836	64	58	62	61	61	63	56	81	69	105	81	76
	PrecMax	1017	141	132	112	99	106	119	100	122	126	175	156	110
	PrecMin	555	19	10	13	7	17	22	12	44	29	36	29	22
	PrecStd	107	28	24	23	20	22	20	21	22	24	31	30	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.6	-3.1	2.9	9.3	18.2	30.1	30.9	24.3	21.1	12.5	0.2	-0.7
		MCWB	-5.3	-3.7	-0.2	3.8	12.1	18.0	19.5	17.7	14.5	8.5	-0.6	-1.2
	2%	DB	-7.8	-5.7	1.1	6.0	13.7	28.1	28.9	22.2	17.7	7.3	-1.9	-3.1
		MCWB	-8.4	-6.3	-0.6	2.4	8.4	18.8	18.1	16.0	13.5	6.3	-2.5	-3.8
	5%	DB	-9.8	-7.6	-0.4	4.2	10.0	25.3	27.1	20.4	14.9	5.0	-3.8	-5.4
		MCWB	-10.3	-8.1	-1.7	1.6	5.8	17.3	17.6	15.2	11.5	3.6	-4.3	-5.9
	10%	DB	-12.8	-10.3	-1.9	2.5	7.3	22.3	24.9	18.5	12.7	3.0	-6.3	-8.1
		MCWB	-13.3	-10.8	-3.0	0.5	4.1	16.0	17.0	14.4	10.2	1.7	-6.8	-8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.1	-3.8	1.0	4.3	13.5	21.0	21.6	18.8	15.9	8.1	-0.4	-1.1
		MCDB	-4.5	-3.3	1.6	8.0	18.1	27.2	27.2	22.7	20.2	11.0	0.2	-0.7
	2%	WB	-8.3	-6.2	-0.5	3.0	9.0	19.4	20.1	17.0	13.8	6.4	-2.4	-3.6
		MCDB	-7.7	-5.8	0.9	5.2	12.9	25.5	25.8	20.5	16.8	7.5	-1.9	-3.0
	5%	WB	-10.3	-8.2	-1.7	1.8	6.3	17.8	18.9	15.8	11.9	4.0	-4.3	-6.0
		MCDB	-9.8	-7.8	-0.5	3.9	8.9	22.9	24.6	19.3	14.9	4.8	-3.9	-5.4
	10%	WB	-13.3	-10.8	-3.0	0.7	4.7	16.4	17.8	14.7	10.3	1.9	-6.8	-8.5
		MCDB	-12.9	-10.4	-1.9	2.3	7.2	21.9	23.0	18.1	12.3	2.8	-6.4	-8.1
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.7	9.8	9.9	7.2	9.2	9.2	7.6	6.3	5.3	7.2	7.8
		MCDBR	7.9	10.3	8.5	9.6	10.5	12.8	12.1	10.7	10.0	5.6	7.7	7.8
		MCWBR	8.0	10.2	7.4	7.4	6.8	5.5	5.0	5.9	6.0	4.3	7.6	7.4
	5% WB	MCDBR	7.8	10.0	8.2	8.7	9.6	11.7	10.8	9.3	8.8	5.2	8.0	7.6
		MCWBR	7.8	9.9	7.3	7.1	6.8	6.2	5.6	5.7	5.6	4.5	7.9	7.3
Clear-Sky Solar Irradiance	taub	0.216	0.270	0.317	0.337	0.353	0.370	0.412	0.393	0.340	0.282	0.205	0.218	
	taud	1.870	2.012	2.009	2.059	2.212	2.412	2.279	2.306	2.404	2.199	1.900	1.876	
	Ebn at Noon	215	571	718	812	844	841	782	758	725	566	217	28	
	Edh at Noon	21	62	102	124	119	101	112	99	71	50	19	6	
All-Sky Solar Radiation	RadAvg	0.10	0.74	2.34	4.41	5.34	5.53	5.02	3.24	1.83	0.68	0.19	0.02	
	RadStd	0.01	0.07	0.20	0.44	0.52	0.47	0.55	0.35	0.28	0.11	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A