

YUIL' SK, Russian Federation

WMO: 236350

Lat: 63.6776N

Lon: 69.6503E

Elev: 281

StdP: 14.55

Time Zone: 5.00 (E05)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.9	-40.5	-52.2	0.3	-48.0	-45.2	0.4	-40.3	14.9	4.7	13.1	10.8	1.3	120	0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	83.7	65.8	79.7	63.9	75.5	62.0	68.0	79.0	65.7	76.4	63.5	73.2	6.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	90.7	73.4	61.6	82.9	70.7	59.3	76.1	68.2	32.6	77.8	30.7	76.5	29.1	73.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.6	12.3	10.8	-51.2	87.4	6.9	3.0	-56.1	89.5	-60.1	91.3	-64.0	92.9	-69.0	95.1		
(5)			-50.7	69.8	6.5	2.7	-55.5	71.7	-59.3	73.3	-63.0	74.8	-67.7	76.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	-9.6	-2.0	14.9	24.3	38.5	56.2	63.0	54.9	43.5	27.6	6.5	-1.9	(6)
(7)		DBStd	27.11	17.23	16.33	13.85	11.22	9.98	9.56	8.44	6.68	6.85	9.85	15.55	18.36	(7)
(8)		HDD50	9454	1848	1456	1087	770	387	48	6	29	216	693	1306	1608	(8)
(9)		HDD65	14168	2313	1876	1552	1220	823	289	142	321	645	1158	1756	2073	(9)
(10)		CDD50	874	0	0	0	0	31	235	408	179	21	0	0	0	(10)
(11)		CDD65	115	0	0	0	0	2	26	80	7	0	0	0	0	(11)
(12)		CDH74	1199	0	0	0	0	34	243	857	65	0	0	0	0	(12)
(13)		CDH80	314	0	0	0	0	4	41	262	7	0	0	0	0	(13)
(14)	Wind	WSAvg	5.1	4.3	4.4	5.7	6.1	5.9	5.5	4.8	4.8	5.0	5.1	4.6	4.5	(14)
(15)	Precipitation	PrecAvg	30.1	1.9	1.7	2.2	2.4	2.3	3.2	3.0	3.1	2.4	3.2	2.7	2.1	(15)
(16)		PrecMax	37.1	3.3	2.8	4.4	4.1	3.9	5.0	8.4	6.7	4.1	5.3	4.1	3.7	(16)
(17)		PrecMin	25.3	0.7	0.5	0.4	0.4	0.9	1.7	0.5	1.6	0.9	0.9	1.1	1.1	(17)
(18)		PrecStd	2.7	0.7	0.6	0.9	0.8	0.8	0.8	1.6	1.0	0.9	0.9	0.7	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.4	31.9	42.0	50.9	78.7	84.5	89.1	80.6	66.8	52.1	38.0	30.6	(19)
(20)			MCWB	28.0	29.9	34.9	40.4	60.3	66.1	69.6	65.8	55.9	47.9	37.0	29.1	(20)
(21)		2%	DB	23.4	28.5	38.1	46.6	70.9	80.1	86.2	75.0	61.6	47.4	32.6	28.4	(21)
(22)			MCWB	22.2	27.2	32.2	38.1	56.4	64.4	67.6	62.7	53.5	44.9	31.7	27.3	(22)
(23)		5%	DB	18.8	25.0	35.4	42.9	62.9	76.4	82.7	71.1	57.5	43.7	30.0	25.4	(23)
(24)			MCWB	17.8	23.6	30.9	37.7	52.9	62.0	65.3	59.6	51.4	40.9	29.0	24.2	(24)
(25)		10%	DB	14.2	20.4	33.1	39.8	55.2	72.1	78.8	67.6	54.3	39.5	27.5	21.4	(25)
(26)			MCWB	13.3	19.2	29.8	35.3	46.3	60.0	63.6	58.3	49.8	37.4	26.7	20.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.3	30.0	35.7	42.7	61.5	69.3	71.9	67.6	57.1	48.1	36.7	29.6	(27)
(28)			MCDWB	29.6	31.2	40.1	46.2	76.5	80.7	85.1	76.9	64.3	51.2	37.6	30.7	(28)
(29)		2%	WB	22.4	27.3	33.0	39.6	57.2	66.1	69.6	64.0	54.5	45.4	31.8	27.3	(29)
(30)			MCDWB	23.3	28.5	36.6	44.7	69.3	77.3	81.4	71.9	60.3	47.6	32.6	28.3	(30)
(31)		5%	WB	17.8	23.8	31.5	37.7	52.8	63.5	67.2	61.6	52.2	41.4	29.2	24.4	(31)
(32)			MCDWB	18.8	25.0	35.0	42.4	62.8	73.4	78.1	69.1	56.2	43.4	29.9	25.4	(32)
(33)		10%	WB	13.4	19.2	29.8	35.9	47.8	61.1	65.2	59.3	50.3	37.5	26.6	20.5	(33)
(34)			MCDWB	14.2	20.5	33.0	39.9	54.5	70.1	75.7	65.4	53.9	39.0	27.6	21.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.6	16.7	18.7	18.5	16.5	17.5	18.7	16.0	12.1	8.9	14.4	14.1	(35)
(36)			MCDBR	18.6	15.6	16.0	19.0	26.5	22.8	24.7	23.4	17.5	11.8	13.4	10.3	(36)
(37)			MCWBR	18.6	14.0	11.6	13.1	14.5	10.2	9.2	12.4	10.4	9.1	13.4	9.6	(37)
(38)		5% WB	MCDWB	18.8	14.2	14.1	16.7	25.2	21.0	21.4	19.8	15.6	9.9	13.4	10.9	(38)
(39)			MCWBR	18.6	14.0	10.8	12.2	13.8	10.6	9.7	11.6	10.0	8.6	13.4	10.3	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.225	0.280	0.329	0.351	0.368	0.384	0.415	0.388	0.339	0.303	0.225	0.224	(41)	
(42)		taud	1.915	2.034	2.009	2.080	2.296	2.374	2.282	2.334	2.435	2.283	1.960	1.894	(42)	
(43)		Ebn at Noon	107	195	232	258	267	265	251	247	239	192	105	41	(43)	
		Edh at Noon	10	22	34	40	36	34	36	31	23	17	9	5		
(44)	All-Sky Solar Radiation	RadAvg	68	320	824	1393	1640	1637	1592	1083	632	265	83	26	(44)	
(45)		RadStd	4	25	47	143	146	116	181	114	66	31	14	2	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page