

KHALYASAVEY, Russian FederationWMO: **236560**Lat: **63.384N**Lon: **78.324E**Elev: **220**StdP: **14.58**Time Zone: **5.00 (E05)**Period: **90-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-49.7	-42.6	-55.3	0.2	-49.6	-48.9	0.3	-42.7	14.8	4.5	14.0	4.8	2.6	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	84.8	64.8	81.1	63.7	76.6	62.3	67.8	77.8	66.0	76.2	64.0	74.2	7.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.2	90.5	71.8	62.3	84.6	70.4	60.0	77.8	68.3	32.3	77.9	30.9	75.3	29.4	74.6	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 16.4	14.3	12.8	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	-51.8	68.8	5.6	3.2	-55.8	71.1	-59.1	72.9	-62.2	74.7	-66.2	77.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	-11.0	-4.0	12.9	24.8	35.9	58.2	63.7	55.7	43.7	26.5	3.2	-0.9
	DBStd	27.99	17.56	17.16	14.68	10.91	10.11	10.17	7.62	6.55	7.88	9.99	16.26	17.64
	HDD50	9757	1891	1513	1150	757	454	41	1	18	221	730	1403	1578
	HDD65	14411	2356	1933	1615	1207	904	250	121	297	638	1194	1853	2043
	CDD50	956	0	0	0	0	17	286	425	194	33	1	0	0
	CDD65	135	0	0	0	0	2	45	80	8	0	0	0	0
	CDH74	1447	0	0	0	0	21	463	903	60	0	0	0	0
	CDH80	421	0	0	0	0	5	134	275	7	0	0	0	0
	WSAvg	6.3	5.7	5.9	6.9	7.1	7.5	6.7	6.2	5.8	5.9	6.3	5.9	5.8
	PrecAvg	20.1	0.9	0.7	0.9	1.1	1.5	2.0	2.4	3.1	2.1	2.2	1.6	1.3
(15) Precipitation	PrecMax	25.7	1.7	1.4	1.9	2.3	2.8	4.3	5.7	5.4	3.4	4.2	3.1	2.6
	PrecMin	15.2	0.1	0.3	0.1	0.3	0.7	0.2	0.4	1.3	0.6	1.0	0.6	0.5
	PrecStd	3.2	0.4	0.3	0.5	0.5	0.5	0.9	1.3	1.0	0.7	0.9	0.6	0.5
	PrecStd	3.2	0.4	0.3	0.5	0.5	0.5	0.9	1.3	1.0	0.7	0.9	0.6	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	34.3	39.6	51.7	75.6	88.7	90.0	79.9	68.2	55.5	37.3	31.5
		MCWB	23.4	33.3	33.7	41.9	58.6	64.4	66.6	64.6	58.5	46.5	36.9	30.2
	2%	DB	19.9	27.3	35.7	46.9	65.9	83.9	86.4	75.1	63.4	45.6	32.5	28.7
		MCWB	19.0	26.0	31.4	38.5	53.7	64.4	64.2	62.2	55.5	42.6	31.3	27.4
	5%	DB	16.9	23.5	33.7	43.4	57.6	79.8	83.1	71.2	59.3	42.1	30.0	25.2
		MCWB	15.9	22.4	31.0	36.9	48.8	62.8	64.8	60.6	52.7	38.8	29.3	24.3
	10%	DB	13.4	19.0	31.6	40.1	51.6	74.6	79.4	67.4	55.9	37.8	27.6	21.5
		MCWB	12.4	17.7	29.2	35.2	44.6	61.5	63.1	58.6	50.9	35.4	26.9	20.4
	0.4%	WB	24.0	33.2	34.6	42.6	59.4	69.7	69.6	68.3	59.6	47.3	36.3	30.6
		MCDB	24.4	34.2	37.1	50.3	74.7	79.7	81.9	74.8	64.8	54.4	37.0	31.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	19.2	26.2	32.5	39.5	54.4	67.1	68.2	64.7	56.2	42.9	31.8	27.4
		MCDB	20.0	27.3	34.8	44.4	64.8	75.7	79.9	70.8	62.1	45.6	32.6	28.6
	5%	WB	16.0	22.4	31.0	37.6	49.5	65.2	66.8	61.9	53.9	39.2	29.3	24.1
		MCDB	16.9	23.3	33.3	42.7	56.8	75.9	78.1	68.9	58.7	41.1	30.0	25.0
	10%	WB	12.4	18.0	29.3	35.6	44.8	63.0	65.1	60.0	51.0	35.7	26.5	20.3
		MCDB	13.4	19.0	31.6	39.3	50.7	73.3	75.9	65.9	55.4	37.2	27.4	21.2
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	15.3	16.9	17.2	14.3	17.7	17.8	15.1	11.5	8.7	13.2	14.1
		MCDBR	17.1	14.0	15.4	19.0	25.3	24.0	24.9	21.4	16.5	9.9	9.6	14.6
		MCWBR	16.8	13.7	12.9	12.6	15.0	8.6	7.7	10.7	9.1	7.2	10.1	14.4
	5% WB	MCDBR	17.0	14.5	14.5	17.0	24.6	20.7	20.7	17.6	15.2	9.6	9.9	14.9
		MCWBR	16.8	14.3	12.8	12.3	15.8	9.6	8.1	10.5	9.2	7.7	9.8	14.8
(40) Clear-Sky Solar Irradiance	taub		0.232	0.282	0.332	0.353	0.365	0.381	0.430	0.402	0.349	0.304	0.226	0.226
	taud		1.912	2.019	1.983	2.042	2.255	2.397	2.232	2.294	2.399	2.214	1.940	1.879
	Ebn at Noon		108	195	231	257	268	266	246	242	235	189	108	44
	Edh at Noon		11	23	36	42	37	33	38	33	24	19	10	5
	RadAvg		73	329	850	1474	1709	1731	1574	1080	655	247	89	31
(45) All-Sky Solar Radiation	RadStd		6	25	46	146	152	129	165	133	95	36	19	2

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+2.57	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page