

NYAKSIMVOL, Russian Federation

WMO: 237240

Lat: 62.433N

Lon: 60.867E

Elev: 167

StdP: 14.61

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.0	-32.0	-41.6	0.5	-36.8	-36.7	0.7	-31.9	12.3	18.1	11.0	16.3	0.8	10	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	84.3	67.0	80.3	64.7	76.6	62.7	68.6	80.2	66.5	76.6	64.6	74.0	3.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	92.1	72.6	62.8	86.0	70.6	60.7	79.8	69.5	32.9	79.5	31.2	76.6	29.8	74.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.8	11.2	9.6	-43.2	88.1	5.0	2.8	-46.7	90.2	-49.6	91.8	-52.4	93.4	-56.0	95.5		
			-42.6	71.0	5.7	2.3	-46.7	72.7	-50.0	74.0	-53.2	75.3	-57.3	76.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	30.7	-2.9	2.1	18.9	32.5	45.4	57.5	62.5	56.1	46.0	32.8	12.9	2.5	(6)
(7)		DBStd	25.35	15.86	15.95	12.36	9.38	9.10	8.58	7.84	7.39	6.82	8.73	15.50	17.59	(7)
(8)		HDD50	8012	1641	1341	964	527	206	27	5	22	157	535	1114	1473	(8)
(9)		HDD65	12644	2106	1761	1429	975	610	254	145	292	571	999	1564	1938	(9)
(10)		CDD50	957	0	0	0	2	63	252	392	211	36	1	0	0	(10)
(11)		CDD65	114	0	0	0	0	2	29	67	16	0	0	0	0	(11)
(12)		CDH74	1386	0	0	0	0	69	367	772	173	5	0	0	0	(12)
(13)		CDH80	365	0	0	0	0	9	82	233	41	0	0	0	0	(13)
(14)	Wind	WSAvg	3.7	3.0	3.2	4.2	4.3	4.4	4.0	3.3	3.4	3.8	4.2	3.5	3.0	(14)
(15)	Precipitation	PrecAvg	20.7	1.1	0.8	0.9	1.4	1.7	2.7	2.8	2.9	2.2	1.7	1.5	1.1	(15)
(16)		PrecMax	28.3	2.3	1.6	2.2	3.8	5.0	9.4	7.6	5.9	5.9	3.2	3.1	2.6	(16)
(17)		PrecMin	13.3	0.3	0.0	0.0	0.2	0.1	0.3	0.5	0.7	0.7	0.3	0.0	0.3	(17)
(18)		PrecStd	3.6	0.5	0.4	0.6	0.8	0.9	1.8	1.5	1.2	1.0	0.8	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	36.9	48.1	65.5	81.2	86.9	89.3	85.2	73.5	57.5	42.6	36.9	(19)
(20)			MCWB	31.8	33.2	38.1	50.3	61.1	66.6	68.6	68.3	60.2	51.3	39.4	33.8	(20)
(21)		2%	DB	27.4	32.1	42.0	55.3	74.9	82.0	85.8	78.2	65.4	52.5	38.4	33.5	(21)
(22)			MCWB	25.9	29.4	34.8	44.3	57.3	64.5	67.9	64.3	56.3	46.4	35.7	30.9	(22)
(23)		5%	DB	24.0	28.6	39.0	50.5	69.5	78.3	82.3	74.1	60.8	48.1	35.0	30.3	(23)
(24)			MCWB	22.6	26.2	33.3	41.4	54.6	62.8	66.3	62.3	53.7	44.0	32.3	28.2	(24)
(25)		10%	DB	19.7	25.2	36.0	46.6	63.7	73.7	78.1	69.9	56.8	44.3	32.2	26.5	(25)
(26)			MCWB	18.1	23.1	31.5	39.1	51.5	60.9	64.5	60.5	51.6	41.0	30.2	24.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.0	33.4	39.3	51.3	62.8	68.4	71.7	69.6	61.2	51.9	39.9	33.9	(27)
(28)			MDCB	33.4	36.7	46.7	63.8	78.4	80.3	83.3	82.6	69.9	57.4	42.0	36.7	(28)
(29)		2%	WB	26.0	29.7	35.6	45.5	59.1	66.2	69.9	66.5	57.4	47.0	35.8	31.2	(29)
(30)			MDCB	27.0	32.1	40.5	53.4	71.3	78.4	82.2	74.9	63.8	51.3	38.3	33.3	(30)
(31)		5%	WB	22.6	26.3	33.6	42.2	55.8	64.4	67.9	64.1	54.8	44.1	32.7	28.2	(31)
(32)			MDCB	23.8	28.3	38.3	49.0	67.8	75.8	79.0	71.5	59.4	47.8	34.7	30.2	(32)
(33)		10%	WB	18.1	23.2	31.6	39.6	52.2	62.2	65.9	61.6	52.4	41.4	30.1	24.8	(33)
(34)			MDCB	19.6	25.0	36.0	45.8	62.8	71.9	75.4	68.4	56.2	44.0	32.1	26.4	(34)
(35)	Mean Daily Temperature Range	MDBR	14.9	18.4	19.9	17.7	20.5	19.9	19.6	18.2	14.5	11.5	12.2	14.1	(35)	
(36)		5% DB	MCDBR	13.0	14.8	18.5	23.6	31.3	26.5	26.2	25.5	21.3	16.5	9.3	12.1	(36)
(37)			MCWBR	12.4	12.4	13.3	14.9	16.7	12.2	10.7	12.4	13.2	11.7	8.0	11.2	(37)
(38)		5% WB	MCDBR	12.9	14.0	16.3	21.2	27.5	23.7	23.5	22.0	18.9	15.3	9.4	12.0	(38)
(39)			MCWBR	12.4	11.9	12.1	14.4	15.4	11.7	10.6	11.8	12.6	11.4	8.5	11.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.240	0.290	0.331	0.365	0.368	0.378	0.415	0.393	0.345	0.310	0.249	0.228	(40)	
(41)		taud	1.976	2.054	2.054	2.138	2.372	2.410	2.306	2.342	2.450	2.368	2.060	1.928	(41)	
(42)		Ebn at Noon	126	201	237	257	269	268	252	248	241	202	122	66	(42)	
(43)		Edh at Noon	12	23	34	38	33	33	36	32	23	17	10	7	(43)	
(44)	All-Sky Solar Radiation	RadAvg	77	313	728	1175	1548	1646	1674	1172	651	308	100	36	(44)	
(45)		RadStd	6	30	70	142	139	119	140	109	111	32	14	2	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page