

NYAKSIMVOL, Russian Federation

WMO: 237240

Lat: 62.433N

Lon: 60.867E

Elev: 51

StdP: 100.72

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -38.3	(c) -35.6	(d) -40.9	(e) 0.1	(f) -38.2	(g) -38.2	(h) 0.1	(i) -35.5	(j) 5.5	(k) -7.7	(l) 4.9	(m) -8.7	(n) 0.3	(o) 10	(p) 0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	29.1	19.4	26.9	18.2	24.8	17.1	20.4	26.8	19.2	24.8	18.1	23.4	1.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.2	22.5	17.1	12.3	21.4	16.0	11.4	20.8	58.7	26.4	54.7	24.8	51.4	23.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.7	(b) 5.0	(c) 4.3	(e) -41.7	(f) 31.2	(g) 2.8	(h) 1.6	(i) -43.7	(j) 32.3	(k) -45.3	(l) 33.2	(m) -46.9	(n) 34.1	(o) -48.9	(p) 35.3		
(a) 5.7	(b) 5.0	(c) 4.3	(e) -41.4	(f) 21.7	(g) 3.1	(h) 1.3	(i) -43.7	(j) 22.6	(k) -45.6	(l) 23.3	(m) -47.3	(n) 24.0	(o) -49.6	(p) 25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.7	-19.4	-16.6	-7.3	0.3	7.4	14.2	16.9	13.4	7.8	0.4	-10.6	-16.4
	DBStd	14.08	8.81	8.86	6.87	5.21	5.06	4.77	4.36	4.11	3.79	4.85	8.61	9.77
	HDD10.0	4451	912	745	536	293	114	15	3	12	87	297	619	818
	HDD18.3	7024	1170	978	794	542	339	141	81	162	317	555	869	1077
	CDD10.0	532	0	0	0	1	35	140	218	117	20	1	0	0
	CDD18.3	63	0	0	0	0	1	16	37	9	0	0	0	0
	CDH23.3	770	0	0	0	0	38	204	429	96	3	0	0	0
	CDH26.7	203	0	0	0	0	5	46	129	23	0	0	0	0
Wind	WSAvg	1.7	1.4	1.4	1.9	1.9	2.0	1.8	1.5	1.5	1.7	1.9	1.6	1.4
Precipitation	PrecAvg	527	28	20	23	36	42	68	72	74	57	44	37	29
	PrecMax	719	59	40	56	96	128	239	192	151	149	82	80	67
	PrecMin	339	7	0	1	4	3	8	13	17	17	7	1	8
	PrecStd	91	12	10	15	20	24	46	39	31	25	20	15	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.7	2.7	8.9	18.6	27.3	30.5	31.8	29.5	23.1	14.2	5.9	2.7
		MCWB	-0.1	0.7	3.4	10.2	16.2	19.2	20.3	20.2	15.7	10.7	4.1	1.0
	2%	DB	-2.6	0.1	5.6	12.9	23.8	27.8	29.9	25.7	18.6	11.4	3.5	0.8
		MCWB	-3.4	-1.5	1.6	6.8	14.0	18.0	19.9	17.9	13.5	8.0	2.0	-0.6
	5%	DB	-4.5	-1.9	3.9	10.3	20.8	25.7	27.9	23.4	16.0	8.9	1.6	-1.0
		MCWB	-5.2	-3.2	0.7	5.2	12.6	17.1	19.1	16.8	12.0	6.7	0.2	-2.1
	10%	DB	-6.9	-3.8	2.2	8.1	17.6	23.2	25.6	21.0	13.8	6.8	0.1	-3.1
		MCWB	-7.7	-5.0	-0.3	3.9	10.8	16.1	18.0	15.8	10.9	5.0	-1.0	-4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.0	0.8	4.1	10.7	17.1	20.2	22.0	20.9	16.2	11.1	4.4	1.1
		MCDB	0.8	2.6	8.2	17.7	25.8	26.9	28.5	28.1	21.1	14.1	5.5	2.6
	2%	WB	-3.3	-1.3	2.0	7.5	15.1	19.0	21.0	19.2	14.1	8.4	2.1	-0.4
		MCDB	-2.8	0.1	4.7	11.9	21.8	25.8	27.9	23.8	17.7	10.7	3.5	0.7
	5%	WB	-5.2	-3.2	0.9	5.6	13.2	18.0	19.9	17.8	12.7	6.7	0.4	-2.1
		MCDB	-4.5	-2.0	3.5	9.4	19.9	24.4	26.1	22.0	15.2	8.8	1.5	-1.0
	10%	WB	-7.7	-4.9	-0.2	4.2	11.2	16.8	18.8	16.4	11.3	5.2	-1.1	-4.0
		MCDB	-6.9	-3.9	2.2	7.6	17.1	22.2	24.1	20.2	13.4	6.7	0.1	-3.1
Mean Daily Temperature Range	5% DB	MDBR	8.3	10.2	11.1	9.9	11.4	11.1	10.9	10.1	8.1	6.4	6.8	7.8
		MCDBR	7.2	8.2	10.3	13.1	17.4	14.7	14.6	14.2	11.8	9.2	5.2	6.7
		MCWBR	6.9	6.9	7.4	8.3	9.3	6.8	6.0	6.9	7.3	6.5	4.4	6.2
	5% WB	MCDBR	7.2	7.8	9.1	11.8	15.3	13.1	13.0	12.2	10.5	8.5	5.2	6.7
		MCWBR	6.9	6.6	6.7	8.0	8.6	6.5	5.9	6.5	7.0	6.3	4.7	6.3
Clear-Sky Solar Irradiance	taub	0.240	0.290	0.331	0.365	0.368	0.378	0.415	0.393	0.345	0.310	0.249	0.228	
	taud	1.976	2.054	2.054	2.138	2.372	2.410	2.306	2.342	2.450	2.368	2.060	1.928	
	Ebn at Noon	396	633	748	810	849	846	796	781	759	638	385	209	
	Edh at Noon	37	73	107	121	105	104	113	100	74	54	33	21	
All-Sky Solar Radiation	RadAvg	0.24	0.99	2.29	3.70	4.88	5.19	5.28	3.69	2.05	0.97	0.31	0.11	
	RadStd	0.02	0.09	0.22	0.45	0.44	0.37	0.44	0.34	0.35	0.10	0.04	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page