

GAJNY, Russian Federation

WMO: 239090

Lat: 60.2875N

Lon: 54.3342E

Elev: 649

StdP: 14.35

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.5	-19.5	-30.1	1.0	-25.2	-24.1	1.5	-19.4	17.8	17.5	16.5	17.3	4.5	250	0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	83.1	67.5	79.6	65.4	76.0	63.2	69.2	80.0	67.3	76.6	65.3	73.5	6.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.4	96.1	74.2	63.6	90.3	72.1	62.0	85.0	70.3	33.7	80.5	32.1	76.9	30.6	73.6	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	15.2	13.8	DB	-30.6	87.6	7.0	2.3	-35.6	89.3	-39.7	90.7	-43.7	92.0	-48.8	93.6	(4)
(5)			WB	-30.7	71.5	7.0	2.0	-35.8	72.9	-39.9	74.1	-43.8	75.2	-48.9	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.0	6.8	9.3	23.1	36.5	49.0	58.8	63.8	57.7	47.9	35.2	20.1	10.6	(6)	
	DBStd	22.41	13.77	13.60	9.06	9.45	10.26	8.36	8.04	7.92	7.83	8.40	12.20	14.57	(7)	
	HDD50	6632	1341	1139	834	414	150	19	5	16	130	466	898	1220	(8)	
	HDD65	11088	1806	1559	1299	855	504	220	121	252	514	925	1348	1685	(9)	
	CDD50	1174	0	0	0	9	119	285	432	256	67	6	0	0	(10)	
	CDD65	154	0	0	0	0	7	35	83	27	2	0	0	0	(11)	
	CDH74	1189	0	0	0	1	64	263	666	190	5	0	0	0	(12)	
	CDH80	259	0	0	0	0	7	48	156	48	0	0	0	0	(13)	
(14) Wind	WSAvg	7.2	7.2	7.4	7.8	7.6	7.5	7.1	6.2	6.4	7.2	7.5	7.4	7.2	(14)	
(15) Precipitation	PrecAvg	26.0	1.7	1.1	1.6	1.5	2.3	3.1	2.8	3.1	2.4	2.5	2.1	1.7	(15)	
	PrecMax	33.4	2.7	2.8	3.4	3.1	6.3	6.9	7.6	5.8	3.6	4.5	4.1	3.0	(16)	
	PrecMin	20.5	0.4	0.1	0.4	0.0	0.8	0.4	0.6	0.4	0.6	1.2	0.5	0.8	(17)	
	PrecStd	3.0	0.6	0.6	0.7	0.7	1.3	1.5	1.5	1.3	0.8	0.8	0.8	0.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.5	34.3	46.9	68.2	80.2	84.9	87.1	85.6	73.4	61.6	45.7	36.2	(19)	
		MCWB	31.8	32.0	37.9	52.0	60.0	67.0	68.8	68.9	60.0	51.0	44.2	35.7	(20)	
	2%	DB	30.6	32.4	41.0	59.7	75.2	80.6	84.3	79.1	66.4	54.6	39.0	33.4	(21)	
		MCWB	29.9	31.2	34.2	47.1	57.3	64.8	68.7	66.2	58.0	48.5	38.2	32.7	(22)	
	5%	DB	28.1	30.4	37.5	54.1	70.7	76.6	81.2	74.2	62.4	50.4	35.4	31.7	(23)	
		MCWB	27.5	29.1	32.3	43.5	55.0	62.8	66.9	63.6	55.3	46.7	34.5	31.1	(24)	
	10%	DB	24.8	27.5	34.6	49.8	66.0	72.8	77.7	70.2	59.0	46.7	33.3	28.7	(25)	
		MCWB	24.1	26.2	31.3	41.2	53.2	60.7	65.3	61.7	53.7	44.5	32.6	27.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.1	33.1	38.7	52.6	63.8	70.0	71.8	70.5	62.3	53.5	43.6	35.8	(27)	
		MCDB	32.3	33.8	44.3	64.8	75.4	80.8	83.0	82.3	70.5	57.8	45.0	36.0	(28)	
	2%	WB	30.1	31.5	35.6	48.6	59.9	67.0	69.9	67.6	59.1	49.7	38.3	33.0	(29)	
		MCDB	30.7	32.4	39.2	57.6	70.1	76.6	81.2	77.5	64.6	53.5	38.9	33.3	(30)	
	5%	WB	27.5	29.0	33.5	45.2	57.2	64.9	68.3	65.0	56.6	47.1	34.8	31.0	(31)	
		MCDB	28.1	30.2	36.1	52.1	67.1	73.8	78.0	72.0	60.8	50.0	35.3	31.5	(32)	
	10%	WB	24.1	26.3	31.7	42.2	54.5	62.6	66.6	62.7	54.5	44.6	32.8	28.0	(33)	
		MCDB	24.8	27.6	34.3	48.8	64.4	70.5	75.4	69.0	58.1	46.6	33.3	28.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	11.5	13.2	14.6	17.3	16.6	17.0	14.6	11.9	7.9	7.7	9.3	(35)	
		MCDBR	10.0	9.8	14.9	20.9	23.0	20.8	21.2	19.6	16.5	13.0	7.0	6.7	(36)	
	5% WB	MCWBR	10.1	9.5	10.2	11.9	11.0	9.2	8.9	8.8	9.1	8.5	7.0	6.9	(37)	
		MCWBR	10.2	9.9	11.8	18.5	19.8	18.5	19.1	17.7	14.0	11.9	6.9	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.268	0.303	0.347	0.374	0.371	0.368	0.399	0.392	0.355	0.325	0.282	0.250	(40)	
		taud	1.986	2.030	1.998	2.125	2.377	2.429	2.343	2.344	2.413	2.326	2.088	1.938	(41)	
	Ebn at Noon		142	208	237	258	271	274	260	252	243	207	139	98	(42)	
		Edh at Noon	15	26	38	40	34	33	35	32	25	20	14	10	(43)	
(44) All-Sky Solar Radiation	RadAvg		114	355	737	1148	1525	1648	1668	1193	682	283	103	59	(44)	
	RadStd		15	77	101	167	170	130	151	128	78	28	22	10	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-493	-589	N/A	N/A	

Nomenclature: See separate page