

OLENYOK, Russian Federation

WMO: 241250

Lat: 68.500N

Lon: 112.433E

Elev: 220

StdP: 98.71

Time Zone: 9.00 (E09)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-51.6	-49.3	-53.0	0.0	-51.4	-50.7	0.0	-49.5	6.5	-21.7	5.6	-25.2	1.2	110	0.827

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	26.9	16.4	24.5	15.3	22.2	14.4	17.7	24.2	16.4	22.5	15.2	21.1	3.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	11.1	19.9	13.8	10.1	19.1	12.4	9.2	17.9	50.8	24.2	47.0	23.1	43.5	21.0	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.6	5.8	DB	-51.6	29.4	2.8	2.5	-53.6	31.2	-55.2	32.7	-56.8	34.0	-58.8	35.8	(4)
(5)			WB	-52.4	19.4	3.1	1.2	-54.7	20.3	-56.5	21.0	-58.3	21.7	-60.5	22.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.8	-35.5	-33.3	-22.0	-10.0	0.2	11.3	15.5	11.3	2.8	-11.0	-26.8	-33.4	(6)
(7)		DBStd	19.58	9.10	8.60	8.13	6.87	6.24	5.82	4.78	4.10	4.21	7.53	8.60	9.59	(7)
(8)		HDD10.0	7935	1410	1212	993	599	308	53	8	33	219	651	1104	1345	(8)
(9)		HDD18.3	10662	1668	1445	1251	849	561	222	113	220	467	909	1354	1603	(9)
(10)		CDD10.0	352	0	0	0	0	6	91	179	73	2	0	0	0	(10)
(11)		CDD18.3	38	0	0	0	0	0	9	26	3	0	0	0	0	(11)
(12)		CDH23.3	314	0	0	0	0	0	83	208	22	0	0	0	0	(12)
(13)		CDH26.7	68	0	0	0	0	0	21	44	4	0	0	0	0	(13)
(14)	Wind	WSAvg	2.4	1.5	1.6	2.1	3.1	3.4	3.3	2.8	2.7	2.7	2.5	1.9	1.7	(14)
(15)	Precipitation	PrecAvg	293	12	10	11	14	23	40	51	43	32	27	19	13	(15)
(16)		PrecMax	416	28	19	27	35	65	120	130	133	70	49	41	30	(16)
(17)		PrecMin	163	3	1	1	2	6	8	2	9	4	11	6	6	(17)
(18)		PrecStd	60	6	4	5	8	14	23	29	23	15	9	7	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.5	-7.5	-0.4	9.0	21.3	29.3	30.1	26.5	16.1	4.3	-3.3	-8.3	(19)
(20)			MCWB	-10.9	-8.1	-2.5	3.3	11.2	17.2	17.9	17.8	10.9	2.5	-3.8	-8.8	(20)
(21)		2%	DB	-14.9	-13.7	-3.8	5.8	15.6	25.7	27.9	22.9	12.9	1.9	-7.7	-13.0	(21)
(22)			MCWB	-15.2	-14.1	-5.3	1.3	8.1	15.5	16.7	14.9	8.8	0.6	-8.1	-13.5	(22)
(23)		5%	DB	-18.5	-17.7	-7.1	2.8	11.9	23.2	25.7	20.5	10.7	0.2	-11.4	-15.6	(23)
(24)			MCWB	-18.7	-18.1	-8.3	-0.2	6.2	14.0	16.0	14.1	7.3	-0.7	-11.8	-15.9	(24)
(25)		10%	DB	-22.3	-21.0	-10.0	0.2	8.9	20.5	23.5	18.3	8.7	-1.4	-14.7	-19.1	(25)
(26)			MCWB	-22.5	-21.2	-11.0	-2.1	4.3	12.7	15.2	12.7	5.9	-2.3	-15.0	-19.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.8	-8.0	-2.3	3.7	11.8	18.3	19.7	18.3	11.9	2.9	-3.6	-8.8	(27)
(28)			MCDB	-10.5	-7.3	0.0	8.4	19.4	26.7	26.5	24.4	14.4	4.1	-3.2	-8.4	(28)
(29)		2%	WB	-15.2	-14.1	-5.3	1.6	8.7	16.4	18.3	16.2	9.5	0.7	-8.0	-13.5	(29)
(30)			MCDB	-15.0	-13.8	-4.0	5.1	15.1	24.0	24.7	20.9	12.0	1.5	-7.7	-13.1	(30)
(31)		5%	WB	-18.7	-18.0	-8.3	0.0	6.5	15.1	17.1	14.8	7.6	-0.6	-11.8	-15.8	(31)
(32)			MCDB	-18.5	-17.6	-7.2	2.7	11.8	21.5	23.0	19.1	9.9	0.2	-11.4	-15.5	(32)
(33)		10%	WB	-22.4	-21.2	-11.0	-2.1	4.6	13.4	16.1	13.4	6.3	-2.3	-15.0	-19.4	(33)
(34)			MCDB	-22.2	-21.0	-10.0	0.1	8.4	19.4	22.1	17.5	8.5	-1.4	-14.7	-19.1	(34)
(35)	Mean Daily Temperature Range		MDBR	6.2	6.3	9.3	9.5	7.6	8.4	8.5	7.8	5.9	5.5	6.3	6.4	(35)
(36)		5% DB	MCDBR	8.6	9.4	9.4	10.0	10.2	11.5	11.8	11.6	9.3	6.0	8.5	8.3	(36)
(37)			MCWBR	8.5	9.3	8.3	7.3	5.9	5.7	4.8	5.9	5.7	5.3	8.4	8.2	(37)
(38)		5% WB	MCDBR	8.5	9.5	9.4	9.7	9.6	10.6	9.4	9.8	7.9	5.9	8.5	8.5	(38)
(39)			MCWBR	8.4	9.3	8.4	7.4	6.1	5.6	4.8	5.8	5.3	5.4	8.4	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.186	0.224	0.282	0.311	0.336	0.355	0.414	0.401	0.304	0.234	0.176	N/A	(40)	
(41)		taud	1.868	2.023	2.061	2.093	2.214	2.420	2.246	2.227	2.464	2.142	1.888	N/A	(41)	
(42)		Ebn at Noon	68	559	730	823	848	844	764	723	739	541	62	0	(42)	
(43)		Edh at Noon	7	47	87	114	114	97	112	102	61	40	6	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.03	0.55	2.16	4.20	5.51	5.55	4.95	3.36	1.77	0.63	0.09	0.00	(44)	
(45)		RadStd	0.00	0.04	0.12	0.24	0.38	0.40	0.36	0.42	0.20	0.07	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page