

KISLOKAN, Russian Federation

WMO: 246060

Lat: 63.590N

Lon: 103.950E

Elev: 691

StdP: 14.33

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-59.1	-54.9	-62.7	0.1	-59.4	-58.4	0.2	-54.3	14.0	3.3	12.2	1.5	0.2	260	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.0	85.0	63.7	80.9	61.7	77.1	60.5	65.7	79.6	63.9	77.0	61.9	74.3	5.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	81.2	70.1	58.5	75.1	68.6	56.6	70.1	67.3	31.0	79.3	29.6	76.6	28.2	74.6	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	10.9	9.4	-61.0	90.2	3.7	2.6	-63.6	92.0	-65.8	93.6	-67.9	95.0	-70.5	96.9		
(5)			-61.0	68.7	3.7	1.5	-63.6	69.8	-65.8	70.7	-67.9	71.6	-70.5	72.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	-29.9	-19.3	2.4	23.9	38.7	56.4	60.6	54.1	39.4	20.0	-12.5	-27.6		
	DBStd	34.70	15.69	15.22	16.35	11.64	8.26	7.20	6.02	6.98	7.76	13.76	19.48	17.04		
	HDD50	12628	2476	1939	1475	783	359	20	3	35	329	929	1875	2405		
	HDD65	17423	2941	2359	1940	1233	816	271	160	346	768	1394	2325	2870		
	CDD50	727	0	0	0	0	9	212	333	162	11	0	0	0		
	CDD65	46	0	0	0	0	0	13	25	8	0	0	0	0		
	CDH74	1320	0	0	0	0	5	452	690	172	1	0	0	0		
	CDH80	329	0	0	0	0	0	132	168	29	0	0	0	0		
(14) Wind	WSAvg	3.3	2.1	2.5	3.5	4.4	4.6	3.8	3.6	3.4	3.5	3.5	2.6	1.8		
(15) Precipitation	PrecAvg	14.1	0.5	0.4	0.4	0.7	1.0	1.9	2.3	2.8	1.4	1.1	0.9	0.6		
	PrecMax	19.9	0.9	1.0	0.9	2.0	2.1	3.7	5.9	8.3	3.0	2.0	1.6	1.3		
	PrecMin	8.5	0.2	0.1	0.1	0.2	0.4	0.2	0.5	0.4	0.4	0.3	0.4	0.2		
	PrecStd	2.7	0.2	0.2	0.2	0.4	0.4	0.9	1.5	1.4	0.7	0.4	0.3	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.5	21.7	43.2	56.8	74.8	90.9	88.1	83.6	71.1	49.7	34.5	25.5		
		MCWB	13.3	19.3	34.8	42.1	53.7	64.1	65.4	65.4	55.6	43.1	31.9	23.8		
	2%	DB	12.0	17.8	38.1	50.9	67.6	86.4	84.7	78.9	63.2	44.8	29.0	17.4		
		MCWB	10.5	15.5	31.6	39.1	49.1	62.7	64.3	61.9	51.7	40.0	27.3	16.2		
	5%	DB	4.9	13.6	32.2	46.4	60.3	81.5	81.1	74.4	57.7	40.6	23.2	6.7		
		MCWB	3.7	12.2	27.6	36.9	45.9	61.1	62.2	59.5	49.4	37.2	21.8	5.7		
	10%	DB	-3.3	6.7	27.8	42.3	55.7	77.0	77.6	70.2	53.8	36.9	17.1	-1.0		
		MCWB	-4.0	5.5	23.7	35.2	43.5	59.7	61.3	57.9	46.8	34.0	15.7	-1.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	19.5	35.6	42.7	54.0	66.8	68.5	67.0	57.7	44.0	32.3	23.4		
		MCDB	15.2	21.4	42.9	54.6	72.9	85.0	81.5	80.8	65.3	48.6	34.4	25.2		
	2%	WB	10.4	15.4	31.7	40.0	50.0	64.7	66.3	63.9	53.8	40.3	27.5	16.2		
		MCDB	12.5	17.1	38.2	49.2	66.6	81.0	79.2	74.9	60.2	44.2	29.0	17.3		
	5%	WB	3.9	12.1	27.7	37.6	47.0	62.7	64.6	61.1	50.4	37.4	21.6	6.0		
		MCDB	5.0	13.7	32.3	45.6	59.4	79.2	77.1	71.0	56.8	40.2	23.0	6.7		
	10%	WB	-4.0	5.6	23.8	35.5	44.1	60.5	62.9	59.0	47.6	34.1	15.9	-1.7		
		MCDB	-3.4	6.8	27.4	41.7	53.8	74.9	74.5	68.2	53.5	36.5	17.1	-1.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	23.9	30.7	24.7	21.0	26.5	27.0	24.5	19.9	16.1	17.9	15.7		
		MCDBR	23.3	19.8	27.9	27.0	32.3	36.5	35.9	33.7	29.7	17.6	17.7	24.0		
		MCWBR	21.9	18.5	22.1	17.2	17.9	16.4	17.5	18.1	18.9	13.1	16.5	23.4		
	5% WB	MCDBR	23.3	19.6	26.8	22.0	29.6	32.4	29.5	27.9	26.5	16.7	16.6	24.3		
		MCWBR	22.0	18.3	21.7	14.2	17.4	15.9	15.5	15.7	17.2	12.9	15.4	23.7		
(40) Clear-Sky Solar Irradiance	taub		0.217	0.268	0.301	0.334	0.351	0.377	0.448	0.417	0.330	0.277	0.205	0.198		
	taud		1.895	2.021	2.057	2.074	2.271	2.399	2.160	2.217	2.445	2.246	1.919	1.870		
	Ebn at Noon		111	201	245	264	272	267	240	236	242	202	115	50		
	Edh at Noon		10	22	32	40	36	33	41	35	23	17	9	5		
(44) All-Sky Solar Radiation	RadAvg		73	347	874	1496	1714	1785	1609	1129	695	312	114	30		
	RadStd		5	22	49	88	138	183	136	85	75	37	10	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	+1.87	N/A	N/A	+3.17	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page