

NYURBA, Russian Federation

WMO: 246390

Lat: 63.300N

Lon: 118.353E

Elev: 391

StdP: 14.49

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-59.3	-53.9	-62.1	0.1	-59.0	-57.4	0.2	-53.9	17.0	-5.0	14.4	-6.3	1.0	230	0.722

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	85.1	66.2	81.1	64.2	77.3	62.4	68.3	80.7	66.2	77.5	64.1	74.4	6.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.0	90.4	73.2	61.8	83.6	71.2	59.7	77.5	69.3	32.9	80.8	31.2	77.6	29.6	74.5	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	13.5	11.5	-60.0	90.9	6.1	3.3	-64.4	93.3	-68.0	95.2	-71.5	97.1	-75.9	99.5		
(5)			-60.2	72.2	6.1	2.7	-64.6	74.1	-68.1	75.6	-71.6	77.1	-76.0	79.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	-29.0	-21.5	-0.9	23.2	42.8	59.0	63.5	56.9	41.5	19.9	-11.5	-28.3
	DBStd	35.85	15.61	14.69	15.11	11.29	8.41	8.34	6.99	6.70	7.90	12.61	16.66	16.23
	HDD50	12608	2450	2002	1578	803	254	20	2	18	275	934	1844	2428
	HDD65	17197	2915	2422	2043	1253	689	213	112	260	704	1399	2294	2893
	CDD50	996	0	0	0	0	31	290	421	233	21	0	0	0
	CDD65	108	0	0	0	0	0	32	66	10	0	0	0	0
	CDH74	1554	0	0	0	0	12	498	861	181	2	0	0	0
	CDH80	434	0	0	0	0	0	133	267	34	0	0	0	0
	WSAvg	4.9	4.1	4.1	4.3	5.5	6.5	5.6	4.8	4.6	5.2	5.4	4.4	4.0
	PrecAvg	11.3	0.5	0.4	0.3	0.4	1.0	1.7	1.7	2.0	1.2	1.0	0.7	0.6
(15) Precipitation	PrecMax	14.9	0.9	1.0	0.8	1.2	2.2	3.9	3.8	3.7	2.7	1.7	1.5	1.5
	PrecMin	7.8	0.2	0.1	0.1	0.0	0.1	0.6	0.3	0.2	0.1	0.3	0.2	0.1
	PrecStd	1.8	0.2	0.2	0.2	0.3	0.5	0.8	0.8	0.9	0.6	0.4	0.3	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	22.4	40.6	56.4	75.6	88.4	91.0	84.6	70.3	45.7	32.7	21.2
		MCWB	15.0	21.1	33.3	43.9	55.4	65.5	68.3	65.6	55.8	39.9	30.8	20.7
	2%	DB	6.7	13.7	33.2	49.7	69.1	83.9	86.5	78.8	64.5	41.4	28.3	9.8
		MCWB	5.8	12.3	28.4	39.7	52.2	64.6	67.4	62.7	52.7	37.3	27.3	9.1
	5%	DB	0.3	7.1	27.8	44.6	63.8	80.0	82.8	74.9	59.1	38.1	22.0	2.2
		MCWB	-0.5	6.2	24.5	36.6	49.5	62.5	65.9	61.0	50.2	34.9	21.2	1.5
	10%	DB	-6.1	0.7	23.1	40.4	59.0	75.8	78.9	71.1	54.6	35.0	14.4	-4.9
		MCWB	-6.6	-0.1	20.3	33.8	47.1	60.7	64.3	59.8	47.7	32.5	13.4	-5.4
	0.4%	WB	15.0	21.3	34.1	44.5	57.1	70.6	71.9	68.3	57.6	41.2	31.4	20.6
		MCDB	15.7	22.1	40.2	55.4	72.1	81.7	83.9	81.0	67.4	44.3	32.4	21.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	6.0	12.5	28.6	40.3	53.0	66.7	69.3	65.2	54.5	37.8	26.9	9.1
		MCDB	6.8	13.7	33.0	48.8	66.4	79.0	81.9	74.6	61.8	40.7	28.5	9.6
	5%	WB	-0.3	6.1	24.4	37.1	50.4	64.3	67.4	62.9	51.2	35.3	21.1	1.6
		MCDB	0.3	6.9	27.7	43.6	62.8	76.6	79.7	71.8	57.2	37.5	22.1	2.1
	10%	WB	-6.6	0.0	20.3	34.4	47.6	62.0	65.5	60.8	48.6	32.7	13.6	-5.3
		MCDB	-6.2	0.6	23.0	39.9	58.0	73.3	76.3	69.3	53.9	35.0	14.5	-4.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	18.6	26.5	23.3	18.9	21.8	21.3	20.9	17.0	13.0	14.8	13.0
		MCDBR	16.9	20.8	23.3	24.6	27.8	29.2	29.3	29.1	25.0	13.6	16.0	18.4
		MCWBR	16.6	20.2	19.5	16.5	14.9	12.9	13.1	14.8	14.2	10.4	15.7	18.1
		MCDBR	17.1	20.8	22.5	21.8	25.6	25.5	25.2	23.4	21.5	11.9	16.1	18.3
	5% WB	MCWBR	16.8	20.2	18.9	14.9	14.6	12.8	12.6	13.1	13.0	9.8	15.9	18.0
(40) Clear-Sky Solar Irradiance	taub		0.212	0.257	0.293	0.332	0.365	0.410	0.472	0.448	0.326	0.277	0.207	0.191
	taud		1.917	2.063	2.089	2.116	2.310	2.285	2.081	2.101	2.463	2.329	1.951	1.880
	Ebn at Noon		122	212	251	266	268	256	233	225	246	209	122	61
	Edh at Noon		10	21	31	39	35	37	44	40	23	16	10	5
(44) All-Sky Solar Radiation	RadAvg		81	376	928	1567	1727	1811	1673	1250	770	338	123	34
	RadStd		5	18	31	68	95	125	92	96	86	30	12	1

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			+0.99	N/A	N/A	N/A	N/A	N/A	-360	N/A	N/A
(47) Regional (4 neighbors)			+1.30	N/A	N/A	N/A	N/A	N/A	-409	-477	N/A

Nomenclature: See separate page