

BATAMAY, Russian Federation

WMO: 246560

Lat: 63.522N

Lon: 129.422E

Elev: 260

StdP: 14.56

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-59.8	-56.5	-63.6	0.1	-59.6	-60.3	0.1	-56.1	13.6	-28.6	12.1	-29.1	0.8	40	0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	81.3	66.0	78.0	64.2	74.9	62.9	68.3	77.5	66.4	75.0	64.4	72.8	5.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	93.7	73.2	62.9	86.6	71.1	60.9	80.5	69.1	32.9	77.4	31.3	75.3	29.7	72.9	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	14.4	12.0	-62.5	86.4	4.3	2.5	-65.6	88.2	-68.1	89.6	-70.5	91.0	-73.6	92.8		
			-62.2	72.1	4.1	2.9	-65.2	74.2	-67.6	76.0	-69.9	77.6	-72.9	79.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	-39.9	-33.0	-8.3	20.1	42.1	57.8	63.5	57.0	41.1	15.8	-20.1	-38.7
	DBStd	39.38	10.09	10.60	14.15	11.75	7.89	6.96	6.06	6.50	7.38	12.65	14.88	10.84
	HDD50	14294	2786	2324	1807	896	266	15	0	13	277	1059	2102	2749
	HDD65	18919	3251	2744	2272	1346	709	230	102	259	716	1524	2552	3214
	CDD50	933	0	0	0	0	22	250	418	231	12	0	0	0
	CDD65	82	0	0	0	0	0	15	55	12	0	0	0	0
	CDH74	857	0	0	0	0	1	187	557	112	0	0	0	0
	CDH80	145	0	0	0	0	0	18	112	15	0	0	0	0
Wind	WSAvg	4.7	3.1	3.2	4.5	5.6	6.4	5.5	4.9	5.1	5.4	5.2	4.1	3.1
Precipitation	PrecAvg	12.4	0.4	0.3	0.4	0.4	1.2	1.5	2.1	1.8	1.8	1.5	0.7	0.4
	PrecMax	16.6	1.0	0.7	1.3	1.0	2.7	3.0	4.8	3.6	3.8	2.8	1.5	1.1
	PrecMin	7.6	0.1	0.0	0.0	0.0	0.0	0.4	0.3	0.2	0.1	0.2	0.2	0.1
	PrecStd	2.4	0.2	0.2	0.3	0.2	0.7	0.7	1.2	0.9	0.9	0.7	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.2	2.8	32.4	50.1	69.4	82.6	86.6	81.8	67.0	41.8	20.1	-6.4
		MCWB	-6.8	2.2	27.4	40.2	52.7	63.9	68.3	67.2	55.5	37.2	18.1	-6.9
	2%	DB	-14.2	-3.5	26.0	44.9	64.3	78.8	83.3	76.9	61.2	36.9	13.3	-12.7
		MCWB	-14.6	-4.2	22.1	36.4	50.4	62.4	67.1	63.5	51.9	33.0	12.3	-13.1
	5%	DB	-19.9	-9.5	20.3	41.0	60.2	75.8	80.0	73.3	57.4	33.9	7.5	-17.5
		MCWB	-20.2	-10.1	17.2	34.1	48.2	61.2	66.1	62.4	50.4	31.1	6.7	-17.9
	10%	DB	-24.7	-15.5	14.7	37.6	56.3	72.6	76.7	69.7	53.5	31.3	3.0	-22.2
		MCWB	-25.0	-16.0	12.4	31.7	45.8	59.6	64.8	60.6	47.7	29.1	2.2	-22.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.8	2.2	27.7	40.5	54.4	68.0	72.0	69.2	56.8	37.2	18.3	-7.0
		MCDB	-6.2	2.9	31.8	49.5	66.5	77.8	81.8	78.3	62.6	40.3	19.5	-6.6
	2%	WB	-14.7	-4.1	22.2	37.4	51.6	65.0	69.5	66.2	54.0	33.7	12.4	-13.1
		MCDB	-14.4	-3.5	25.9	44.2	62.6	75.1	79.0	74.2	59.6	35.7	13.3	-12.7
	5%	WB	-20.2	-10.1	17.3	34.7	49.1	63.1	67.8	63.7	51.2	31.4	6.7	-17.9
		MCDB	-20.0	-9.6	20.1	39.9	58.4	73.1	76.6	70.3	56.2	33.7	7.4	-17.5
	10%	WB	-25.0	-15.9	12.3	32.3	46.6	60.9	66.1	61.6	48.5	29.0	2.2	-22.5
		MCDB	-24.8	-15.6	14.8	37.3	54.8	70.2	74.6	68.2	52.7	31.3	3.0	-22.3
Mean Daily Temperature Range	5% DB	MDBR	13.1	18.8	25.9	23.9	17.6	19.8	19.8	19.5	15.9	12.7	14.1	11.4
		MCDBR	18.1	21.0	26.4	21.3	23.5	26.9	26.1	25.3	23.2	13.2	14.2	15.9
		MCWBR	17.8	20.2	22.9	15.2	13.1	13.2	13.0	14.1	15.0	10.4	13.6	15.6
	5% WB	MCDBR	18.1	20.8	25.6	18.5	21.9	23.0	22.2	21.4	20.4	12.0	14.4	16.0
		MCWBR	17.7	20.2	22.2	13.5	12.6	12.8	12.7	13.0	13.9	9.8	13.9	15.7
Clear-Sky Solar Irradiance	taub	0.195	0.248	0.295	0.350	0.411	0.407	0.489	0.462	0.347	0.272	0.197	0.179	
	taud	1.930	2.086	2.073	2.058	2.148	2.294	2.040	2.069	2.377	2.284	1.940	1.889	
	Ebn at Noon	130	216	249	259	252	257	227	220	234	207	123	63	
	Edh at Noon	10	21	32	41	41	36	46	41	24	17	9	4	
All-Sky Solar Radiation	RadAvg	77	367	936	1592	1709	1915	1715	1297	775	325	120	31	
	RadStd	4	14	36	62	154	109	112	105	106	30	8	1	

Historical Trends

DBAvg	Heating		Cooling			Degree-Days				
	99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+1.24	+2.66	+2.61	N/A	N/A	N/A	-430	-490	+144	N/A
Regional (5 neighbors)	+1.19	N/A	N/A	N/A	N/A	N/A	-410	-423	N/A	N/A

Nomenclature: See separate page