

BATAMAY, Russian Federation

WMO: 246560

Lat: 63.522N

Lon: 129.422E

Elev: 79

StdP: 100.38

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -51.0	(c) -49.2	(d) -53.1	(e) 0.0	(f) -50.9	(g) -51.3	(h) 0.0	(i) -48.9	(j) 6.1	(k) -33.7	(l) 5.4	(m) -34.0	(n) 0.4	(o) 40	(p) 0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.0	(c) 27.4	(d) 18.9	(e) 25.5	(f) 17.9	(g) 23.9	(h) 17.2	(i) 20.2	(j) 25.3	(k) 19.1	(l) 23.9	(m) 18.0	(n) 22.7	(o) 2.5	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.4	22.9	17.2	12.4	21.7	16.0	11.5	20.6	58.6	25.2	54.9	24.0	51.3	22.7	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.8	(b) 6.4	(c) 5.4	(e) -52.5	(f) 30.2	(g) 2.4	(h) 1.4	(i) -54.2	(j) 31.2	(k) -55.6	(l) 32.0	(m) -56.9	(n) 32.8	(o) -58.7	(p) 33.8		
(a) 7.8	(b) 6.4	(c) 5.4	(e) -52.4	(f) 22.3	(g) 2.3	(h) 1.6	(i) -54.0	(j) 23.5	(k) -55.3	(l) 24.4	(m) -56.6	(n) 25.3	(o) -58.3	(p) 26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.3	-39.9	-36.1	-22.4	-6.6	5.6	14.4	17.5	13.9	5.1	-9.0	-28.9	-39.3	(6)
(7)		DBStd	21.88	5.61	5.89	7.86	6.53	4.38	3.87	3.37	3.61	4.10	7.03	8.27	6.02	(7)
(8)		HDD10.0	7941	1548	1291	1004	498	148	8	0	7	154	588	1168	1527	(8)
(9)		HDD18.3	10511	1806	1524	1262	748	394	128	57	144	398	847	1418	1786	(9)
(10)		CDD10.0	518	0	0	0	0	12	139	232	128	7	0	0	0	(10)
(11)		CDD18.3	46	0	0	0	0	0	8	31	7	0	0	0	0	(11)
(12)		CDH23.3	476	0	0	0	0	1	104	309	62	0	0	0	0	(12)
(13)		CDH26.7	81	0	0	0	0	0	10	62	8	0	0	0	0	(13)
(14)	Wind	WSAvg	2.1	1.4	1.4	2.0	2.5	2.9	2.5	2.2	2.3	2.4	2.3	1.9	1.4	(14)
(15)	Precipitation	PrecAvg	316	9	8	10	11	30	38	54	45	38	18	10	(15)	
(16)		PrecMax	422	25	19	32	26	68	75	123	92	96	71	38	29	(16)
(17)		PrecMin	194	2	1	1	1	0	10	8	5	2	4	4	3	(17)
(18)		PrecStd	62	6	5	8	6	19	17	31	23	24	17	10	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-21.2	-16.2	0.2	10.1	20.8	28.1	30.4	27.7	19.5	5.4	-6.6	-21.3	(19)
(20)			MCWB	-21.6	-16.6	-2.5	4.5	11.5	17.7	20.1	19.5	13.1	2.9	-7.7	-21.6	(20)
(21)		2%	DB	-25.7	-19.7	-3.3	7.2	18.0	26.0	28.5	24.9	16.2	2.7	-10.4	-24.8	(21)
(22)			MCWB	-25.9	-20.1	-5.5	2.5	10.2	16.9	19.5	17.5	11.1	0.5	-10.9	-25.1	(22)
(23)		5%	DB	-28.8	-23.1	-6.5	5.0	15.7	24.4	26.6	22.9	14.1	1.0	-13.6	-27.5	(23)
(24)			MCWB	-29.0	-23.4	-8.2	1.2	9.0	16.2	19.0	16.9	10.2	-0.5	-14.1	-27.7	(24)
(25)		10%	DB	-31.5	-26.4	-9.6	3.1	13.5	22.6	24.9	20.9	12.0	-0.4	-16.1	-30.1	(25)
(26)			MCWB	-31.7	-26.7	-10.9	-0.2	7.6	15.3	18.2	15.9	8.7	-1.6	-16.5	-30.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-21.5	-16.6	-2.4	4.7	12.4	20.0	22.2	20.7	13.8	2.9	-7.6	-21.6	(27)
(28)			MCDWB	-21.2	-16.2	-0.1	9.7	19.1	25.5	27.7	25.7	17.0	4.6	-7.0	-21.4	(28)
(29)		2%	WB	-25.9	-20.1	-5.5	3.0	10.9	18.3	20.9	19.0	12.2	0.9	-10.9	-25.1	(29)
(30)			MCDWB	-25.8	-19.7	-3.4	6.8	17.0	24.0	26.1	23.5	15.3	2.1	-10.4	-24.8	(30)
(31)		5%	WB	-29.0	-23.4	-8.2	1.5	9.5	17.3	19.9	17.6	10.6	-0.3	-14.0	-27.7	(31)
(32)			MCDWB	-28.9	-23.1	-6.6	4.4	14.7	22.9	24.8	21.3	13.5	0.9	-13.7	-27.5	(32)
(33)		10%	WB	-31.7	-26.6	-10.9	0.2	8.1	16.1	18.9	16.5	9.2	-1.7	-16.5	-30.3	(33)
(34)			MCDWB	-31.5	-26.4	-9.6	2.9	12.7	21.2	23.7	20.1	11.5	-0.4	-16.1	-30.2	(34)
(35)	Mean Daily Temperature Range	MDBR		7.3	10.4	14.4	13.3	9.8	11.0	11.0	10.8	8.8	7.1	7.8	6.3	(35)
(36)		5% DB	MCDBR	10.1	11.6	14.7	11.8	13.1	14.9	14.5	14.0	12.9	7.3	7.9	8.8	(36)
(37)			MCWBR	9.9	11.2	12.7	8.4	7.3	7.3	7.2	7.8	8.3	5.8	7.6	8.7	(37)
(38)			MCDBR	10.0	11.6	14.2	10.3	12.2	12.8	12.3	11.9	11.4	6.7	8.0	8.9	(38)
(39)		5% WB	MCWBR	9.9	11.2	12.4	7.5	7.0	7.1	7.1	7.2	7.7	5.4	7.7	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.195	0.248	0.295	0.350	0.411	0.407	0.489	0.462	0.347	0.272	0.197	0.179	(40)
(41)		taud		1.930	2.086	2.073	2.058	2.148	2.294	2.040	2.069	2.377	2.284	1.940	1.889	(41)
(42)		Ebn at Noon		411	680	784	815	794	811	716	694	738	654	388	200	(42)
(43)		Edh at Noon		31	65	100	129	130	115	145	129	77	53	29	14	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.24	1.16	2.95	5.02	5.39	6.04	5.41	4.09	2.44	1.02	0.38	0.10	(44)
(45)		RadStd		0.01	0.04	0.11	0.20	0.49	0.34	0.35	0.33	0.33	0.10	0.03	0.00	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.69	+1.48	+1.45	N/A	N/A	N/A	-239	-272	+80	N/A	(46)
(47)	Regional (5 neighbors)	+0.66	N/A	N/A	N/A	N/A	N/A	-228	-235	N/A	N/A	(47)

Nomenclature: See separate page