

VERHOJANSK PEREVOZ, Russian Federation

WMO: 246680

Lat: 63.317N

Lon: 132.017E

Elev: 298

StdP: 14.54

Time Zone: 9.00 (E09)

Period: 83-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-65.4	-61.9	-68.3	0.1	-63.6	-65.3	0.1	-61.9	11.7	-24.5	10.2	-27.5	0.3	90	0.705

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	83.0	65.2	78.9	63.2	75.3	61.4	67.5	78.5	65.4	74.9	63.5	72.1	3.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	89.8	71.3	61.9	83.6	69.3	59.9	77.9	67.6	32.3	79.2	30.6	75.0	29.1	72.3	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.3	9.2	-66.3	90.0	5.0	2.3	-69.9	91.6	-72.9	92.9	-75.7	94.2	-79.3	95.9		
(5)			-66.3	70.9	5.0	2.8	-69.9	72.8	-72.9	74.5	-75.7	76.0	-79.3	78.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-45.7	-35.1	-6.9	20.9	42.8	58.6	63.4	57.0	40.6	14.6	-23.9	-41.6		
	DBStd	40.98	10.69	10.79	15.11	11.85	8.39	6.48	6.95	6.53	7.80	13.18	14.40	12.11		
	HDD50	14712	2966	2382	1763	873	251	10	2	17	292	1099	2216	2841		
	HDD65	19315	3431	2802	2228	1323	687	205	115	256	732	1564	2666	3306		
	CDD50	962	0	0	0	0	29	269	418	235	11	0	0	0		
	CDD65	90	0	0	0	0	0	15	66	9	0	0	0	0		
	CDH74	1065	0	0	0	0	6	250	704	105	0	0	0	0		
	CDH80	254	0	0	0	0	0	42	201	11	0	0	0	0		
	WSAvg	2.9	1.4	1.9	3.2	4.1	4.4	3.7	3.1	3.1	3.0	3.2	2.1	1.6		
	PrecAvg	14.6	0.5	0.3	0.4	0.6	1.5	2.0	2.5	2.2	2.0	1.5	0.7	0.4		
(15) Precipitation	PrecMax	19.1	1.2	0.8	1.4	1.5	3.0	3.7	5.0	4.3	3.8	2.9	1.8	1.1		
	PrecMin	10.4	0.2	0.0	0.0	0.0	0.2	0.6	1.0	0.3	0.2	0.1	0.1	0.1		
	PrecStd	1.9	0.2	0.2	0.3	0.4	0.7	0.8	1.0	0.9	0.9	0.7	0.4	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.5	1.4	32.3	49.5	73.7	84.9	89.7	81.6	66.8	42.3	19.2	-3.8		
		MCWB	-8.8	0.4	27.3	38.8	53.1	63.4	67.7	65.5	53.8	37.3	18.0	-4.5		
	2%	DB	-17.3	-6.4	27.7	45.9	68.0	80.1	85.6	76.8	62.4	38.2	11.4	-10.3		
		MCWB	-17.6	-7.0	23.8	36.2	50.5	61.7	67.4	62.4	51.2	34.3	10.5	-10.9		
	5%	DB	-24.2	-12.4	23.9	42.2	62.6	76.6	81.7	73.3	58.6	34.3	5.6	-17.1		
		MCWB	-24.3	-12.9	20.2	33.6	47.9	59.3	65.2	61.5	49.7	31.8	5.1	-17.5		
	10%	DB	-29.7	-17.9	19.5	38.7	58.6	72.9	77.7	69.9	54.6	31.7	-1.4	-23.1		
		MCWB	-30.0	-18.3	16.6	31.5	46.2	58.2	64.1	60.0	47.5	29.5	-1.9	-23.3		
	0.4%	WB	-8.9	0.6	28.6	39.5	55.4	65.9	71.4	67.2	56.4	39.4	17.5	-4.1		
		MCDB	-8.7	1.4	30.4	48.6	69.7	77.8	83.9	76.5	62.3	40.9	19.4	-3.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-17.6	-7.0	23.4	36.9	51.7	63.5	68.9	64.8	53.5	34.7	10.9	-10.7		
		MCDB	-17.3	-6.4	27.2	44.4	64.0	75.6	80.7	72.8	59.9	36.8	11.7	-10.3		
	5%	WB	-24.3	-12.8	20.3	34.3	49.3	61.8	67.3	63.2	50.9	32.2	4.9	-17.3		
		MCDB	-24.2	-12.4	23.8	40.6	61.0	73.1	78.2	70.5	56.7	34.2	5.5	-16.9		
	10%	WB	-29.8	-18.2	16.5	32.2	47.2	59.9	65.4	61.2	48.3	29.5	-1.9	-23.2		
		MCDB	-29.6	-17.8	19.4	38.3	57.2	69.7	74.7	68.0	54.2	31.9	-1.4	-23.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	20.3	29.1	26.0	20.3	22.1	21.6	20.6	19.9	14.8	14.9	11.6		
		MCDBR	19.5	23.5	26.7	23.9	28.4	29.4	27.6	25.8	26.8	15.2	16.2	16.7		
		MCWBR	19.2	23.0	23.1	16.0	14.4	13.5	11.5	13.4	16.4	11.5	15.9	16.7		
		MCDBR	19.4	23.6	26.0	20.3	24.6	24.9	24.3	21.2	22.7	13.4	16.3	17.0		
	5% WB	MCWBR	19.2	23.0	22.6	14.2	13.0	12.7	11.6	12.0	14.7	10.6	16.0	16.8		
(40) Clear-Sky Solar Irradiance	taub		0.192	0.248	0.297	0.355	0.416	0.403	0.504	0.457	0.346	0.273	0.197	0.175		
	taud		1.946	2.093	2.072	2.039	2.129	2.310	1.990	2.084	2.384	2.284	1.952	1.894		
	Ebn at Noon		137	218	249	257	251	259	223	222	235	208	128	71		
	Edh at Noon		10	21	32	42	42	36	49	40	24	17	9	5		
(44) All-Sky Solar Radiation	RadAvg		84	381	944	1589	1685	1853	1701	1297	767	351	129	34		
	RadStd		4	13	36	54	141	132	112	109	95	30	9	2		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (4 neighbors)		+1.44	+2.65	+2.29	N/A	N/A	N/A	-459	-518	+130	N/A	

Nomenclature: See separate page