

VERHOJANSK PEREVOZ, Russian Federation

WMO: 246680

Lat: 63.317N

Lon: 132.017E

Elev: 91

StdP: 100.24

Time Zone: 9.00 (E09)

Period: 83-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-54.1	-52.2	-55.7	0.0	-53.1	-54.1	0.0	-52.1	5.2	-31.4	4.6	-33.0	0.1	90	0.705

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	28.3	18.5	26.1	17.4	24.1	16.3	19.7	25.8	18.6	23.8	17.5	22.3	1.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	12.8	21.9	16.6	11.9	20.7	15.5	11.1	19.8	57.1	26.2	53.3	23.9	49.8	22.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.1	5.0	4.1	-54.6	32.2	2.8	1.3	-56.6	33.1	-58.3	33.9	-59.8	34.6	-61.9	35.5		
			-54.6	21.6	2.8	1.5	-56.6	22.7	-58.3	23.6	-59.8	24.4	-61.9	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.9	-43.2	-37.3	-21.6	-6.2	6.0	14.8	17.5	13.9	4.8	-9.7	-31.0	-40.9
	DBStd	22.77	5.94	5.99	8.40	6.58	4.66	3.60	3.86	3.63	4.34	7.32	8.00	6.73
	HDD10.0	8173	1648	1323	979	485	139	6	1	9	162	611	1231	1578
	HDD18.3	10731	1906	1557	1238	735	382	114	64	142	407	869	1481	1837
	CDD10.0	534	0	0	0	0	16	149	232	131	6	0	0	0
	CDD18.3	50	0	0	0	0	0	8	37	5	0	0	0	0
	CDH23.3	592	0	0	0	0	3	139	391	58	0	0	0	0
	CDH26.7	141	0	0	0	0	0	23	112	6	0	0	0	0
Wind	WSAvg	1.3	0.6	0.8	1.4	1.8	2.0	1.7	1.4	1.4	1.3	1.4	0.9	0.7
Precipitation	PrecAvg	370	12	8	9	15	39	50	63	56	52	39	19	9
	PrecMax	484	30	20	35	39	76	94	126	110	96	73	45	28
	PrecMin	263	4	1	1	1	6	16	25	8	6	2	3	2
	PrecStd	47	6	5	8	10	18	20	25	24	22	17	10	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-22.5	-17.0	0.2	9.7	23.2	29.4	32.0	27.5	19.3	5.7	-7.1	-19.9
		MCWB	-22.7	-17.5	-2.6	3.8	11.7	17.4	19.8	18.6	12.1	2.9	-7.8	-20.3
	2%	DB	-27.4	-21.4	-2.4	7.7	20.0	26.7	29.8	24.9	16.9	3.5	-11.4	-23.5
		MCWB	-27.6	-21.7	-4.5	2.3	10.3	16.5	19.7	16.9	10.7	1.3	-12.0	-23.8
	5%	DB	-31.2	-24.7	-4.5	5.7	17.0	24.8	27.6	22.9	14.8	1.3	-14.7	-27.3
		MCWB	-31.3	-24.9	-6.5	0.9	8.8	15.2	18.4	16.4	9.8	-0.1	-15.0	-27.5
	10%	DB	-34.3	-27.7	-7.0	3.7	14.8	22.7	25.4	21.1	12.6	-0.2	-18.5	-30.6
		MCWB	-34.4	-27.9	-8.6	-0.3	7.9	14.5	17.8	15.6	8.6	-1.4	-18.8	-30.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-22.7	-17.5	-1.9	4.2	13.0	18.8	21.9	19.5	13.6	4.1	-8.1	-20.1
		MCDB	-22.6	-17.0	-0.9	9.2	20.9	25.4	28.8	24.7	16.8	4.9	-7.0	-19.8
	2%	WB	-27.5	-21.6	-4.8	2.7	11.0	17.5	20.5	18.2	12.0	1.5	-11.7	-23.7
		MCDB	-27.4	-21.3	-2.6	6.9	17.8	24.2	27.0	22.7	15.5	2.7	-11.3	-23.5
	5%	WB	-31.3	-24.9	-6.5	1.3	9.6	16.6	19.6	17.3	10.5	0.1	-15.0	-27.4
		MCDB	-31.2	-24.6	-4.6	4.8	16.1	22.8	25.7	21.4	13.7	1.2	-14.7	-27.2
	10%	WB	-34.4	-27.9	-8.6	0.1	8.4	15.5	18.6	16.2	9.1	-1.4	-18.9	-30.7
		MCDB	-34.2	-27.7	-7.0	3.5	14.0	21.0	23.7	20.0	12.3	0.0	-18.6	-30.6
Mean Daily Temperature Range	5% DB	MDBR	7.0	11.3	16.2	14.5	11.3	12.3	12.0	11.5	11.1	8.2	8.3	6.5
		MCDBR	10.9	13.0	14.9	13.3	15.8	16.4	15.3	14.4	14.9	8.4	9.0	9.3
		MCWBR	10.7	12.8	12.8	8.9	8.0	7.5	6.4	7.4	9.1	6.4	8.8	9.3
	5% WB	MCDBR	10.8	13.1	14.4	11.3	13.7	13.9	13.5	11.8	12.6	7.4	9.1	9.5
		MCWBR	10.6	12.8	12.6	7.9	7.2	7.1	6.5	6.7	8.1	5.9	8.9	9.3
Clear-Sky Solar Irradiance	taub	0.192	0.248	0.297	0.355	0.416	0.403	0.504	0.457	0.346	0.273	0.197	0.175	
	taud	1.946	2.093	2.072	2.039	2.129	2.310	1.990	2.084	2.384	2.284	1.952	1.894	
	Ebn at Noon	433	686	785	810	790	816	703	701	742	657	403	224	
	Edh at Noon	31	65	101	132	133	114	153	127	77	54	29	15	
All-Sky Solar Radiation	RadAvg	0.27	1.20	2.98	5.01	5.31	5.84	5.36	4.09	2.42	1.11	0.41	0.11	
	RadStd	0.01	0.04	0.12	0.17	0.44	0.42	0.35	0.34	0.30	0.10	0.03	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+0.80	+1.47	+1.27	N/A	N/A	N/A	-255	-288	+72	N/A

Nomenclature: See separate page