

POKROVSK, Russian Federation

WMO: 248560

Lat: 61.483N

Lon: 129.150E

Elev: 396

StdP: 14.49

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -59.2	(c) -56.0	(d) -61.8	(e) 0.1	(f) -58.5	(g) -58.7	(h) 0.2	(i) -56.2	(j) 13.6	(k) -31.8	(l) 12.0	(m) -30.9	(n) 2.3	(o) 240	(p) 0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	86.1	65.9	82.3	64.6	78.4	63.0	68.7	80.7	66.8	78.2	64.7	75.4	6.4	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	92.8	73.7	62.4	85.6	72.1	60.3	79.2	70.3	33.2	80.8	31.7	78.6	30.1	75.7	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	13.3	11.7	-62.1	92.0	4.3	2.8	-65.2	94.0	-67.7	95.6	-70.1	97.2	-73.3	99.2
			-62.1	72.5	4.3	3.2	-65.2	74.8	-67.7	76.7	-70.1	78.5	-73.3	80.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	-37.0	-28.9	-5.3	22.9	44.2	59.4	65.0	58.1	41.8	18.5	-16.3	-36.3
	DBStd	38.73	11.40	11.75	13.71	11.15	7.61	7.41	6.83	6.75	7.60	12.01	15.70	12.07
	HDD50	13568	2697	2210	1713	813	212	11	1	10	262	976	1988	2675
	HDD65	18109	3162	2630	2178	1263	646	197	86	231	697	1441	2438	3140
	CDD50	1070	0	0	0	0	31	293	467	263	16	0	0	0
	CDD65	134	0	0	0	0	0	28	87	19	0	0	0	0
	CDH74	1920	0	0	0	0	14	528	1102	273	3	0	0	0
	CDH80	564	0	0	0	0	1	141	360	62	0	0	0	0
Wind	WSAvg	5.4	4.1	4.4	5.4	6.0	6.8	6.1	5.7	5.7	6.2	5.5	4.6	3.9
Precipitation	PrecAvg	10.7	0.4	0.3	0.2	0.3	0.9	1.4	2.0	1.9	1.3	0.9	0.6	0.4
	PrecMax	15.5	1.1	0.5	0.6	1.1	2.9	3.4	4.5	5.6	3.7	1.9	1.5	1.2
	PrecMin	5.0	0.2	0.1	0.0	0.0	0.1	0.4	0.5	0.4	0.5	0.2	0.2	0.2
	PrecStd	2.4	0.2	0.1	0.2	0.2	0.7	0.8	1.2	1.1	0.8	0.4	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.3	15.2	37.2	55.9	75.7	88.7	92.1	86.2	70.3	45.1	30.4	4.7
		MCWB	-2.0	13.9	31.1	42.7	55.0	65.2	68.4	66.8	55.8	39.1	29.1	4.0
	2%	DB	-8.9	2.4	30.0	48.6	68.8	83.9	87.9	80.6	63.7	40.4	22.4	-6.8
		MCWB	-9.3	1.7	25.1	38.8	51.3	63.3	67.2	65.0	52.5	35.7	21.2	-7.2
	5%	DB	-14.3	-5.1	24.2	43.9	64.3	80.1	84.2	76.5	59.3	36.8	13.8	-13.4
		MCWB	-14.7	-5.6	21.1	35.5	48.7	61.7	65.9	62.4	50.9	33.5	12.9	-13.7
	10%	DB	-20.0	-11.0	18.0	40.0	60.0	76.2	80.4	72.7	55.6	33.8	6.6	-18.9
		MCWB	-20.2	-11.5	15.6	33.2	47.0	60.1	64.8	60.8	49.1	31.1	5.9	-19.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.8	13.9	31.0	43.2	56.3	68.7	71.8	70.1	57.5	40.6	29.7	4.1
		MCDB	-1.4	15.1	36.6	54.7	73.1	82.3	84.7	80.5	66.0	44.0	30.3	4.7
	2%	WB	-9.2	1.7	25.5	39.3	52.5	65.4	69.7	66.9	54.6	36.5	21.3	-7.0
		MCDB	-8.8	2.3	29.6	47.4	65.6	79.3	82.3	76.8	60.9	39.4	22.6	-6.6
	5%	WB	-14.7	-5.7	21.1	36.2	50.2	63.3	68.1	64.3	52.0	33.7	12.9	-13.7
		MCDB	-14.3	-5.3	24.1	42.5	61.7	76.4	80.2	74.0	57.6	36.7	13.7	-13.5
	10%	WB	-20.2	-11.4	15.6	33.6	47.9	61.2	66.4	62.0	49.5	31.2	5.8	-19.1
		MCDB	-20.0	-11.1	17.9	39.4	58.2	73.8	77.5	70.7	55.0	33.8	6.4	-18.9
Mean Daily Temperature Range	5% DB	MDBR	13.9	19.8	28.2	24.8	20.9	23.7	22.1	22.1	18.9	15.1	16.2	12.5
		MCDBR	20.8	24.3	30.1	25.0	30.4	31.5	29.7	30.0	27.4	16.3	19.8	19.0
		MCWBR	20.5	23.8	26.2	16.3	16.2	14.2	12.9	15.6	17.2	12.6	18.9	18.8
	5% WB	MCDBR	20.8	24.2	30.0	22.9	26.4	27.3	24.3	24.6	22.5	14.5	19.5	19.0
		MCWBR	20.5	23.7	26.2	15.6	14.6	13.9	11.8	13.6	15.1	11.7	18.8	18.8
Clear-Sky Solar Irradiance	taub	0.223	0.264	0.305	0.365	0.434	0.429	0.515	0.488	0.370	0.292	0.229	0.190	
	taud	1.973	2.066	2.061	2.065	2.096	2.224	1.964	1.995	2.289	2.300	2.005	1.887	
	Ebn at Noon	150	221	252	258	248	253	223	216	230	213	143	104	
	Edh at Noon	13	23	34	42	44	40	51	45	28	19	12	8	
All-Sky Solar Radiation	RadAvg	126	449	1009	1608	1659	1879	1719	1335	825	376	172	62	
	RadStd	7	15	36	64	124	127	108	92	85	40	14	2	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+1.01	N/A	N/A	N/A	N/A	N/A	-369	N/A	N/A	N/A
Regional (5 neighbors)		+1.28	+2.57	+2.27	N/A	N/A	N/A	-425	-443	N/A	N/A

Nomenclature: See separate page