

UST-MAYA, Russian Federation

WMO: 249660

Lat: 60.3650N

Lon: 134.4510E

Elev: 559

StdP: 14.40

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-57.9	-55.2	-60.5	0.1	-57.6	-57.9	0.2	-55.1	9.4	-16.5	7.4	-21.2	0.3	20	0.682

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	84.9	66.3	81.4	64.8	77.9	63.0	68.6	80.3	66.6	77.7	64.6	75.0	5.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	93.4	73.2	62.4	86.2	71.9	60.4	80.0	69.8	33.3	80.4	31.6	77.6	30.1	75.1	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.4	11.2	9.4	-60.9	90.4	3.2	2.7	-63.2	92.4	-65.1	94.0	-66.9	95.5	-69.2	97.5		
			-61.0	71.5	3.2	2.3	-63.3	73.2	-65.1	74.5	-66.9	75.8	-69.2	77.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	-37.7	-28.0	-2.2	26.0	46.2	60.6	65.6	59.3	43.8	20.2	-15.2	-37.0
	DBStd	39.15	11.18	11.54	13.22	10.50	7.14	6.85	6.34	6.67	7.60	11.78	16.36	11.95
	HDD50	13202	2718	2185	1617	719	161	6	0	7	213	923	1956	2697
	HDD65	17649	3183	2605	2082	1169	584	164	70	200	636	1388	2406	3162
	CDD50	1174	0	0	0	0	42	323	485	297	27	0	0	0
	CDD65	146	0	0	0	0	0	31	90	25	0	0	0	0
	CDH74	1687	0	0	0	0	15	455	970	245	2	0	0	0
	CDH80	433	0	0	0	0	1	101	288	43	0	0	0	0
Wind	WSAvg	3.5	1.3	1.7	3.2	4.5	5.5	5.0	4.5	4.1	4.3	3.9	2.4	1.3
Precipitation	PrecAvg	12.2	0.4	0.4	0.3	0.4	1.1	1.4	2.2	2.0	1.7	1.1	0.8	0.4
	PrecMax	16.9	1.0	0.9	1.7	1.3	2.2	2.8	5.4	5.6	3.5	2.6	1.6	0.9
	PrecMin	7.4	0.1	0.1	0.0	0.0	0.2	0.4	0.2	0.4	0.4	0.4	0.2	0.1
	PrecStd	2.4	0.2	0.2	0.4	0.3	0.5	0.6	1.3	1.2	0.9	0.6	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.6	12.8	38.0	55.9	76.0	87.3	90.1	84.8	70.1	46.3	31.7	-1.9
		MCWB	-0.1	11.6	31.5	43.3	56.4	66.2	69.0	67.5	56.6	39.9	28.9	-2.5
	2%	DB	-9.7	2.6	31.8	49.8	69.6	83.1	86.4	80.1	64.5	41.0	24.6	-7.6
		MCWB	-10.1	1.8	26.8	39.3	53.1	63.5	67.5	65.5	54.0	37.0	23.5	-8.0
	5%	DB	-16.3	-3.7	26.2	45.9	65.1	79.5	83.3	76.2	60.2	37.3	16.5	-13.6
		MCWB	-16.7	-4.3	22.3	36.7	50.5	61.8	66.3	63.0	51.2	33.8	15.3	-13.9
	10%	DB	-21.4	-10.4	21.0	41.8	61.0	75.8	79.6	72.5	56.6	34.1	8.6	-19.5
		MCWB	-21.6	-10.9	17.9	34.2	48.1	60.3	64.8	60.9	49.4	31.5	7.8	-19.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.2	11.9	32.1	43.5	57.1	68.1	71.8	70.0	58.3	41.4	28.8	-2.6
		MCDB	0.7	13.0	38.0	54.9	74.3	82.5	85.3	79.9	66.7	44.6	30.7	-2.3
	2%	WB	-10.0	2.0	26.8	39.6	53.8	65.6	69.8	66.9	55.6	37.1	23.5	-8.0
		MCDB	-9.7	2.6	31.6	48.6	68.3	79.0	82.1	76.4	62.2	40.7	24.6	-7.5
	5%	WB	-16.6	-4.3	22.3	37.2	51.2	63.6	68.0	64.5	53.0	34.2	15.3	-13.9
		MCDB	-16.4	-3.7	26.0	45.0	63.8	75.8	79.3	73.7	58.2	36.7	16.4	-13.5
	10%	WB	-21.5	-10.8	17.8	34.8	48.7	61.5	66.1	62.3	50.4	31.8	7.8	-19.7
		MCDB	-21.3	-10.4	20.9	41.3	59.4	73.4	77.0	70.9	55.6	33.9	8.6	-19.4
Mean Daily Temperature Range	5% DB	MDBR	12.4	21.0	29.7	22.8	19.9	22.0	20.6	19.5	17.2	12.7	13.8	10.2
		MCDBR	16.9	23.2	29.9	22.8	28.6	28.9	27.1	25.2	24.2	14.2	17.5	14.5
		MCWBR	16.6	22.4	25.2	14.2	15.3	12.4	11.3	12.2	14.1	10.0	16.5	14.3
	5% WB	MCDBR	17.0	23.2	28.7	21.1	26.1	25.4	22.4	22.3	19.9	13.1	17.5	14.4
		MCWBR	16.8	22.4	24.1	13.5	14.2	11.9	10.3	11.5	12.6	9.6	16.7	14.3
Clear-Sky Solar Irradiance	taub	0.224	0.263	0.309	0.384	0.453	0.430	0.517	0.458	0.350	0.300	0.236	0.196	
	taud	2.007	2.076	2.040	1.961	2.030	2.222	1.959	2.096	2.391	2.276	2.019	1.925	
	Ebn at Noon	167	229	253	252	243	254	224	229	244	215	156	126	
	Edh at Noon	14	24	36	47	48	40	51	42	26	20	14	10	
All-Sky Solar Radiation	RadAvg	160	496	1050	1612	1643	1885	1720	1336	814	383	203	86	
	RadStd	8	19	37	63	135	132	105	115	78	41	20	4	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	-295	N/A	N/A

Nomenclature: See separate page