

AYON, Russian Federation

WMO: 250420

Lat: 69.935N

Lon: 167.989E

Elev: 14

StdP: 101.16

Time Zone: 12.00 (E12)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -39.3	(c) -37.6	(d) -41.9	(e) 0.1	(f) -39.0	(g) -40.3	(h) 0.1	(i) -37.4	(j) 14.3	(k) -20.4	(l) 13.2	(m) -14.1	(n) 2.8	(o) 170	(p) 1.073

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	19.5	13.7	17.1	12.6	14.4	11.0	14.3	18.4	12.7	16.8	11.1	14.3	6.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	8.6	17.6	10.3	7.8	15.2	8.7	7.0	13.2	40.3	18.3	36.1	16.9	31.9	14.4	18.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.2	10.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-40.3	15.8	1.8	2.6	-41.6	17.7	-42.6	19.2	-43.6	20.6	-44.9	22.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.4	-26.7	-25.9	-24.6	-15.1	-5.0	3.5	6.2	5.0	1.5	-5.9	-15.9	-22.9	(6)
(7)		DBStd	13.59	6.40	7.07	6.57	6.04	4.50	4.51	4.67	4.45	3.56	5.75	6.99	7.62	(7)
(8)		HDD10.0	7496	1137	1006	1073	754	466	204	141	168	257	493	778	1019	(8)
(9)		HDD18.3	10489	1396	1239	1332	1004	724	444	376	413	505	751	1028	1277	(9)
(10)		CDD10.0	50	0	0	0	0	0	10	24	14	2	0	0	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(11)
(12)		CDH23.3	12	0	0	0	0	0	0	9	3	0	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.0	4.4	4.6	5.0	4.9	4.7	4.8	4.8	5.2	5.4	5.2	5.8	4.9	(14)
(15)	Precipitation	PrecAvg	112	6	7	5	7	6	7	13	15	14	15	11	7	(15)
(16)		PrecMax	164	17	15	11	18	31	17	37	39	24	41	26	25	(16)
(17)		PrecMin	56	0	0	1	1	1	1	4	4	5	3	3	1	(17)
(18)		PrecStd	24	4	4	3	4	6	4	8	9	6	8	5	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.0	-4.0	-2.9	1.2	8.0	20.9	23.9	22.7	16.9	6.0	-0.6	-2.1	(19)
(20)			MCWB	-4.7	-4.7	-3.5	0.3	6.4	13.1	16.8	16.6	11.8	4.9	-1.1	-2.6	(20)
(21)		2%	DB	-8.3	-8.7	-8.6	-1.8	3.2	18.2	20.2	18.1	10.6	3.2	-2.0	-6.1	(21)
(22)			MCWB	-8.8	-9.1	-9.0	-2.6	2.1	12.0	14.6	13.3	8.1	2.8	-2.5	-6.6	(22)
(23)		5%	DB	-15.5	-13.4	-11.9	-4.2	2.0	15.3	17.6	15.4	8.0	2.0	-4.1	-8.8	(23)
(24)			MCWB	-15.8	-13.8	-12.2	-4.8	1.1	10.8	13.3	12.0	6.4	1.6	-4.7	-9.1	(24)
(25)		10%	DB	-19.1	-16.1	-14.9	-6.3	1.0	11.7	14.6	12.5	6.0	0.7	-6.1	-12.2	(25)
(26)			MCWB	-19.4	-16.4	-15.2	-6.8	0.3	8.6	11.7	10.0	4.9	0.2	-6.6	-12.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.8	-4.7	-3.3	0.2	6.6	13.7	17.0	17.2	11.7	5.1	-1.0	-2.5	(27)
(28)			MCDWB	-4.1	-4.2	-2.7	1.1	8.1	19.6	23.8	22.5	16.3	5.9	-0.8	-2.0	(28)
(29)		2%	WB	-8.7	-9.0	-9.0	-2.5	2.1	12.2	14.9	14.0	8.6	2.9	-2.5	-6.5	(29)
(30)			MCDWB	-8.3	-8.5	-8.6	-1.8	2.9	17.7	19.2	17.2	10.5	3.2	-2.0	-6.2	(30)
(31)		5%	WB	-15.9	-13.8	-12.2	-4.8	1.2	10.6	13.4	11.9	6.5	1.7	-4.7	-9.1	(31)
(32)			MCDWB	-15.6	-13.5	-11.9	-4.3	1.8	15.1	17.3	15.1	7.8	1.9	-4.2	-8.8	(32)
(33)		10%	WB	-19.3	-16.4	-15.2	-6.8	0.3	8.5	11.7	10.2	4.9	0.3	-6.6	-12.4	(33)
(34)			MCDWB	-19.1	-16.2	-14.9	-6.3	0.9	11.7	14.7	12.6	5.8	0.7	-6.1	-12.1	(34)
(35)	Mean Daily Temperature Range	MDBR		5.3	5.4	6.1	6.9	5.4	6.3	7.0	5.9	4.1	3.9	5.4	5.2	(35)
(36)		5% DB	MCDBR	10.2	8.8	8.0	7.7	5.6	13.6	12.9	12.1	8.4	3.4	5.4	7.4	(36)
(37)			MCWBR	9.9	8.7	7.9	7.2	4.9	8.6	8.0	7.8	6.0	3.1	5.5	7.3	(37)
(38)		5% WB	MCDBR	10.3	8.8	8.1	7.6	5.3	13.3	12.3	11.5	7.8	3.0	5.6	7.4	(38)
(39)			MCWBR	10.0	8.7	8.1	7.1	4.8	8.7	7.8	7.8	5.7	2.8	5.6	7.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		N/A	0.207	0.283	0.324	0.349	0.344	0.377	0.376	0.312	0.248	N/A	N/A	(40)
(41)		taud		N/A	2.009	2.016	1.962	2.011	2.226	2.293	2.325	2.466	2.135	N/A	N/A	(41)
(42)		Ebn at Noon		0	532	698	786	816	842	794	743	710	456	0	0	(42)
(43)		Edh at Noon		0	40	86	126	137	115	105	90	58	35	0	0	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.00	0.34	2.00	4.36	6.28	6.48	5.07	3.26	1.64	0.49	0.00	0.00	(44)
(45)		RadStd		0.00	0.06	0.12	0.21	0.28	0.55	0.42	0.29	0.11	0.07	0.00	0.00	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page