

MYS SHMIDTA, Russian Federation

WMO: 251730

Lat: 68.900N

Lon: 179.633W

Elev: 10

StdP: 14.69

Time Zone: 12.00 (E12)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.8	-32.4	-39.2	0.6	-35.6	-35.8	0.7	-32.1	42.6	-13.4	38.9	-8.8	2.5	160	1.057

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	60.3	51.8	55.1	49.8	50.6	46.5	52.7	58.9	49.8	55.2	46.7	50.4	9.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.6	50.8	55.0	46.0	45.8	51.9	43.5	41.7	48.7	21.9	58.7	20.2	55.3	18.6	50.5	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.0	29.4	25.7	-39.3	73.2	3.0	5.3	-41.4	77.0	-43.2	80.1	-44.8	83.1	-47.0	86.9		
(5)			-39.9	58.5	3.3	4.3	-42.3	61.5	-44.3	64.0	-46.1	66.4	-48.6	69.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	-13.2	-15.3	-9.3	0.9	23.1	36.6	41.0	39.8	34.2	21.2	6.5	-7.0		
	DBStd	23.03	10.44	10.49	12.54	10.84	9.10	6.24	6.34	5.84	6.20	9.07	12.11	13.22		
	HDD50	13399	1960	1827	1838	1474	834	407	293	326	474	894	1304	1768		
	HDD65	18845	2425	2247	2303	1924	1299	852	743	783	923	1359	1754	2233		
	CDD50	30	0	0	0	0	0	5	15	9	1	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	4	0	0	0	0	0	0	3	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	10.7	11.7	12.6	9.5	9.5	8.3	8.4	9.5	9.8	10.0	12.1	13.2	13.5		
	PrecAvg	10.1	0.7	0.5	0.3	0.4	0.5	0.7	1.3	1.7	1.6	1.1	1.1	0.6		
(15) Precipitation	PrecMax	14.2	3.7	1.4	1.0	1.8	1.9	2.1	3.1	3.9	7.4	3.5	2.5	2.0		
	PrecMin	4.9	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.5	0.1	0.2	0.1	0.0		
	PrecStd	2.7	0.7	0.4	0.2	0.4	0.4	0.4	0.8	1.0	1.6	0.7	0.6	0.5		
	PrecStd	2.7	0.7	0.4	0.2	0.4	0.4	0.4	0.8	1.0	1.6	0.7	0.6	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	21.7	33.7	34.4	45.9	62.7	70.1	64.7	58.2	38.3	33.2	31.5		
		MCWB	24.4	20.7	28.9	32.4	40.2	51.9	57.5	54.3	48.9	36.1	31.7	30.0		
	2%	DB	11.1	12.7	26.2	29.2	40.5	55.9	62.0	57.2	50.3	35.1	29.8	25.2		
		MCWB	10.3	12.1	24.4	27.7	36.5	48.6	53.2	51.7	45.5	33.4	28.9	23.7		
	5%	DB	5.4	5.7	18.7	23.1	37.3	50.7	56.0	52.9	45.3	33.1	27.2	19.0		
		MCWB	4.9	5.1	17.7	21.7	34.8	45.4	50.8	48.7	42.6	31.6	26.4	17.8		
	10%	DB	0.9	-0.4	10.6	17.7	34.6	45.8	50.2	48.7	42.0	32.0	23.3	11.7		
		MCWB	0.4	-0.9	9.9	16.8	33.0	41.9	46.6	46.1	40.6	30.7	22.2	10.9		
	0.4%	WB	24.4	20.0	29.4	32.8	40.4	52.5	57.8	55.5	50.2	36.6	32.2	29.8		
		MCDB	25.4	21.6	32.5	34.1	45.8	60.6	67.1	62.6	56.8	37.9	32.8	32.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	10.4	12.0	24.4	27.8	36.9	48.8	54.0	51.7	45.7	33.9	28.9	23.8		
		MCDB	11.2	12.5	26.1	29.3	40.1	55.6	61.1	57.4	49.7	34.8	29.7	25.2		
	5%	WB	4.9	5.1	17.7	21.8	34.8	45.3	50.5	49.0	43.0	32.1	26.4	17.8		
		MCDB	5.4	5.6	18.6	23.1	36.9	50.5	56.3	52.8	45.0	32.7	27.1	18.9		
	10%	WB	0.5	-0.9	9.9	16.7	33.1	42.0	46.9	45.9	40.6	30.8	22.2	11.0		
		MCDB	1.0	-0.4	10.5	17.6	34.5	45.6	49.9	48.5	41.7	31.8	23.1	11.8		
	5% DB	MDBR	9.9	10.1	12.3	13.4	9.3	8.0	9.0	7.6	6.3	8.1	9.5	9.2		
		MCDBR	15.6	20.0	19.9	16.1	12.7	17.6	22.1	18.2	13.8	7.7	10.7	13.8		
		MCWBR	15.2	19.4	18.5	14.7	9.5	11.2	14.5	12.4	9.6	6.7	10.2	13.3		
		MCWBR	15.1	20.0	20.1	15.4	11.7	17.2	21.0	17.3	12.0	6.5	10.5	13.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	14.7	19.4	18.7	14.1	9.0	11.2	14.5	12.2	8.7	6.2	10.2	13.2		
		MCWBR	14.7	19.4	18.7	14.1	9.0	11.2	14.5	12.2	8.7	6.2	10.2	13.2		
	Clear-Sky Solar Irradiance	taub	0.164	0.222	0.261	0.318	0.355	0.346	0.352	0.346	0.305	0.239	0.170	N/A		
		taud	1.900	2.032	2.146	2.014	2.022	2.293	2.436	2.468	2.476	2.180	1.925	N/A		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	23	174	243	255	259	269	264	252	233	167	16	0		
		Edh at Noon	2	14	25	39	44	35	29	25	19	12	1	0		
(44) All-Sky Solar Radiation	RadStd	RadAvg	7	135	672	1412	1908	1989	1531	1020	548	159	21	0		
		RadStd	1	15	43	69	93	118	157	114	55	23	3	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page