

MYS SHMIDTA, Russian Federation

WMO: 251730

Lat: 68.900N

Lon: 179.633W

Elev: 3

StdP: 101.29

Time Zone: 12.00 (E12)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.7	-35.8	-39.5	0.1	-37.5	-37.7	0.1	-35.6	19.0	-25.2	17.4	-22.7	1.1	160	1.057

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	15.7	11.0	12.8	9.9	10.4	8.1	11.5	15.0	9.9	12.9	8.2	10.2	4.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	7.3	12.8	7.8	6.5	11.0	6.4	6.0	9.3	33.0	14.8	29.1	12.9	25.3	10.3	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.2	13.1	11.5	DB	-39.6	22.9	1.6	3.0	-40.8	25.0	-41.8	26.7	-42.7	28.4	-43.9	30.5	(4)
(5)			WB	-39.9	14.7	1.9	2.4	-41.3	16.4	-42.4	17.8	-43.4	19.1	-44.8	20.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.3	-25.1	-26.3	-22.9	-17.3	-4.9	2.6	5.0	4.3	1.2	-6.0	-14.2	-21.7	(6)
(7)		DBStd	12.79	5.80	5.83	6.97	6.02	5.06	3.46	3.52	3.25	3.45	5.04	6.73	7.35	(7)
(8)		HDD10.0	7444	1089	1015	1021	819	463	226	163	181	263	497	724	982	(8)
(9)		HDD18.3	10469	1347	1248	1279	1069	722	473	413	435	513	755	974	1241	(9)
(10)		CDD10.0	17	0	0	0	0	0	3	8	5	1	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	2	0	0	0	0	0	0	2	1	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	5.2	5.6	4.2	4.3	3.7	3.8	4.3	4.4	4.5	5.4	5.9	6.0	(14)
(15)	Precipitation	PrecAvg	256	17	13	8	10	12	17	34	43	40	28	28	15	(15)
(16)		PrecMax	360	94	36	25	45	47	53	78	98	188	89	63	51	(16)
(17)		PrecMin	125	0	0	1	1	2	0	2	12	2	6	3	1	(17)
(18)		PrecStd	68	17	9	6	9	10	11	20	25	40	18	15	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.8	-5.7	0.9	1.3	7.7	17.1	21.2	18.2	14.6	3.5	0.7	-0.3	(19)
(20)			MCWB	-4.2	-6.3	-1.7	0.2	4.6	11.0	14.2	12.4	9.4	2.3	-0.1	-1.1	(20)
(21)		2%	DB	-11.6	-10.7	-3.2	-1.6	4.7	13.3	16.7	14.0	10.2	1.7	-1.2	-3.8	(21)
(22)			MCWB	-12.1	-11.1	-4.2	-2.4	2.5	9.2	11.8	10.9	7.5	0.8	-1.7	-4.6	(22)
(23)		5%	DB	-14.8	-14.6	-7.4	-5.0	2.9	10.4	13.3	11.6	7.4	0.6	-2.7	-7.2	(23)
(24)			MCWB	-15.1	-15.0	-8.0	-5.7	1.6	7.5	10.4	9.3	5.9	-0.2	-3.1	-7.9	(24)
(25)		10%	DB	-17.3	-18.0	-11.9	-7.9	1.4	7.6	10.1	9.3	5.6	0.0	-4.8	-11.3	(25)
(26)			MCWB	-17.5	-18.3	-12.3	-8.5	0.5	5.5	8.1	7.8	4.8	-0.7	-5.5	-11.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.2	-6.6	-1.4	0.4	4.7	11.4	14.3	13.1	10.1	2.5	0.1	-1.2	(27)
(28)			MCDWB	-3.6	-5.8	0.3	1.1	7.7	15.9	19.5	17.0	13.8	3.3	0.4	0.0	(28)
(29)		2%	WB	-12.0	-11.1	-4.2	-2.3	2.7	9.3	12.2	11.0	7.6	1.0	-1.7	-4.5	(29)
(30)			MCDWB	-11.6	-10.8	-3.3	-1.5	4.5	13.1	16.2	14.1	9.8	1.6	-1.3	-3.8	(30)
(31)		5%	WB	-15.0	-14.9	-8.0	-5.7	1.6	7.4	10.3	9.4	6.1	0.0	-3.1	-7.9	(31)
(32)			MCDWB	-14.8	-14.6	-7.4	-4.9	2.7	10.3	13.5	11.6	7.2	0.4	-2.7	-7.3	(32)
(33)		10%	WB	-17.5	-18.3	-12.3	-8.5	0.6	5.6	8.3	7.7	4.8	-0.7	-5.4	-11.6	(33)
(34)			MCDWB	-17.2	-18.0	-11.9	-8.0	1.4	7.6	10.0	9.2	5.4	-0.1	-4.9	-11.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	5.6	6.8	7.4	5.1	4.5	5.0	4.2	3.5	4.5	5.3	5.1	(35)
(36)			MCDBR	8.7	11.1	11.1	9.0	7.1	9.8	12.3	10.1	7.6	4.3	5.9	7.7	(36)
(37)			MCWBR	8.4	10.8	10.3	8.2	5.3	6.2	8.1	6.9	5.3	3.7	5.7	7.4	(37)
(38)		5% WB	MCDBR	8.4	11.1	11.2	8.6	6.5	9.5	11.7	9.6	6.7	3.6	5.8	7.6	(38)
(39)			MCWBR	8.1	10.8	10.4	7.8	5.0	6.2	8.1	6.8	4.8	3.4	5.6	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.164	0.222	0.261	0.318	0.355	0.346	0.352	0.346	0.305	0.239	0.170	N/A	(40)	
(41)		taud	1.900	2.032	2.146	2.014	2.022	2.293	2.436	2.468	2.476	2.180	1.925	N/A	(41)	
(42)		Ebn at Noon	71	549	766	805	816	847	832	794	735	526	51	0	(42)	
(43)		Edh at Noon	5	45	78	122	138	109	92	80	59	37	4	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.02	0.42	2.12	4.45	6.02	6.27	4.83	3.22	1.73	0.50	0.07	0.00	(44)	
(45)		RadStd	0.00	0.05	0.14	0.22	0.29	0.37	0.49	0.36	0.17	0.07	0.01	0.00	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page