

ILIRNEY, Russian Federation

WMO: 252480

Lat: 67.256N

Lon: 167.962E

Elev: 1160

StdP: 14.09

Time Zone: 12.00 (E12)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -57.4	(c) -54.3	(d) -61.7	(e) 0.1	(f) -56.4	(g) -58.6	(h) 0.2	(i) -54.1	(j) 20.5	(k) 15.5	(l) 18.6	(m) 5.2	(n) 0.0	(o) 130	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	77.2	59.1	73.0	57.4	69.1	55.7	61.4	72.7	59.3	69.8	57.1	66.1	5.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	73.4	64.4	54.7	66.5	62.2	52.2	60.5	61.1	27.9	73.0	26.5	70.0	25.0	66.2	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	14.6	12.7	-61.7	82.9	4.0	4.1	-64.7	85.8	-67.0	88.2	-69.3	90.5	-72.2	93.5
			-61.7	65.4	3.8	3.5	-64.4	67.9	-66.7	70.0	-68.8	71.9	-71.6	74.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-28.8	-25.8	-14.2	4.9	30.3	51.6	55.0	49.4	37.2	13.6	-9.6	-22.3
	DBStd	33.34	17.95	16.65	14.67	12.46	11.05	7.65	7.30	7.20	7.73	13.66	16.48	18.14
	HDD50	14276	2442	2122	1990	1354	614	75	34	99	389	1128	1788	2241
	HDD65	19358	2907	2542	2455	1804	1076	404	316	483	834	1593	2238	2706
	CDD50	400	0	0	0	0	2	122	189	82	5	0	0	0
	CDD65	9	0	0	0	0	0	1	7	1	0	0	0	0
	CDH74	211	0	0	0	0	0	51	145	15	0	0	0	0
	CDH80	26	0	0	0	0	0	4	19	3	0	0	0	0
Wind	WSAvg	3.7	2.5	2.1	3.4	3.5	5.0	5.1	4.6	4.6	4.4	3.2	3.2	2.5
Precipitation	PrecAvg	7.5	0.4	0.4	0.4	0.2	0.3	0.7	1.0	1.1	0.7	0.8	0.7	0.5
	PrecMax	11.7	1.4	1.7	1.1	0.8	0.8	2.0	2.6	3.6	1.9	3.2	1.7	1.3
	PrecMin	3.7	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.2	0.1	0.1	0.0	0.0
	PrecStd	2.2	0.3	0.4	0.3	0.2	0.2	0.4	0.6	0.7	0.4	0.7	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.3	30.7	31.4	36.9	64.9	80.6	84.4	75.6	67.3	45.0	31.0	28.1
		MCWB	27.4	28.8	28.9	31.0	48.8	57.9	62.2	59.2	52.4	42.5	29.4	26.7
	2%	DB	21.5	19.4	23.9	32.8	56.7	75.4	79.6	71.1	59.1	38.0	27.2	20.6
		MCWB	19.7	18.0	21.6	28.3	44.9	55.8	61.2	57.0	48.4	36.1	25.5	19.0
	5%	DB	10.1	8.7	16.2	29.7	51.3	71.8	75.2	67.6	54.6	34.6	22.4	14.4
		MCWB	8.9	7.6	14.7	26.0	42.3	55.6	59.2	55.0	46.4	32.8	21.1	13.2
	10%	DB	-3.1	0.0	8.0	26.0	46.3	67.9	70.2	63.5	50.2	31.4	17.0	4.4
		MCWB	-3.8	-0.6	6.3	23.1	39.4	53.6	57.3	53.6	44.1	29.9	16.2	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.8	29.1	32.4	49.2	61.4	66.2	63.1	53.5	42.5	29.9	26.5
		MCDB	29.1	29.4	31.1	36.6	62.5	75.2	77.7	70.9	63.8	45.0	31.2	28.3
	2%	WB	20.1	18.0	21.7	28.5	45.6	58.1	62.7	59.4	50.5	36.5	25.6	19.0
		MCDB	21.3	19.4	23.8	32.4	55.7	70.6	74.0	67.8	57.1	38.0	27.2	20.6
	5%	WB	9.1	7.6	14.4	26.1	42.5	56.0	60.7	56.7	47.4	33.1	21.1	13.1
		MCDB	10.4	8.6	16.0	29.5	50.8	69.4	72.2	64.5	53.2	34.5	22.5	14.5
	10%	WB	-3.7	-0.6	6.3	23.0	39.6	54.3	58.8	54.6	44.7	29.9	16.1	3.6
		MCDB	-3.1	0.0	7.9	25.8	46.0	67.0	69.0	62.4	49.9	31.5	17.0	4.4
Mean Daily Temperature Range	5% DB	MDBR	14.5	17.7	23.6	27.1	17.6	19.5	18.2	19.7	16.0	14.2	15.7	14.8
		MCDBR	22.8	20.5	20.9	24.7	22.8	28.6	28.4	27.7	26.3	9.3	15.7	22.7
		MCWBR	21.9	20.1	18.9	21.2	13.3	13.7	13.3	14.8	16.3	7.5	15.0	22.0
	5% WB	MCDBR	22.6	20.0	20.3	23.7	22.1	25.6	22.7	22.5	22.1	8.7	16.8	22.1
		MCWBR	21.8	19.6	19.0	20.5	13.4	13.6	13.0	13.6	15.3	7.2	16.2	21.4
Clear-Sky Solar Irradiance	taub	0.155	0.219	0.284	0.333	0.370	0.357	0.404	0.384	0.303	0.245	0.172	N/A	
	taud	1.931	2.124	2.087	1.991	2.055	2.382	2.257	2.273	2.451	2.162	1.920	N/A	
	Ebn at Noon	71	202	238	254	258	269	248	239	240	180	51	0	
	Edh at Noon	3	15	28	41	43	32	36	31	20	14	3	0	
All-Sky Solar Radiation	RadAvg	16	186	750	1496	1839	1738	1525	1138	627	238	39	0	
	RadStd	2	23	51	53	136	116	161	116	61	29	4	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page