

EGVEKINOT, Russian Federation

WMO: 253780

Lat: 66.3582N

Lon: 179.1130W

Elev: 26

StdP: 101.01

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.3	-31.1	-35.9	0.1	-32.6	-33.9	0.2	-30.8	20.3	-20.2	18.0	-17.3	0.6	350	0.917

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	18.2	12.8	16.1	11.6	14.4	10.8	13.6	16.9	12.5	15.0	11.5	13.6	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	8.8	14.4	11.2	8.3	13.3	10.3	7.8	12.3	38.3	17.1	35.4	15.0	33.0	13.8	19.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	13.0	11.3	DB	-34.5	23.1	3.4	3.4	-37.0	25.5	-39.0	27.5	-40.9	29.5	-43.4	32.0	
			WB	-34.8	15.6	3.3	2.0	-37.1	17.1	-39.0	18.2	-40.9	19.3	-43.2	20.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.6	-17.9	-16.7	-16.3	-9.8	-0.6	6.6	10.6	9.6	5.1	-2.2	-9.6	-14.9
	DBStd	11.79	7.94	7.86	6.99	5.75	3.98	3.37	2.63	2.43	3.30	4.53	6.18	7.42
	HDD10.0	5407	866	749	815	593	329	111	23	36	149	378	588	772
	HDD18.3	8372	1124	982	1073	843	587	351	240	270	397	637	838	1030
	CDD10.0	78	0	0	0	0	1	9	41	24	2	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	7	0	0	0	0	0	1	6	0	0	0	0	0
	CDH26.7	2	0	0	0	0	0	1	1	0	0	0	0	0
Wind	WSAvg	4.5	5.7	5.6	4.4	4.4	3.7	3.3	3.7	3.7	3.7	4.8	4.7	6.1
Precipitation	PrecAvg	389	23	20	9	15	16	38	82	71	50	23	31	14
	PrecMax	857	67	131	52	61	52	92	198	166	261	97	152	70
	PrecMin	253	3	1	0	0	1	10	24	13	0	1	0	0
	PrecStd	131	17	23	10	15	14	21	46	35	58	23	36	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.4	0.6	0.3	3.0	12.5	20.3	22.7	19.8	14.0	9.6	3.8	2.2
		MCWB	-0.6	-0.8	-0.4	0.4	8.4	12.0	15.1	14.4	9.0	7.3	2.3	0.4
	2%	DB	-0.4	-0.7	-0.9	1.5	8.8	16.8	18.7	16.9	12.1	7.2	2.2	0.4
		MCWB	-1.3	-1.5	-1.5	-0.4	5.3	10.4	13.4	12.5	8.8	5.3	1.0	-0.9
	5%	DB	-2.8	-2.3	-2.6	0.1	6.6	14.2	16.6	14.8	10.8	5.2	0.8	-1.6
		MCWB	-4.2	-3.3	-3.5	-1.2	3.7	9.4	12.4	11.2	8.2	3.4	-0.2	-2.8
	10%	DB	-6.3	-4.6	-4.8	-1.4	4.5	12.1	14.9	13.4	9.7	3.4	-0.8	-3.8
		MCWB	-7.5	-5.6	-5.8	-2.8	2.3	8.2	11.5	10.6	7.4	1.5	-1.9	-5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.2	-0.1	-0.1	1.1	8.5	12.9	15.6	15.3	10.7	7.7	2.6	1.0
		MCDB	0.5	0.3	0.2	2.4	12.5	18.9	20.2	18.7	12.3	9.2	3.5	1.9
	2%	WB	-1.5	-1.5	-1.4	0.0	5.7	11.0	14.1	13.2	9.6	5.6	1.2	-0.7
		MCDB	-0.3	-0.9	-1.0	1.0	8.5	15.5	17.9	15.7	11.0	7.0	2.0	0.2
	5%	WB	-4.1	-3.3	-3.2	-1.1	3.9	9.8	13.0	12.2	8.8	3.6	-0.2	-2.8
		MCDB	-3.0	-2.5	-2.6	0.1	6.2	13.5	15.8	14.0	10.1	4.9	0.6	-1.6
	10%	WB	-7.6	-5.6	-5.9	-2.8	2.5	8.6	12.0	11.3	7.8	1.7	-1.8	-4.9
		MCDB	-6.3	-4.5	-4.7	-1.3	4.2	11.7	14.3	12.7	9.2	3.1	-0.7	-3.8
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.3	6.7	6.6	4.9	6.2	5.2	4.8	4.7	3.8	4.6	5.0
		MCDBR	7.9	7.0	6.2	6.1	7.9	10.8	8.9	7.5	6.0	3.6	3.9	6.4
		MCWBR	7.3	6.6	6.1	5.0	5.2	6.1	5.1	4.8	4.0	2.9	3.8	5.9
	5% WB	MCDBR	8.0	6.8	6.0	5.6	7.6	9.8	7.8	6.2	4.9	3.2	3.8	6.2
		MCWBR	7.6	6.6	6.1	4.8	5.0	6.0	4.9	4.4	3.8	2.8	3.8	5.9
Clear-Sky Solar Irradiance	taub	0.170	0.247	0.274	0.336	0.370	0.363	0.365	0.370	0.306	0.265	0.181	0.176	
	taud	1.904	2.075	2.172	2.011	2.041	2.326	2.436	2.384	2.499	2.208	1.911	1.897	
	Ebn at Noon	260	602	787	806	817	843	831	782	768	575	213	24	
	Edh at Noon	16	55	83	129	139	108	95	90	63	47	15	3	
All-Sky Solar Radiation	RadAvg	0.08	0.66	2.40	4.67	5.64	5.32	4.62	3.43	2.06	0.71	0.16	0.01	
	RadStd	0.01	0.08	0.19	0.17	0.51	0.50	0.59	0.39	0.21	0.11	0.02	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page