

MYS UELEN, Russian Federation

WMO: 253990

Lat: 66.162N

Lon: 169.833W

Elev: 23

StdP: 14.68

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.9	-24.2	-33.4	0.8	-28.6	-28.9	1.1	-24.1	52.3	26.5	41.0	25.8	5.0	210	1.075

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	58.1	52.6	54.8	50.8	52.2	49.2	53.2	57.2	51.1	54.3	49.4	52.0	14.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.6	54.7	55.4	48.9	51.2	53.1	47.4	48.5	51.3	22.1	57.4	20.9	54.4	20.0	52.2	62.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
39.0	34.9	31.0	DB	-30.7	63.1	5.6	4.4	-34.7	66.2	-38.0	68.8	-41.2	71.2	-45.3	74.4
			WB	-31.3	55.8	5.4	3.0	-35.2	58.0	-38.4	59.8	-41.5	61.5	-45.4	63.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.9	-2.1	-1.7	-1.6	10.3	27.4	37.9	45.1	44.9	39.9	31.9	21.3	7.5
	DBStd	20.52	14.16	15.92	13.54	11.63	7.38	5.37	5.04	4.09	4.63	6.60	9.99	14.08
	HDD50	10296	1616	1448	1600	1191	699	365	167	167	305	560	860	1318
	HDD65	15743	2081	1868	2065	1641	1164	812	616	624	754	1025	1310	1783
	CDD50	30	0	0	0	0	0	4	17	8	1	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.7	12.6	12.9	11.4	11.0	10.8	12.5	14.1	14.4	15.1	16.4	17.5	16.2
Precipitation	PrecAvg	12.0	0.7	0.7	0.5	0.6	0.6	0.6	1.3	1.9	1.5	1.7	1.0	0.8
	PrecMax	17.8	1.8	1.8	1.8	2.6	1.7	1.3	3.5	4.4	5.2	3.7	2.2	2.4
	PrecMin	6.3	0.0	0.1	0.0	0.1	0.1	0.0	0.2	0.2	0.4	0.4	0.0	0.0
	PrecStd	3.1	0.4	0.4	0.4	0.6	0.5	0.4	0.9	1.1	1.0	1.0	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.4	36.0	33.5	38.0	42.9	61.2	65.2	59.8	54.9	48.3	40.2	37.6
		MCWB	32.7	34.1	31.8	35.0	38.9	53.6	55.8	54.6	50.4	45.1	38.2	34.6
	2%	DB	31.5	32.1	31.1	34.0	39.0	53.6	60.0	55.7	51.2	43.8	36.8	32.8
		MCWB	30.1	30.4	29.6	32.3	36.5	48.8	53.6	51.9	48.4	41.6	35.1	31.1
	5%	DB	27.7	30.0	27.7	31.7	36.4	49.3	56.4	53.2	48.7	41.5	34.9	30.5
		MCWB	26.6	28.5	26.3	30.4	34.6	45.8	51.5	50.4	46.8	39.8	33.5	29.2
	10%	DB	20.0	25.5	21.4	28.6	34.7	45.7	53.3	51.1	46.6	39.6	33.4	27.7
		MCWB	18.8	24.2	20.0	27.4	33.2	43.0	50.0	48.8	44.7	38.0	32.1	26.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.9	34.2	32.0	35.1	39.3	53.9	56.8	55.1	50.7	45.1	38.6	35.1
		MCDB	34.1	35.8	33.3	37.2	42.2	59.9	62.7	58.7	53.7	48.2	40.0	37.3
	2%	WB	30.2	30.7	29.8	32.6	36.8	49.2	54.2	52.3	48.6	42.0	35.3	31.3
		MCDB	31.5	32.1	31.0	34.1	38.8	53.2	59.3	55.1	50.6	43.7	36.4	32.6
	5%	WB	26.5	28.5	26.3	30.4	34.8	45.8	51.9	50.4	47.1	39.9	33.6	29.2
		MCDB	27.6	30.1	27.7	31.7	36.1	49.0	55.6	52.7	48.7	41.4	34.7	30.6
	10%	WB	18.5	24.2	20.0	27.3	33.3	43.2	50.0	49.0	44.8	38.1	32.1	26.4
		MCDB	19.7	25.5	21.3	28.6	34.4	45.5	53.2	50.9	46.5	39.5	33.4	27.7
Mean Daily Temperature Range		MDBR	9.4	9.9	10.5	9.8	5.8	6.6	7.9	5.8	4.6	5.0	7.7	8.4
		MCDBR	13.6	12.5	11.4	9.1	7.6	13.1	14.4	10.3	7.9	5.6	6.2	9.2
		MCWBR	13.2	12.1	11.0	8.6	6.0	9.1	9.5	7.8	6.0	4.8	5.9	8.8
	5% WB	MCDDBR	13.6	12.5	11.3	9.0	7.0	12.5	12.6	9.8	7.8	5.0	6.1	9.4
		MCWBR	13.1	12.1	11.1	8.5	5.8	8.9	8.9	7.7	6.2	4.6	6.0	9.0
Clear-Sky Solar Irradiance	taub	0.161	0.243	0.276	0.329	0.369	0.352	0.370	0.385	0.322	0.282	0.373	0.182	
	taud	1.903	2.068	2.103	1.992	2.103	2.453	2.445	2.337	2.488	2.277	2.706	1.903	
	Ebn at Noon	94	194	247	259	260	272	263	242	238	180	73	9	
	Edh at Noon	5	17	29	42	42	30	30	30	21	15	6	1	
All-Sky Solar Radiation	RadAvg	28	213	770	1406	1605	1740	1446	1033	613	203	39	3	
	RadStd	3	29	68	100	209	126	134	114	60	23	5	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page