

MYS UELEN, Russian Federation

WMO: 253990

Lat: 66.162N

Lon: 169.833W

Elev: 7

StdP: 101.24

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.8	-31.2	-36.3	0.1	-33.7	-33.8	0.2	-31.1	23.4	-3.1	18.3	-3.5	2.2	210	1.075

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 4.4	(c) 14.5	(d) 11.4	(e) 12.7	(f) 10.4	(g) 11.2	(h) 9.6	(i) 11.8	(j) 14.0	(k) 10.6	(l) 12.4	(m) 9.7	(n) 11.1	(o) 6.7	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	7.8	13.0	9.4	7.3	11.7	8.6	6.9	10.7	33.6	14.1	30.8	12.5	28.6	11.2	17.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	15.6	13.9	-34.8	17.3	3.1	2.4	-37.1	19.0	-38.9	20.4	-40.7	21.8	-42.9	23.6
			-35.2	13.2	3.0	1.7	-37.3	14.4	-39.1	15.4	-40.8	16.4	-43.0	17.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.6	-19.0	-18.7	-18.7	-12.1	-2.5	3.3	7.3	7.1	4.4	0.0	-5.9	-13.6		
	DBStd	11.40	7.87	8.84	7.52	6.46	4.10	2.99	2.80	2.27	2.57	3.67	5.55	7.82		
	HDD10.0	5720	898	804	889	662	388	203	93	93	169	311	478	732		
	HDD18.3	8746	1156	1038	1147	912	647	451	342	347	419	569	728	991		
	CDD10.0	17	0	0	0	0	0	2	9	4	1	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	6.1	5.6	5.8	5.1	4.9	4.8	5.6	6.3	6.4	6.8	7.3	7.8	7.3		
(15) Precipitation	PrecAvg	304	19	19	13	15	14	15	34	48	38	44	25	20		
	PrecMax	452	46	45	45	67	44	33	88	111	131	93	57	61		
	PrecMin	160	1	3	0	2	2	1	4	6	10	11	1	0		
	PrecStd	80	11	10	9	14	12	9	22	28	25	25	14	16		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.3	2.2	0.9	3.4	6.0	16.2	18.5	15.5	12.7	9.1	4.6	3.1		
		MCWB	0.4	1.2	-0.1	1.7	3.9	12.0	13.2	12.6	10.2	7.3	3.4	1.4		
	2%	DB	-0.3	0.1	-0.5	1.1	3.9	12.0	15.5	13.2	10.6	6.6	2.6	0.4		
		MCWB	-1.1	-0.9	-1.3	0.2	2.5	9.4	12.0	11.1	9.1	5.3	1.7	-0.5		
	5%	DB	-2.4	-1.1	-2.4	-0.2	2.5	9.6	13.5	11.8	9.3	5.3	1.6	-0.8		
		MCWB	-3.0	-1.9	-3.2	-0.9	1.4	7.7	10.8	10.2	8.2	4.3	0.8	-1.6		
	10%	DB	-6.7	-3.6	-5.9	-1.9	1.5	7.6	11.8	10.6	8.1	4.2	0.8	-2.4		
		MCWB	-7.3	-4.3	-6.7	-2.6	0.6	6.1	10.0	9.3	7.1	3.3	0.0	-3.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.5	1.2	0.0	1.7	4.1	12.2	13.8	12.8	10.4	7.3	3.6	1.7		
		MCDB	1.1	2.1	0.7	2.9	5.6	15.5	17.1	14.8	12.0	9.0	4.4	2.9		
	2%	WB	-1.0	-0.7	-1.2	0.3	2.6	9.6	12.3	11.3	9.2	5.6	1.8	-0.4		
		MCDB	-0.3	0.1	-0.6	1.1	3.8	11.8	15.1	12.9	10.3	6.5	2.5	0.3		
	5%	WB	-3.1	-1.9	-3.1	-0.9	1.5	7.6	11.0	10.2	8.4	4.4	0.9	-1.6		
		MCDB	-2.4	-1.1	-2.4	-0.2	2.3	9.5	13.1	11.5	9.3	5.2	1.5	-0.8		
	10%	WB	-7.5	-4.4	-6.7	-2.6	0.7	6.2	10.0	9.4	7.1	3.4	0.0	-3.1		
		MCDB	-6.8	-3.6	-5.9	-1.9	1.3	7.5	11.8	10.5	8.0	4.2	0.8	-2.4		
(35) Mean Daily Temperature Range	MDBR		5.2	5.5	5.8	5.4	3.2	3.7	4.4	3.2	2.5	2.8	4.3	4.6		
	5% DB	MCDBR	7.5	6.9	6.4	5.1	4.2	7.3	8.0	5.7	4.4	3.1	3.4	5.1		
		MCWBR	7.3	6.7	6.1	4.8	3.4	5.1	5.3	4.3	3.4	2.7	3.3	4.9		
	5% WB	MCDBR	7.5	7.0	6.3	5.0	3.9	6.9	7.0	5.5	4.3	2.8	3.4	5.2		
		MCWBR	7.3	6.7	6.1	4.7	3.2	4.9	5.0	4.3	3.4	2.6	3.3	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.161	0.243	0.276	0.329	0.369	0.352	0.370	0.385	0.322	0.282	0.373	0.182		
	taud		1.903	2.068	2.103	1.992	2.103	2.453	2.445	2.337	2.488	2.277	2.706	1.903		
	Ebn at Noon		295	613	779	815	821	858	828	764	749	568	231	29		
	Edh at Noon		17	55	90	131	132	96	94	95	65	46	19	4		
(44) All-Sky Solar Radiation	RadAvg		0.09	0.67	2.43	4.43	5.06	5.48	4.56	3.26	1.93	0.64	0.12	0.01		
	RadStd		0.01	0.09	0.21	0.31	0.66	0.40	0.42	0.36	0.19	0.07	0.01	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page