

OMOLON, Russian Federation

WMO: 254280

Lat: 65.240N

Lon: 160.542E

Elev: 854

StdP: 14.25

Time Zone: 12.00 (E12)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -58.2	(c) -55.7	(d) -63.2	(e) 0.1	(f) -57.7	(g) -60.2	(h) 0.1	(i) -55.1	(j) 14.5	(k) 0.5	(l) 12.7	(m) -1.0	(n) 0.0	(o) 120	(p) 0.782

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	79.3	62.0	75.1	59.4	71.5	57.3	64.0	76.0	61.4	72.0	59.1	68.7	4.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.1	77.2	70.0	56.6	70.5	66.5	54.3	64.6	63.8	29.8	76.2	27.9	72.4	26.2	68.6	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.6	11.1	-61.1	85.1	3.1	3.5	-63.3	87.6	-65.1	89.7	-66.9	91.7	-69.1	94.2
			-61.6	66.7	3.7	2.7	-64.3	68.7	-66.5	70.3	-68.6	71.8	-71.3	73.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-34.3	-30.0	-10.1	10.0	37.0	53.3	58.2	52.1	39.6	15.4	-10.2	-27.4		
	DBStd	35.71	16.53	16.01	16.62	13.45	9.33	6.91	7.53	6.59	7.82	12.44	16.52	18.23		
	HDD50	14050	2614	2239	1863	1201	415	44	17	55	322	1072	1807	2401		
	HDD65	18997	3079	2659	2328	1651	869	354	233	401	763	1537	2257	2866		
	CDD50	555	0	0	0	0	11	142	272	121	9	0	0	0		
	CDD65	26	0	0	0	0	0	2	23	1	0	0	0	0		
	CDH74	410	0	0	0	0	1	60	320	29	0	0	0	0		
	CDH80	72	0	0	0	0	0	7	64	1	0	0	0	0		
	Wind	WSAvg	3.8	1.3	2.0	3.2	4.2	5.6	4.9	4.5	4.7	4.2	2.6	2.2		
	(15) Precipitation	PrecAvg	10.2	0.6	0.5	0.3	0.3	0.4	1.1	1.9	1.7	1.1	0.8	0.6		
		PrecMax	15.2	1.7	1.1	0.9	0.9	1.3	2.5	5.0	3.7	3.2	2.0	1.3		
		PrecMin	6.8	0.0	0.1	0.0	0.0	0.0	0.1	0.4	0.0	0.3	0.2	0.2		
		PrecStd	1.8	0.4	0.3	0.2	0.2	0.3	0.6	1.0	0.8	0.6	0.4	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	28.1	34.1	41.6	68.8	80.6	86.4	77.6	67.6	43.1	37.4	35.4		
		MCWB	26.2	25.8	30.6	34.6	51.4	60.2	65.2	61.0	53.3	37.2	34.1	32.2		
	2%	DB	16.9	13.7	27.9	37.6	63.6	75.6	81.8	73.2	61.1	37.7	31.5	18.9		
		MCWB	14.9	11.9	24.7	32.1	48.8	56.3	63.6	58.8	49.9	34.1	28.6	17.4		
	5%	DB	-4.2	-2.2	21.4	34.8	58.6	72.2	78.3	69.6	56.7	34.3	23.3	7.1		
		MCWB	-4.9	-2.9	18.6	30.0	46.2	55.5	62.3	57.0	47.8	32.0	21.6	6.2		
	10%	DB	-13.2	-8.3	15.3	31.5	52.9	68.7	74.1	66.1	52.6	31.6	14.2	-2.3		
		MCWB	-13.6	-8.9	13.0	27.3	42.7	54.1	60.3	55.3	46.0	29.6	13.3	-3.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	25.5	31.1	35.1	53.0	62.6	67.8	63.7	54.3	38.2	34.0	31.7		
		MCDB	29.3	27.6	34.0	40.2	66.0	76.5	82.7	73.5	64.8	42.1	37.5	35.3		
	2%	WB	14.8	11.4	24.8	32.6	49.3	58.4	65.5	60.5	51.0	34.6	28.7	17.6		
		MCDB	17.0	13.5	27.9	37.5	62.9	71.4	78.1	69.7	58.4	37.2	31.5	19.4		
	5%	WB	-4.9	-3.0	18.9	30.0	46.3	56.5	63.6	58.3	48.9	32.3	21.5	6.1		
		MCDB	-4.3	-2.3	21.6	34.5	57.8	69.2	75.3	67.1	55.4	34.2	23.1	7.1		
	10%	WB	-13.6	-8.8	13.0	27.5	43.1	54.7	61.4	56.5	46.6	29.6	13.2	-2.9		
		MCDB	-13.2	-8.2	15.2	31.4	52.2	66.7	71.8	64.7	51.9	31.5	14.2	-2.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	15.9	24.4	25.9	17.3	19.3	19.4	20.3	15.9	12.9	14.0	12.9		
		MCDBR	22.2	20.5	21.3	20.3	25.9	27.3	27.9	29.0	24.9	13.1	17.8	23.6		
		MCWBR	21.2	18.7	18.7	15.7	14.3	12.3	12.8	15.4	15.0	9.8	16.3	22.6		
		MCDBR	22.7	20.0	20.8	19.3	24.7	24.3	24.5	24.4	22.1	11.1	17.2	23.5		
	5% WB	MCWBR	21.6	18.8	18.3	15.0	13.9	12.0	12.4	13.7	13.7	8.6	15.8	22.5		
(40) Clear-Sky Solar Irradiance	taub		0.159	0.232	0.291	0.346	0.383	0.369	0.440	0.422	0.316	0.264	0.178	0.165		
	taud		1.927	2.139	2.085	1.967	2.100	2.370	2.161	2.158	2.450	2.228	1.925	1.918		
	Ebn at Noon		121	214	244	254	257	267	239	230	242	195	98	31		
	Edh at Noon		7	17	30	43	43	33	40	36	22	16	6	2		
(44) All-Sky Solar Radiation	RadAvg		41	278	856	1627	1814	1714	1568	1169	659	300	75	10		
	RadStd		5	22	37	49	171	165	139	116	83	40	9	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page