

OMOLON, Russian Federation

WMO: 254280

Lat: 65.240N

Lon: 160.542E

Elev: 260

StdP: 98.24

Time Zone: 12.00 (E12)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-50.1	-48.7	-52.9	0.0	-49.8	-51.2	0.0	-48.4	6.5	-17.5	5.7	-18.3	0.0	120	0.782

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	26.3	16.7	24.0	15.2	21.9	14.1	17.8	24.5	16.4	22.2	15.0	20.4	1.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	11.0	21.1	13.7	10.1	19.2	12.4	9.2	17.7	51.3	24.5	47.0	22.5	43.1	20.3	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.6	4.9	-51.7	29.5	1.7	1.9	-53.0	30.9	-54.0	32.0	-54.9	33.1	-56.2	34.6		
			DB	WB	-52.0	19.3	2.1	1.5	-53.5	20.4	-54.7	21.3	-55.9	22.1	-57.4	23.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.5	-36.9	-34.4	-23.4	-12.2	2.8	11.8	14.6	11.2	4.2	-9.2	-23.5	-33.0
	DBStd	19.84	9.18	8.89	9.23	7.47	5.18	3.84	4.18	3.66	4.34	6.91	9.18	10.13
	HDD10.0	7806	1452	1244	1035	667	231	24	9	31	179	596	1004	1334
	HDD18.3	10554	1711	1477	1293	917	483	197	129	223	424	854	1254	1592
	CDD10.0	308	0	0	0	0	6	79	151	67	5	0	0	0
	CDD18.3	14	0	0	0	0	0	1	13	1	0	0	0	0
	CDH23.3	228	0	0	0	0	1	33	178	16	0	0	0	0
	CDH26.7	40	0	0	0	0	0	4	36	1	0	0	0	0
Wind	WSAvg	1.7	0.6	0.9	1.4	1.9	2.5	2.5	2.2	2.0	2.1	1.9	1.2	1.0
Precipitation	PrecAvg	259	16	12	8	8	11	27	47	44	27	20	20	16
	PrecMax	385	42	29	24	22	32	64	128	93	81	50	56	33
	PrecMin	172	0	2	0	0	0	0	2	9	1	7	6	4
	PrecStd	46	11	7	6	5	8	16	26	20	16	10	12	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.4	-2.2	1.2	5.4	20.4	27.0	30.2	25.3	19.8	6.2	3.0	1.9
		MCWB	-3.2	-3.5	-0.8	1.5	10.8	15.7	18.4	16.1	11.8	2.9	1.1	0.1
	2%	DB	-8.4	-10.2	-2.3	3.1	17.6	24.2	27.7	22.9	16.2	3.2	-0.3	-7.3
		MCWB	-9.5	-11.1	-4.0	0.0	9.4	13.5	17.5	14.9	10.0	1.1	-1.9	-8.1
	5%	DB	-20.1	-19.0	-5.9	1.6	14.8	22.3	25.7	20.9	13.7	1.3	-4.8	-13.8
		MCWB	-20.5	-19.4	-7.4	-1.1	7.9	13.1	16.9	13.9	8.8	0.0	-5.8	-14.3
	10%	DB	-25.1	-22.4	-9.3	-0.3	11.6	20.4	23.4	18.9	11.5	-0.2	-9.9	-19.1
		MCWB	-25.3	-22.7	-10.5	-2.6	6.0	12.3	15.7	13.0	7.8	-1.3	-10.4	-19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.3	-3.6	-0.5	1.7	11.7	17.0	19.9	17.6	12.4	3.4	1.1	-0.2
		MCDB	-1.5	-2.5	1.1	4.6	18.9	24.7	28.2	23.1	18.2	5.6	3.0	1.8
	2%	WB	-9.5	-11.4	-4.0	0.4	9.6	14.7	18.6	15.8	10.6	1.4	-1.8	-8.0
		MCDB	-8.3	-10.3	-2.3	3.0	17.2	21.9	25.6	20.9	14.7	2.9	-0.3	-7.0
	5%	WB	-20.5	-19.4	-7.3	-1.1	8.0	13.6	17.5	14.6	9.4	0.2	-5.8	-14.4
		MCDB	-20.2	-19.1	-5.8	1.4	14.3	20.6	24.1	19.5	13.0	1.2	-4.9	-13.8
	10%	WB	-25.3	-22.7	-10.6	-2.5	6.2	12.6	16.3	13.6	8.1	-1.4	-10.4	-19.4
		MCDB	-25.1	-22.3	-9.3	-0.3	11.2	19.3	22.1	18.2	11.1	-0.3	-9.9	-19.0
Mean Daily Temperature Range	5% DB	MDBR	7.0	8.8	13.6	14.4	9.6	10.7	10.8	11.3	8.8	7.2	7.8	7.2
		MCDBR	12.4	11.4	11.8	11.3	14.4	15.2	15.5	16.1	13.8	7.3	9.9	13.1
		MCWBR	11.8	10.4	10.4	8.7	7.9	6.8	7.1	8.5	8.3	5.4	9.1	12.5
	5% WB	MCDBR	12.6	11.1	11.6	10.7	13.7	13.5	13.6	13.6	12.3	6.1	9.6	13.1
		MCWBR	12.0	10.4	10.2	8.3	7.7	6.7	6.9	7.6	7.6	4.8	8.8	12.5
Clear-Sky Solar Irradiance	taub		0.159	0.232	0.291	0.346	0.383	0.369	0.440	0.422	0.316	0.264	0.178	0.165
	taud		1.927	2.139	2.085	1.967	2.100	2.370	2.161	2.158	2.450	2.228	1.925	1.918
	Ebn at Noon		382	674	768	801	811	843	755	724	763	614	309	97
	Edh at Noon		21	55	95	137	134	105	126	115	68	50	20	6
All-Sky Solar Radiation	RadAvg		0.13	0.88	2.70	5.13	5.72	5.40	4.94	3.69	2.08	0.95	0.23	0.03
	RadStd		0.01	0.07	0.12	0.15	0.54	0.52	0.44	0.36	0.26	0.13	0.03	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page