

KEDON, Russian FederationWMO: **256210**Lat: **64.000N**Lon: **158.917E**Elev: **2241**StdP: **13.54**Time Zone: **11.00 (E11)**Period: **90-00**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -55.5	(c) -52.8	(d) -58.4	(e) 0.2	(f) -55.3	(g) -55.4	(h) 0.2	(i) -52.4	(j) 21.1	(k) 16.4	(l) 14.8	(m) 17.0	(n) 1.5	(o) 200	(p) 0.852

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	75.7	59.6	71.7	57.6	67.8	55.4	61.2	73.0	58.9	69.9	56.4	65.7	5.3	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.1	72.7	64.1	53.8	66.9	63.5	51.7	61.7	61.2	28.3	74.0	26.7	69.9	25.0	65.4	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.5	(b) 12.0	(c) 9.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-29.4	-28.2	-14.8	7.2	30.7	49.2	53.7	46.5	33.7	9.2	-13.7	-30.7	
	DBStd	33.50	16.09	14.67	13.37	11.69	8.48	7.96	6.52	6.91	9.00	15.18	16.91	15.82	
	HDD50	15007	2461	2189	2009	1283	599	111	37	148	492	1264	1912	2502	
	HDD65	20206	2926	2609	2474	1733	1064	475	352	575	940	1729	2362	2967	
	CDD50	281	0	0	0	0	0	87	153	39	2	0	0	0	
	CDD65	4	0	0	0	0	0	1	3	0	0	0	0	0	
	CDH74	169	0	0	0	0	0	53	92	24	0	0	0	0	
	CDH80	16	0	0	0	0	0	6	9	1	0	0	0	0	
Wind	WSAvg	3.3	1.6	1.6	2.7	3.6	4.0	4.9	4.4	4.3	4.1	3.2	2.7	1.8	
Precipitation	PrecAvg	17.0	0.9	1.1	1.1	0.8	0.8	1.5	2.1	2.4	1.8	1.7	1.8	1.1	
	PrecMax	22.6	1.9	1.8	2.3	1.9	1.5	2.5	4.2	5.6	3.1	3.6	5.4	2.6	
	PrecMin	12.0	0.2	0.2	0.1	0.1	0.2	0.5	0.5	0.7	0.4	0.8	0.5	0.2	
	PrecStd	2.7	0.4	0.5	0.6	0.5	0.4	0.6	0.9	1.1	0.7	0.5	1.0	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	22.6	27.4	35.5	57.8	79.9	80.9	77.0	60.1	43.5	29.9	23.7	
		MCWB	19.3	21.2	24.9	31.7	45.4	61.3	62.3	62.3	48.3	38.6	28.6	22.0	
	2%	DB	16.6	13.1	20.3	32.0	51.5	74.4	76.6	70.4	55.3	37.6	26.2	14.9	
		MCWB	14.6	11.9	17.7	28.4	41.1	58.4	59.9	57.8	46.1	34.8	24.9	13.2	
	5%	DB	9.5	1.7	14.3	29.4	47.3	69.7	73.2	65.1	51.6	33.3	22.7	4.6	
		MCWB	8.2	1.0	12.8	26.3	39.0	54.8	58.8	53.9	45.0	31.1	21.7	3.5	
	10%	DB	-2.3	-5.9	7.2	26.3	43.6	66.1	69.8	60.8	48.1	29.8	15.5	-6.4	
		MCWB	-2.7	-6.3	6.2	23.7	37.2	52.9	57.1	51.7	43.9	27.9	14.9	-6.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	21.1	24.7	32.1	45.7	62.9	64.0	65.2	50.6	39.0	28.7	22.1
			MCDB	20.8	22.7	27.2	34.9	56.6	78.4	75.6	74.9	56.9	42.2	29.5	23.5
2%		WB	14.6	12.1	17.8	29.6	42.2	59.6	61.6	59.1	48.0	34.7	24.8	13.3	
		MCDB	16.5	13.2	20.2	31.8	50.4	71.8	73.7	68.0	52.1	37.3	26.1	14.6	
5%		WB	8.1	1.3	12.8	26.4	39.8	56.4	59.8	54.9	46.0	31.5	21.5	4.1	
		MCDB	9.5	1.7	14.2	29.0	46.0	67.4	71.1	63.2	50.1	33.2	22.7	4.8	
10%		WB	-2.9	-6.2	6.2	23.5	37.7	53.4	58.0	52.5	43.8	27.9	14.9	-6.7	
		MCDB	-2.6	-5.8	7.3	26.3	43.2	64.4	68.1	58.9	48.2	29.7	15.6	-6.4	
Mean Daily Temperature Range	5% DB	MDBR	15.7	17.7	21.2	23.1	16.0	21.6	20.9	19.2	14.3	17.4	15.7	12.0	
		MCDBR	26.4	23.0	20.2	20.7	20.1	28.6	31.3	31.4	22.9	15.8	16.9	21.2	
		MCWBR	24.7	22.1	18.5	17.3	12.0	14.8	16.4	18.2	14.7	12.9	16.1	21.1	
	5% WB	MCDBR	26.0	23.3	19.7	18.4	18.0	27.2	27.0	27.8	20.0	13.6	17.0	21.4	
		MCWBR	24.7	22.5	18.1	15.7	11.2	14.8	14.6	17.1	13.2	12.0	16.2	21.3	
Clear-Sky Solar Irradiance	taub	0.165	0.232	0.289	0.348	0.384	0.364	0.420	0.415	0.305	0.258	0.178	0.160		
	taud	1.962	2.141	2.062	1.922	2.011	2.347	2.192	2.143	2.442	2.197	1.935	1.908		
	Ebn at Noon	147	224	249	255	258	270	247	234	251	206	126	64		
	Edh at Noon	8	19	32	46	47	35	39	37	22	17	8	3		
All-Sky Solar Radiation	RadAvg	62	313	884	1612	1849	1656	1569	1151	687	336	102	23		
	RadStd	6	23	43	60	124	168	132	139	87	47	11	1		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page