

KEDON, Russian Federation

WMO: 256210

Lat: 64.000N

Lon: 158.917E

Elev: 683

StdP: 93.38

Time Zone: 11.00 (E11)

Period: 90-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -48.6	(c) -47.1	(d) -50.2	(e) 0.0	(f) -48.5	(g) -48.5	(h) 0.0	(i) -46.9	(j) 9.4	(k) -8.7	(l) 6.6	(m) -8.3	(n) 0.7	(o) 200	(p) 0.852

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.6	(c) 24.3	(d) 15.3	(e) 22.0	(f) 14.2	(g) 19.9	(h) 13.0	(i) 16.2	(j) 22.8	(k) 14.9	(l) 21.0	(m) 13.6	(n) 18.7	(o) 2.4	(p) 10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.4	10.4	17.8	12.1	9.6	17.5	10.9	8.8	16.2	48.0	23.3	44.3	21.1	40.3	18.6	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.5	(b) 5.4	(c) 4.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.4	-34.1	-33.4	-26.0	-13.8	-0.7	9.6	12.1	8.0	0.9	-12.6	-25.4	-34.8		
	DBStd	18.61	8.94	8.15	7.43	6.50	4.71	4.42	3.62	3.84	5.00	8.43	9.40	8.79		
	HDD10.0	8337	1367	1216	1116	713	333	62	21	82	273	702	1062	1390		
	HDD18.3	11226	1626	1449	1374	963	591	264	196	319	522	961	1312	1648		
	CDD10.0	156	0	0	0	0	0	48	85	22	1	0	0	0		
	CDD18.3	2	0	0	0	0	0	1	2	0	0	0	0	0		
	CDH23.3	94	0	0	0	0	0	29	51	13	0	0	0	0		
	CDH26.7	9	0	0	0	0	0	3	5	1	0	0	0	0		
(14) Wind	WSAvg	1.5	0.7	0.7	1.2	1.6	1.8	2.2	2.0	1.9	1.9	1.4	1.2	0.8		
(15) Precipitation	PrecAvg	433	22	27	28	20	20	39	54	60	46	42	46	28		
	PrecMax	574	48	45	59	48	38	63	107	141	80	91	137	66		
	PrecMin	304	4	6	2	2	5	12	12	17	9	21	13	4		
	PrecStd	68	10	12	16	13	9	14	22	29	18	13	26	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.0	-5.2	-2.5	1.9	14.4	26.6	27.1	25.0	15.6	6.4	-1.2	-4.6		
		MCWB	-7.1	-6.0	-3.9	-0.2	7.4	16.3	16.8	16.8	9.0	3.6	-1.9	-5.6		
	2%	DB	-8.5	-10.5	-6.5	0.0	10.9	23.6	24.8	21.3	13.0	3.1	-3.2	-9.5		
		MCWB	-9.7	-11.2	-7.9	-2.0	5.1	14.7	15.5	14.3	7.8	1.6	-4.0	-10.5		
	5%	DB	-12.5	-16.8	-9.8	-1.5	8.5	21.0	22.9	18.4	10.9	0.7	-5.2	-15.2		
		MCWB	-13.2	-17.2	-10.7	-3.2	3.9	12.6	14.9	12.2	7.2	-0.5	-5.7	-15.8		
	10%	DB	-19.1	-21.1	-13.8	-3.1	6.5	19.0	21.0	16.0	8.9	-1.2	-9.2	-21.3		
		MCWB	-19.3	-21.3	-14.3	-4.6	2.9	11.6	13.9	10.9	6.6	-2.3	-9.5	-21.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.0	-6.0	-4.0	0.1	7.6	17.1	17.8	18.4	10.3	3.9	-1.8	-5.5		
		MCDB	-6.2	-5.2	-2.6	1.6	13.7	25.8	24.2	23.8	13.8	5.7	-1.4	-4.7		
	2%	WB	-9.7	-11.1	-7.9	-1.3	5.7	15.3	16.5	15.1	8.9	1.5	-4.0	-10.4		
		MCDB	-8.6	-10.4	-6.6	-0.1	10.2	22.1	23.2	20.0	11.2	3.0	-3.3	-9.7		
	5%	WB	-13.3	-17.1	-10.7	-3.1	4.3	13.5	15.4	12.7	7.8	-0.3	-5.8	-15.5		
		MCDB	-12.5	-16.8	-9.9	-1.7	7.8	19.6	21.7	17.3	10.1	0.7	-5.2	-15.1		
	10%	WB	-19.4	-21.2	-14.3	-4.7	3.2	11.9	14.5	11.4	6.5	-2.3	-9.5	-21.5		
		MCDB	-19.2	-21.0	-13.7	-3.2	6.2	18.0	20.0	15.0	9.0	-1.3	-9.1	-21.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.8	11.8	12.8	8.9	12.0	11.6	10.7	8.0	9.7	8.7	6.7		
		MCDBR	14.7	12.8	11.2	11.5	11.2	15.9	17.4	17.4	12.7	8.8	9.4	11.8		
	5% WB	MCWBR	13.7	12.3	10.3	9.6	6.7	8.2	9.1	10.1	8.2	7.1	8.9	11.7		
		MCWBR	14.4	12.9	10.9	10.2	10.0	15.1	15.0	15.5	11.1	7.5	9.5	11.9		
(40) Clear-Sky Solar Irradiance	taub		0.165	0.232	0.289	0.348	0.384	0.364	0.420	0.415	0.305	0.258	0.178	0.160		
	taud		1.962	2.141	2.062	1.922	2.011	2.347	2.192	2.143	2.442	2.197	1.935	1.908		
	Ebn at Noon		463	706	785	805	814	852	780	739	790	650	398	202		
	Edh at Noon		26	59	100	146	148	109	124	118	70	55	26	11		
(44) All-Sky Solar Radiation	RadAvg		0.20	0.99	2.79	5.08	5.83	5.22	4.95	3.63	2.17	1.06	0.32	0.07		
	RadStd		0.02	0.07	0.14	0.19	0.39	0.53	0.41	0.44	0.27	0.15	0.04	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page